


Manuale di zenon

Process Gateway

v.7.60





©2017 Ing. Punzenberger COPA-DATA GmbH

Tutti i diritti riservati.

La distribuzione e la copia di questo documento - indifferentemente dal metodo usato - può essere consentita esclusivamente con permesso scritto della ditta COPA-DATA. I dati tecnici servono solo alla descrizione del prodotto e non rappresentano in alcun modo caratteristiche garantite in senso legale. Con riserva di modifiche - anche di tipo tecnico.

Indice

1. Benvenuti nell'help di COPA-DATA.....	7
2. Process Gateway	7
3. General	8
3.1 Variable assignment using names.....	9
4. Requirements.....	10
5. Start.....	10
5.1 Start via Startup Tool	12
5.2 Start via zenon function	13
5.3 Start with command line.....	15
5.4 Module selection	15
5.4.1 First start	16
5.4.2 Change existing module selection.....	16
5.4.3 Start with configured module	17
5.5 INI file.....	18
6. DEC	20
6.1 Module configuration	20
6.2 Logging	21
6.3 Configuration file: specific entries for AccessDEC.....	21
7. DNP3 slave	22
7.1 Module configuration	22
7.1.1 Naming of the variables for DNP3 in the Process Gateway.	27
7.1.2 Variable selection - object settings	28
7.1.3 Unsolicited Responses.....	31
7.1.4 Event Handling	35
7.1.5 Variations per object group - variations.....	37
7.2 Communication - procedure	41
7.3 Select before Operate	42
7.4 Command processing - Command Routing.....	42

7.4.1	LOG - command routing	44
7.5	Device Profile	46
7.6	Configuration file: specific entries for Access DNP3	46
7.7	LATCH_ON and LATCH_OFF	51
7.8	INI file	52
8.	ICCP-TASE.2	57
8.1	Module configuration	59
8.1.1	General	61
8.1.2	Server variables	67
8.1.3	Client variables	71
8.2	Status variables of the connection.....	74
8.3	Show non-present variables in Runtime	77
8.4	Configuration file: INI entries for ICCP-Tase.2	78
8.5	LOG entries	81
8.6	Interoperability	84
9.	IEC870 Slave	85
9.1	Module configuration	85
9.1.1	Communication settings for 870-101	90
9.1.2	Devices	91
9.1.3	Mapping of double point values.....	115
9.1.4	XML-File.....	117
9.2	Communication.....	121
9.2.1	Start	122
9.2.2	General query.....	122
9.2.3	End of connection and resets	123
9.2.4	Transfer of the value changes	124
9.2.5	Reload.....	125
9.2.6	Data priorities.....	125
9.2.7	Internal type T00 (status variable)	125
9.2.8	Time synchronization	128
9.2.9	Broadcasts	128
9.2.10	Mapping of status bits in message direction.....	129
9.2.11	Commands.....	130
9.2.12	File transfer	131

9.2.13	Sequence of Events (SOE).....	133
9.2.14	Read - T102 - request	138
9.2.15	Test - T104 and T107 - requests	139
9.3	Error analysis.....	139
9.3.1	Analysis tool	139
9.3.2	Error codes	143
9.3.3	Check list.....	144
9.4	Interoperability	145
10.	MODBUS Slave	163
10.1	Module configuration	164
10.2	Hardware address of the MODBUS system	167
10.3	Configuration file: specific entries for AccessMODBUS	167
11.	MS Azure.....	169
11.1	Module configuration	170
11.1.1	MS Azure Connection Settings	173
11.2	Message formats.....	176
11.3	Error message	177
11.4	Configuration file: specific entries for MS Azure	179
12.	OPC UA Server.....	181
12.1	Confronto fra OPC Server e OPC UA Server	181
12.2	Module configuration	183
12.2.1	Server	184
12.2.2	Variables	191
12.3	Start.....	194
12.4	Connection	195
12.5	Security	195
12.6	Alarms and Conditions	196
12.7	Service Sets	199
12.8	Communication.....	200
12.9	Configuration file: INI entries for OPC UA.....	203
12.10	Error message	206
12.11	Status mapping	207
13.	SNMP agent	208

13.1	SNMP architecture	208
13.2	Management Information Base (MIB)	209
13.3	MIB structure	209
13.4	Module configuration	211
13.5	Configuration file: specific entries for Access SNMP	212
13.6	Configuration of the Windows SNMP agent	212
14.	SQL	214
14.1	Module configuration	214
14.2	Variable selection.....	215
14.3	Creating tables	216
14.4	Operation in a redundant system	216
14.5	Configuration file: specific entries for AccessSQL	217
14.6	Table format.....	218
14.6.1	Table for process image	218
14.6.2	Table for variable IDs.....	218

1. Benvenuti nell'help di COPA-DATA

VIDEO TUTORIAL DI ZENON

Nel nostro canale YouTube (https://www.copadata.com/tutorial_menu) si trovano esempi pratici di progettazione con zenon. I tutorial sono raggruppati per tema e forniscono una panoramica di come si lavora con i diversi moduli di zenon. Tutti i tutorial sono disponibili in lingua inglese.

GUIDA GENERALE

Se non avete trovato le informazioni che cercavate o se avete dei consigli relativi al completamento di questo capitolo dell'help, potete scrivere una E-Mail all'indirizzo documentation@copadata.com (<mailto:documentation@copadata.com>).

SUPPORTO ALLA PROGETTAZIONE

Se avete domande che riguardano progetti concreti, potete rivolgervi via E-Mail all'indirizzo support@copadata.com (<mailto:support@copadata.com>).

LICENZE E MODULI

Se avete bisogno di nuovi moduli o licenze, potete rivolgervi ai nostri collaboratori all'indirizzo sales@copadata.com (<mailto:sales@copadata.com>).

2. Process Gateway

*The **Process Gateway** serves as a coupling to higher-level systems, such as a Control Center. This means that parts of the zenon process image are provided for other applications and updated by these.*

- ▶ Process data from zenon Runtime can be forwarded to superordinate systems.
- ▶ Superordinate systems can write values or commands to zenon Runtime.



Informazioni sulla licenza

Nell'Editor e nel Runtime (standalone, server, standby e client) è necessaria una licenza.



Info

*The **Process Gateway** user interface is only available in English.*

3. General

The following is applicable for the **Process Gateway**:

- ▶ It is thought as an add-on to the Runtime of the control system and only works in combination with it.
That means: If zenon Runtime has not been started, the Process Gateway does not start!
- ▶ Several **Process Gateways** can be started on one computer.
You can find further information on this in the Start with command line (A pagina: 15) chapter.
- ▶ The Process Gateway can be started on both a standalone computer as well as in the zenon network (server/standby/client). All Process Gateways that are started in the network provide the same process image.
- ▶ The module to be started is selected and configured in its own INI file (A pagina: 10) of the Process Gateway, not in the zenon6.ini file as is otherwise the case for zenon!
The INI file for the **Process Gateway** is called `zenProcGateway.INI` and is in the `%CD_SYSTEM%` folder. With a standard installation, the storage folder is `C:\ProgramData\COPA-DATA\System` by default.

PROJECT SELECTION

If no special project name is defined in the configuration file (`zenProcGateway.ini`), all configurations of the Process Gateway are applicable to the first project loaded by Runtime.

In a multi-project system, it is possible to access any desired project in the hierarchy. To do this, enter the project name in the **Project=** entry in the **[GENERAL]** section in the INI file. If this entry is empty, the integration project is applicable.

3.1 Variable assignment using names

In the **Process Gateway**, the respective assignment is carried out using the variable name.

This is important if:

- ▶ Variable names in the project configuration are changed in zenon Editor.
- ▶ Variables in the project configuration in the Editor are deleted.
- ▶ zenon calls up a new start project.


In this case, module-independent error dialogs appear when Process Gateway is started.



Attenzione


If a variable assignment is erroneous, the Process Gateway is not started! The Process Gateway only starts if the incorrect variable assignment has been corrected.

The first error dialog lists the unknown variables.



- ▶ In this case, amend the variable assignment again.
- ▶ To do this, remove all incorrectly-assigned variables from the respective export area and re-add the corresponding variables.

The dialog that follows contains module-dependent error messages.



LOG ENTRY


The following LOG entry is created in the event of incorrect variable assignment:

LOG entry	Description
Failed to update value for variable %s.	No COM connection to zenon could be established, or the variable is not (or no longer) available in zenon or has been renamed.

4. Requirements

On the computer on which the **Process Gateway** should run, the Runtime with the corresponding release version and a loaded project that corresponds to the configuration has to be started before it is started. If Runtime is stopped, the Process Gateway is also stopped automatically.

If zenon Runtime is not loaded when Process Gateway is started, a corresponding warning dialog is shown:



Info

The **Process Gateway** uses the COM interface to access zenon data. The COM interface is used by VBA and is only available if **zenon6.ini** is present in the file under **[VBA]** the entry **EVENT=1**.

5. Start

The **Process Gateway** consists of the **zenProcGateway.exe** file. This is copied to the zenon program folder during installation. However, it can also be used in a different folder.

Attention: The module (Accesss*.dll) to be used with the Process Gateway has to be in the same folder as **zenProcGateway.exe**.

Exception: **SNMP** (A pagina: 212).

The **zenProcGateway.ini** configuration file is in the %CD_SYSTEM% system folder. In this INI file, the **DLL=** entry (in the **[GENERAL]** section) determines the module with which the **Process Gateway** starts.

PROCESS GATEWAY - START

The Process Gateway can be started:

- ▶ via Startup Tool (A pagina: 12)
- ▶ via zenon function (A pagina: 13)

In both start methods, the **Process Gateway** can be started with parameters in the command line interface (A pagina: 15). Different INI files of the **Process Gateway** can thus be determined.

CONFIGURATION

The configuration consists of two parts.

- ▶ Module selection (A pagina: 15)
In the first stage of configuration, select the module that communicates with the Process Gateway.
You can find further information on this in the module selection chapter.
- ▶ Module-specific configuration
Depending on the selected module, connection parameters and variable assignments can be configured.
You can find details on this from the module configuration chapter in the respective section in this handbook.

All configurations of the Process Gateway are saved in an INI file. Please note that not all entries of the corresponding INI file can be configured via a corresponding user interface.

The module is determined with the **DLL=** entry (in the **[GENERAL]** section).

Possible entries:

Module	Entry
DEC	DLL=AccessDEC.dll
SQL	DLL=AccessSQL.dll
MODBUS	DLL=AccessMODBUS.dll
DNP3	DLL=AccessDNP3.dll
IEC870SI	DLL=AccessIEC870S1.dll
SNMP	DLL=AccessSNMP.dll
OPCUA	DLL=AccessOPCUA.dll
ICCP/TASE.2	DLL=AccessICCP.dll
MS Azure	DLL=AccessAzure.dll

SECURITY CONFIGURATION

The Process Gateway can be executed hidden to protect it from unauthorized access. If the Process Gateway is started in the command line with the parameter `/hide` (or `-hide`), it starts invisible and cannot be configured or stopped. The Process Gateway closes automatically when the zenon Runtime is closed.


5.1 Start via Startup Tool

The **Process Gateway** can be started via the zenon **Startup Tool**.

To do this, carry out the following steps:

1. Open the zenon **Startup Tool**.
2. Click **Tools**.

The dialog for configuring the zenon Tools is opened.



3. Select **Process Gateway**.
4. Click the Start button to start the Process Gateway with the configuration from the current `zenProcGateway.INI` file.

Or:

Enter the name of the EXE and the name of the INI file as a start parameter into the **Command line parameters**:

zenProcGateway.EXE /ini:MyConfig.INI

You can find further information on this in the Start with command line (A pagina: 15) chapter.


Note: The parameters alone are not sufficient. The **zenProcGateway.EXE** call must be entered.

5. Click on **Start**.

5.2 Start via zenon function

The Process Gateway can - like any other Windows application - be started with the **Eseui programma** function.

ENGINEERING



Procedura di creazione della funzione:

1. Creare una nuova funzione:
Nella barra degli strumenti, oppure nel menù contestuale del nodo "Funzioni", selezionare il comando **Nuova funzione**.
Si apre la finestra di dialogo che consente di selezionare una funzione.
2. Navigate to the node **Windows**.
3. Select the **Esegui programma** function.
The dialog to select the program and enter start parameters is opened.
4. Select the desired program.
 - a) Click on the button ...
The file selection dialog is opened.
 - b) Go to the zenon Installation directory:
Program Files (x86) - 64-bit operating system
Program Files - 32-bit operating system
 - c) Select the file zenProcGateway.exe
 - d) Confirm the selection by clicking on the **Open** button
5. Optional: Configure the parameters that are executed when the function is executed.
You can find further information on this in the Start with command line (A pagina: 15) chapter.
If this parameter is empty, the **Process Gateway** starts with the zenProcGateway.INI file.
6. Close the dialog by clicking on the **OK** button.
7. Assegnare un nome alla funzione nella proprietà **Nome**.



Suggerimento

If this function is linked in the AUTOSTART script, Process Gateway automatically starts with Runtime.*

5.3 Start with command line

Several **Process Gateways** can be started on one computer. To do this, a separate INI file must be present for each **Process Gateway** to be started. The INI file must be in the system folder (%CD_SYSTEM%).

Examples of use:

- ▶ Simultaneous start of several Process Gateways with different modules
- ▶ Start several instances of Process Gateway with the same module (not applicable for all modules).
Requirement: separate communication parameters for each instance, for example no conflicts in IP ports.

In this case, the **zenProcGateway.EXE** must be started with the command line parameter **/ini:[file]**.

Syntax of command line:

- ▶ In the Startup Tool:
`zenProcGateway.EXE /ini:[FileName].INI`
- ▶ In the zenon **Esegui programma** function
Parameter input field: `/ini:[file name].INI`

`[FileName].ini` must be replaced by the correct name of the INI file.


5.4 Module selection

The following possibilities are available for the selection of a module for the **Process Gateway**:

- ▶ First start
When the **Process Gateway** is started for the first time, a dialog to select the module is shown. This selection dialog is also offered when the **Process Gateway** is started if there is no INI file or if no module is configured in the selected INI file.
The `zenProcGateway.INI` file is used by default.
- ▶ Module already configured
If a module has already been configured for Process Gateway, Process Gateway starts with the communication dialog of the configured module.
When the **Process Gateway** starts, communication already starts if all necessary connection parameters for the module have been configured and are valid.

5.4.1 First start

The module must be configured when it is started for the first time.



To start **Process Gateway** with a selectable module:

1. Start **Process Gateway** with an INI file that does not exist (there must be no other module configured in the INI file).
Process Gateway uses the file `zenProcGateway.INI` by default. You can define another file in the command line (`/ini:[FileName].INI`).
You can find more information in the **Start with command line** (A pagina: 15).
2. The dialog to select the module is opened.
3. Select the desired module.
4. Confirm your selection by clicking on the **OK** button.
The **Process Gateway** then creates your INI file.
5. The **Process Gateway** starts with the communication dialog (A pagina: 17) of the selected module.

5.4.2 Change existing module selection


If the Process Gateway starts with a module that has already been configured for a different communication protocol, without offering the dialog to select a module, then:

1. Close the **Process Gateway**.
2. Edit the existing `zenProcGateway.INI` file.
 - a) To do this, go to the `%CD_SYSTEM%` directory.

- b) Open the file in any desired text editor and add comments for the module in the file; or rename the INI file.
3. Restart the **Process Gateway**:
If the INI file has been removed, the dialog to select a module (A pagina: 16) is offered again when **Process Gateway** starts.

5.4.3 Start with configured module

Start the **Process Gateway** with a module that has already been configured; a dialog with static communication data is opened.



Parameter	Description
Statistic information	Information on communication with the counterparty:
Exit	Closes process gateway.
Configuration	Opens the module's configuration dialog.
Help	Opens online help.



Attenzione

If the application is started as `invisible`, there is also no configuration dialog displayed. If the configuration is invalid or not present, the process gateway is automatically closed.

5.5 INI file

The **Process Gateway** saves the both the module selection and the module-specific configurations in the INI file.

The module-specific configurations between the modules are very different. Please note the detailed documentation in the module-dependent INI entries in this manual.

Per motivi che hanno a che fare con il sistema, solamente ANSI e Unicode sono supportati per la lettura dei file INI.



Attenzione

Il formato di salvataggio UTF-8 non viene supportato!

Perciò salvate sempre i vostri file INI come file di testo in formato ANSI o Unicode.

MODULE-INDEPENDENT CONTENT

[GENERAL]

Inserimento	Descrizione
[GENERAL]	Impostazioni generali per il Process Gateway, indipendentemente dal modulo prescelto.
DLL=	<p>Selezione del file DLL da usare per il Process Gateway. Il file DLL selezionato determina la scelta del modulo.</p> <ul style="list-style-type: none"> ▶ AccessDEC.dll ▶ AccessSQL.dll ▶ AccessMODBUS.dll ▶ AccessDNP3.dll ▶ AccessIEC870Si.dll ▶ AccessSNMP.dll ▶ AccessOPCUA.dll ▶ AccessICCP.dll ▶ AccessAzure.dll


[DATABASE]

Entry	Description
PROJECT=	<p>Name of the zenon project with which Process Gateway communicates with Runtime.</p> <p>In a multi-project system, it is possible to access any desired project in the hierarchy. If this entry is empty, the integration project is applicable.</p> <p>Default: Empty (project currently loaded in Runtime)</p>


6. DEC

6.1 Module configuration

The following dialog appears after the **Settings** button is clicked:



Here the variables that should be connected can be selected. In the list on the left-hand side all variables which are available in zenon are displayed. These can be selected and moved to the DEC export list with the '>' button. With the button '<' they can be removed again. If a variable is moved to the export list, a dialog for the name assignment of the zenon variable to the DEC variable opens:



The assignment is defined with a four digit press number and the four digit parameter name. Entered characters are automatically changed to upper case. The variables selected in this way then are continuously synchronized in zenon or in the connected DEC system.

In the lower part of the configuration dialog the TCP/IP connection to the DEC system can be configured.

The port number indicates the port where the Process Gateway waits for incoming connections.

The timeout is the time without response, after that the connection is closed.

6.2 Logging

All telegrams received by the DEC system and the responds from the Process Gateway can be logged.

To do this an entry LOGFILE in the section [DEC] of the configuration file with the name of the log file has to exist. This file then is created in the same folder as `zenProcGateway.exe`.

Example for this entry:

[DEC]

LOGFILE=zenProcGateway.log

6.3 Configuration file: specific entries for AccessDEC

The configuration file must be in the system folder.

Nota: Il file di configurazione deve trovarsi nella cartella di sistema.


[DEC]

Inserimento	Descrizione
LOGFILE=	Nome del file LOG (se lo si desidera, per es. zenProcGateway.log)
PORT=	Numero di porta dove il Process Gateway attende tentativi di connessione.
TCPTIMEOUT=	Intervallo di timeout alla cui scadenza viene interrotta la connessione
REFRESHRATE=	Intervallo in millisecondi in cui il sistema verifica se ci sono modifiche dell'immagine di processo di zenon.

7. DNP3 slave

7.1 Module configuration

The following dialog appears in the Process Gateway after the **Settings** button is clicked:



VARIABLES

Here the variables that should be connected can be selected. On the left-hand side all variables which are available in zenon are displayed. You can select them there and move them to the DNP3 export list with the button >. With the button < they can be removed again.

As a result of the fact that variables are selected from a list, it is ensured that each variable is only used once.

The point list (**Exported into DNP3**) also contains the project reference of a variable. If a variable belongs to the default project, it is displayed with "[Project]#[Variable Name]" in the point list. If it belongs to the default project (marked with *), it is only listed in the point list with the variable name.

If a variable is moved to the export list, a dialog for the name assignment of the zenon variable to an object and point number in DNP3 opens.

The variables selected in this way then are available in the DNP3 slave and are continuously synchronized between zenon and the DNP3's object database.

ALLOCATION OF OBJECT GROUPS TO EVENT CLASSES

The allocation of object groups to event classes is defined and fixed and is as follows:

Event Class 1: Binary inputs

Event Class 2: Analog inputs

Event Class 3: Binary Outputs, Analog Outputs, Running Counters, Octet Strings

VARIABLES

Parameter	Description
VARIABLES	Area for variable selection, depending on the selected project.
Available in SCADA	Area for the display of the available projects and the variables assigned to the selected project.
Projects	<p>List of the projects available in the DNP3 module of the Process Gateway.</p> <p>The default project is marked with a * in front of the project name. This is generally the configured start project.</p> <p>Exception: A different file is configured in the INI file.</p> <p>Please also note the information on naming the variables for DNP3 (A pagina: 27) in the Process Gateway.</p>
Variables	<p>List of all variables of the selected project available in zenon. These are also displayed by selecting a project by clicking in the Projects area.</p> <p>The variables are selected in this area and applied using the > button in the Exported into DNP3 area.</p> <p>Note: Multiple selection (Shift or ALT key) is possible.</p>
Button >	<p>Selected variables from the Variables list are moved to Exported into DNP3.</p> <p>Clicking on the > button opens the object settings (A pagina: 28) dialog.</p>
Button <	<p>Selected variables are removed from the Exported into DNP3 list.</p>
Exported into DNP3	<p>Export list of the assigned variables.</p> <p>Double clicking on the entry opens the object settings (A pagina: 28) dialog.</p> <p>The variables selected in this way are available on the DNP3 slave. These variables are continually synchronized between zenon and the DNP3 object database.</p> <p>Please also note the information on naming the variables for DNP3 (A pagina: 27) in the Process Gateway.</p>

DNP3 CONNECTION

In the lower part of the configuration dialog the serial or TCP/IP connection for the DNP3 slave can be configured.

Parameter	Description
Unsolicited Responses	<p>Button for the configuration of responses that are not requested (Unsolicited Responses), which the Process Gateway sends to the DNP3 master.</p> <p>Attention: The DNP3-Master can also request Unsolicited Responses from the Process Gateway. However to do this, the functionality must be activated in the Process Gateway.</p> <p>The number of events and the maximum time delay can be configured for each event class.</p> <p>Timeout and Retry are given for all event classes together.</p> <p>Clicking on the button opens the configuration dialog.</p> <p>Note: Entries are remanent.</p>
Event Handling	<p>Button for the configuration of event handling</p> <p>Clicking on the button opens the configuration dialog.</p>
Variations	<p>Button for the configuration of the Variations per object group.</p> <p>Clicking on the button opens the configuration dialog.</p>
SELECT Timeout [ms]	<p>Timeout for <code>Select</code> before <code>Operate</code>. An <code>Operate</code> from the master is expected within the configured time.</p> <p>Default: 5000 ms</p> <p>Input range: 1000 to 65000</p>
Local Session Link Adress	<p>Link address of the slave.</p> <p>Default: 3</p> <p>Note: Only one active session is supported, regardless of whether serial or TCP/IP communication is used.</p>
Remote Link Address (Master)	<p>Link address of the master.</p> <p>Default: 4</p> <p>Note: Only one active session is supported, regardless of whether serial or TCP/IP communication is used.</p>
Time Zone	<p>Button to select the time format:</p> <ul style="list-style-type: none"> ▶ Local Time ▶ UTC

SERIAL

Serial	Configurations of the serial interface for communication on the DNP3 slave
Port	<p>Drop-down list for the configuration of the communication interface:</p> <p>Value range: COM 1 to COM 64</p> <p>Default: COM 1</p> <p>Note: Only active if Serial is activated as the communication method.</p>
Stop Bits	<p>Drop-down list for the configuration of the number of stopbits transferred:</p> <ul style="list-style-type: none"> ▶ 1 ▶ 1,5 ▶ 2 <p>Default: 1</p> <p>Note: Only active if Serial is activated as the communication method.</p>
Parity	<p>Drop-down list for the configuration of the parity:</p> <ul style="list-style-type: none"> ▶ No ▶ Odd ▶ Even <p>Default: No (= no parity)</p> <p>Note: Only active if Serial is activated as the communication method.</p>
Data Bits	<p>Drop-down list for the configuration of the number of data bits transferred:</p> <ul style="list-style-type: none"> ▶ 5 ▶ 6 ▶ 7 ▶ 8 <p>Default: 8</p> <p>Note: Only active if Serial is activated as the communication method.</p>
Baudrate	<p>Drop-down list to select the Baud rate for serial interface communication.</p> <p>Selection options: 110, 300, 600, 1200, 2400, 4800, 9600, 19200, 38400, 56000, 57600, 115200, 128000, 256000</p>

	Default: 9600 Note: Only active if Serial is activated as the communication method.
--	--

TCP/IP

TCP/IP	Configurations for communication in a network via TCP/IP.
Port Input field for the configuration of the "Listener-/Horch-" protocol port Default: 20000 Note: Only active if TCP/IP is activated as the communication method.	

CLOSE DIALOG

OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.

7.1.1 Naming of the variables for DNP3 in the Process Gateway.


The variable name of the DNP3 slave for communication to the DNP3 master comprises the following components:

- ▶ Project name
- ▶ #
A # character is inserted after the project name as a separator
Attention: There is no project name and separator with start projects!
 If a variable name in the DNP3 module of the Process Gateway is not preceded by a project, the project defined in the INI file (A pagina: 46) is automatically placed in front for communication to the DNP3 master.
 If there is no project defined in the INI file, this corresponds to the start project in Runtime.
 The start project is marked with a * in the module configuration (A pagina: 22), in the **Available in SCADA** group, in the **Projects** .
- ▶ Variable name
As configured in zenon.
- ▶ Object type
As configured in the Object Settings (A pagina: 28) dialog.

- ▶ Point index
As configured in the Object Settings (A pagina: 28) dialog.
- ▶ Event handling
As configured in the Object Settings (A pagina: 28) dialog.

7.1.2 Variable selection - object settings

If a variable is moved to the export list, a dialog for the name assignment of the zenon variable to an object and point number in DNP3 opens:



The variables selected in this way then are available in the DNP3 slave and are continuously synchronized between zenon and the DNP3's object database.

SETTINGS

Parameter	Description
Name	<p>Name of the variable for which the configurations can be carried out.</p> <p>Note: For information only and grayed out, because it cannot be changed.</p>
Object	<p>Drop-down list to select the driver data type to the driver</p> <ul style="list-style-type: none"> ▶ Analog Inputs ▶ Analog Output Status (written value is mirrored as a response after successful writing) ▶ Binary Inputs ▶ Binary Output Status ▶ Running Counters ▶ String Data <p>Default: Binary inputs</p>
Event Handling	<p>Denotes which events can be processed:</p> <ul style="list-style-type: none"> ▶ Default Events are handled as defined in the object group. For this, please note the configuration in the Event handling (A pagina: 35) dialog. ▶ SOE Events are treated as a Serie of Events. ▶ Most recent Only the last change of a binary change event is retained. <p>Note: Inactive if the data type is <code>string data</code>.</p> <p>Default: Default</p>
Point	<p>Pointindex for the event.</p> <p>Default: 0</p> <p>Note: Ensure that the point index is unique for each variable. It is recommended that that the point index is started at 0 and numbered incrementally.</p>
Enable SBO routing	<p>Checkbox for the activation of command processing (command routing). The <code>Command Routing</code> can be configured individually for each variable.</p> <ul style="list-style-type: none"> ▶ Active:

	<p>Communication includes Command Routing</p> <ul style="list-style-type: none"> ▶ Inactive: Communication is carried out without Command Routing. <p>Note: only active if, in the Object drop-down list, the Binary Output _Status entry has been selected.</p>
--	---

CLOSE DIALOG

OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	<p>Annulla tutte le modifiche e chiude la finestra di dialogo.</p> <p>Note: The variable is in this case not available on the DNP3 slave.</p>




Info

If several variables have been selected during module configuration, a switch to the configuration dialog of the next variable is made by clicking on the **OK** or **Cancel** buttons. A separate configuration dialog is thus called up step by step for each selected variable.

7.1.3 Unsolicited Responses

Dialog for the configuration of the Unsolicited Responses in the object settings:



The dialog box, titled "Object Settings", contains the following configuration options:

- ☒ Enable unsolicited response
- Timeout: 5 s
- Number of retries: 3
- Event Class 1
 - Maximum Number of Events: 5
 - Maximum Delay: 5 s
- Event Class 2
 - Maximum Number of Events: 5
 - Maximum Delay: 5 s
- Event Class 3
 - Maximum Number of Events: 5
 - Maximum Delay: 5 s

At the bottom are "OK" and "Cancel" buttons.

Parameter	Description
Enable unsolicited response	<p>Check box to activate the use of Unsolicited responses. If this check box is not activated, no unsolicited responses are generated.</p> <p>Default: <i>Inactive</i></p> <p>Note: If this property is not active, all of the following entries are grayed out.</p> <p>Attention: If this option is not active, no unsolicited responses are sent to the master. Even if these are requested by the master.</p>
Timeout	<p>Time in seconds for communication to the master. A time exceedance is triggered once this time has expired.</p> <p>Input range: 1 to 60 s</p> <p>Default: 5 s</p> <p>Note: This setting depends on the type and speed of its communication to the master. In principle, the slower the communication, the higher the Timeout time.</p>
Number of retries	<p>Number of retries for communication to the master.</p> <p>Input range: 0 – 65535 (0 = an infinite amount of attempts)</p> <p>Default: 3</p> <p>Example: If an unsolicited response is sent to the master, this is confirmed by the master. If this confirmation from the master remains outstanding, a confirmation is sent as many times as configured in Number of retries. A new unsolicited response is then created.</p>

EVENT CLASS 1

Maximum Number of Events	<p>Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response.</p> <p>Intervallo di input: 0 – 255</p> <p>Default: 5</p>
Maximum Delay	<p>Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i>.</p> <p>Intervallo di input: 0 – 65535 secondi (0 = nessun ritardo, cioè al cambio di valore).</p>

	Default: 5
--	------------

Maximum Number of Events and **Maximum Delay** work together. The value that is reached first triggers communication to the master.

Note: You can also prioritize the three event classes with these entries.

EVENT CLASS 2

Maximum Number of Events	<p>Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response.</p> <p>Intervallo di input: 0 - 255 Default: 5</p>
Maximum Delay	<p>Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <code>unsolicited response</code>.</p> <p>Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5</p>

EVENT CLASS 3

Maximum Number of Events	<p>Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response.</p> <p>Intervallo di input: 0 - 255 Default: 5</p>
Maximum Delay	<p>Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <code>unsolicited response</code>.</p> <p>Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5</p>

CLOSE DIALOG

OK	Applica le impostazioni e chiude la finestra di dialogo.
-----------	--


Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.
---------------	---

7.1.4 Event Handling

Configuration dialog for event groups and their behavior when the value of variable is changed.

Possible options are:

- ▶ Behavior on deletion
- ▶ Behavior on value change
- ▶ Buffer size



The 'Event Handling' dialog box is shown with a blue title bar and a close button (X) in the top right corner. It contains several sections for configuring event handling:

- Delete on buffer overflow:** Radio buttons for ☒ Oldest and ☐ Newest.
- Binary Change Events:** Radio buttons for ☐ Most recent and ☒ SOE; a text box for Buffer Size with value 100.
- Binary Output Events:** Radio buttons for ☐ Most recent and ☒ SOE; a text box for Buffer Size with value 100.
- Counter Events:** Radio buttons for ☒ Most recent and ☐ SOE; a text box for Buffer Size with value 100.
- Analog Change Events:** Radio buttons for ☒ Most recent and ☐ SOE; a text box for Buffer Size with value 100.
- Analog Output Events:** Radio buttons for ☐ Most recent and ☒ SOE; a text box for Buffer Size with value 100.
- String Events:** A text box for Buffer Size with value 100.

At the bottom right, there are 'OK' and 'Cancel' buttons.

Parameter	Description
Delete on buffer overflow	<p>Global setting for which event is deleted when the buffer is full:</p> <ul style="list-style-type: none"> ▶ Oldest Oldest entries are deleted. ▶ Newest Most recent entries are deleted. <p>Default: Oldest</p>

BINARY CHANGE EVENTS

Parameter	Description
Buffer Size	<p>Setting for buffer size for the respective event group.</p> <p>Input range: 1 – 65535 Default: 100</p>

BINARY OUTPUT EVENTS

Parameter	Description
Buffer Size	<p>Setting for buffer size for the respective event group.</p> <p>Input range: 1 – 65535 Default: 100</p>

ANALOG CHANGE EVENTS

Parameter	Description
Buffer Size	<p>Setting for buffer size for the respective event group.</p> <p>Input range: 1 – 65535 Default: 100</p>

ANALOG OUTPUT EVENTS

Parameter	Description
-----------	-------------

Buffer Size	Setting for buffer size for the respective event group. Input range: 1 – 65535 Default: 100
--------------------	---

COUNTER EVENTS

Parameter	Description
Buffer Size	Setting for buffer size for the respective event group. Input range: 1 – 65535 Default: 100

STRING EVENTS

Parameter	Description
Buffer Size	Setting for buffer size for the respective event group. Input range: 1 – 65535 Default: 100

CHIUDERE LA FINESTRA DI DIALOGO.

Opzione	Descrizione
Ok	Applica le impostazioni e chiude la finestra di dialogo.
Annulla	Annulla tutte le modifiche e chiude la finestra di dialogo.


7.1.5 Variations per object group - variations

In this dialog, (Variations) can be configured for the following object groups:

- ▶ 1 Binary Input
- ▶ 2 Binary Input Event
- ▶ 10 Binary Output

- ▶ 11 Binary Output Event
- ▶ 20 Counter
- ▶ 22 Counter Event
- ▶ 30 Analog Input
- ▶ 32 Analog Input Event
- ▶ 40 Analog Output Status
- ▶ 42 Analog Output Event

Different variations are supported depending on the object group:



The screenshot shows a dialog box titled "Default Variations" with a close button (X) in the top right corner. The dialog contains a section labeled "Variations" with a grid of dropdown menus for different object groups. The settings are as follows:

Object Group	Selected Variation
Binary Input	1: packet format
Binary Input Event	3: with relative time
Binary Output	2: with flags
Binary Output Event	1: status without time
Counter	5: 32 bit without flag
Counter Event	1: 32 bit with flag
Analog Input	6: double precision, floating-point with flag
Analog Input Event	6: double precision, floating-point without time
Analog Output	2: 16 bit with flag
Analog Output Event	2: 16 bit without time

At the bottom right of the dialog are "OK" and "Cancel" buttons.

Parameter	Description
Binary Input	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Binary Input:</p> <p>1: packet format 2: with flags</p> <p>Default: 1: packet format</p>
Binary Input Event	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Binary Input Event:</p> <p>1: without time 2: with absolute time 3: with relative time</p> <p>Default: 3: with relative time</p>
Binary Output	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Binary Output:</p> <p>1: packet format 2: with flags</p> <p>Default: 1: with flags</p>
Binary Output Event	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Binary Output Event:</p> <p>1: status without time 2: status with time</p> <p>Default: 1: status without time</p>
Counter	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Counter:</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit without flag 6: 16 bit without flag</p> <p>Default: 5: 32 bit without flag</p>
Counter Event	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.Counter Event:</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit flag and time 6: 16 bit flag and time</p> <p>Default: 1: 32 bit with flag</p>

Analog Input	<p>Menù a tendina con le Variations supportate per il gruppo oggetti. Analog Input:</p> <ul style="list-style-type: none"> 1: 32 bit with flag 2: 16 bit with flag 3: 32 bit without flag 4: 16 bit without flag 5: single precision, floating-point with flag 6: double precision, floating-point with flag <p>Default: 6: double precision, floating-point with flag</p>
Analog Input Event	<p>Menù a tendina con le Variations supportate per il gruppo oggetti. Analog Input Event:</p> <ul style="list-style-type: none"> 1: 32 bit without time 2: 16 bit without time 3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time 7: single precision, floating-point with time 8: double precision, floating-point with time <p>Default: 6: double precision, floating-point without time</p>
Analog Output	<p>Menù a tendina con le Variations supportate per il gruppo oggetti. Binary Input:</p> <ul style="list-style-type: none"> 1: 32 bit with flag 2: 16 bit with flag 3: single precision, floating-point with flags 4: double precision, floating-point with flags <p>Default: 2: 16 bit with flag</p>
Analog Output Event	<p>Menù a tendina con le Variations supportate per il gruppo oggetti. Analog Output Event:</p> <ul style="list-style-type: none"> 1: 32 bit without time 2: 16 bit without time 3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time

	7: single precision, floating-point with time 8: double precision, floating-point with time Default: 2: 16 bit without time
--	---

CHIUDERE LA FINESTRA DI DIALOGO.

Opzione	Descrizione
Ok	Applica le impostazioni e chiude la finestra di dialogo.
Annulla	Annulla tutte le modifiche e chiude la finestra di dialogo.

7.2 Communication - procedure

Value changes are executed via COM. An update in stack direction only occurs if:

- ▶ It is the first value for the object (initial value).
- ▶ The value changes (value change).
- ▶ The status bits `Invalid` or `Not current` change (value change of the status bit).

The time stamp of the change is applied in the event of a change. This time stamp is applied from the COM event and transferred to the stack event. The Time Zone setting determines the type of time stamp:

- ▶ Local time or
- ▶ UTC time

The stack no longer checks for a value change, but the gateway cyclically takes the value changes from the queue of the COM threads and forwards them to the stack for entry into the event buffer of the corresponding object group. Event values and static values (with poll in the stack) are read from the shadow of the item and no longer from the shared memory. The time stamp is applied from the COM event and transferred to the stack event as a local time with millisecond precision.

Binary and analog output variables are written from the master to the Process Gateway.

In addition, these variables send the value back to the master, the same thing that binary and analog input variables do if the assigned variables are changed in zenon Runtime.

As a result of the fact that variables are selected from a list, it is ensured that double selection is prevented.

7.3 Select before Operate

Analog Outputs and Binary Outputs have SBO (Select before Operate) functionality. For this, the following applies:

- ▶ The DNP3 master sends a `Select` command to the outstation.
- ▶ When the `Binary Output` object type is requested, the following requirements must be met in order for the request to be answered in the positive:
 - The variable exists and is signed in or can be signed in.
 - The data type of the variable is `IEC_BOOL` or `IEC_USINT`
 - The value of the command is valid:
`NUL`, `PulseOn`, `PulseOff`, `LatchOn`, `LatchOff`, `PulseOn + Close`, `PulseOn + Trip`
- ▶ Requests of the `Analog Output` object type are always answered in the positive
- ▶ The configured `Select` timeout is activated automatically.
 If, within this timeout, there is no `Operate` command received for the respective variable, the processing of the variable is ended automatically.
Note: If, instead of an `Operate Request`, a different `Request` is received for the respective variable, the sequence number is incorrect or the `Operate Request` does not correspond to the `Select Request`. Processing is ended automatically.
- ▶ An `Operate Request` without a previous `Select Request` is acknowledged with an error.



Suggerimento

You can find further general information on *Select before Operate* in the Energy Edition manual, **Command Processing** in the Execution of a command chapter.

7.4 Command processing - Command Routing

Basic requirements for the positive execution of the `Select` or `Operate` command are:

- ▶ The variable type is `Binary Output`
- ▶ The variable exists, is signed in or can be signed in, and is valid (no I-Bit).
- ▶ The data type of the variable is `IEC_REAL`, `IEC_BOOL` or `IEC_USINT`.
- ▶ The control code is valid and can be converted to a Boolean value-
 The following values are valid (the corresponding Boolean value is stated in brackets):
 - `NUL` (`false`)
 - `PulseOn` (`true`)

- PulseOff (false)
- LatchOn (true)
- LatchOff (false)
- PulseOn + Close (true)
- PulseOn + Trip (false)

PROCEDURE

In general, the following applies: Command routing is only activated for exported `Binary Output` variables for which the **Command Routing** option has been activated.

- ▶ If a `Select` command is received for a `Binary Output` for which the **Command Routing** option has been deactivated, a positive `Response` is returned to the master, provided the basic requirements have been met.
- ▶ If, for `Binary Output`, the **Command Routing** option has been set, the `COT_act` command with the control code is sent to the command variable (configured with **Binary Output**), in the Runtime.
Note: `COT_act` is coded in the status value with the help of the `COT_act`, `S_SE_BIT` and `S_SELECT` bits.
- ▶ There is then a wait for the execution of the `Select` command by the auto-remote command action, before the `Response` is sent to the master.
 Only once there is a positive response to the `Select` command sent to the master does the `Select Timeout Timer` start.
- ▶ The processing of the following `Operate` command is carried out in the same way as for the `Select` command. In addition, for an `Operate` command, there is a check to see whether a `Select`-command has been received before the command is forwarded to the command processing in Runtime.
- ▶ If, for the `Operate` command, the **Command Routing** option is not active or no `Select` command has been received beforehand, an `Operate Request` is answered directly.
- ▶ After the `Operate` command has been processed successfully by the command processing in Runtime, a positive `Operate Response` is sent to the master. In the event of an error, an `Operate Response` is sent to the master with an error.

STATUS OF COMMAND ROUTING

The following status codes are sent to the master from the outstation:

- ▶ **Status Code 0 - SUCCESS**
 The command processing was successful.
- ▶ **Status Code 1 - TIMEOUT**
 A timeout has occurred during command processing.
 The command processing could not be successfully completed within 2 minutes.

► **Status Code 2 - NO_SELECT**

The `Select` command has been sent by the command processing with an invalid status.
Invalid statuses are:

- `S_PN_BIT` (negative confirmation) received
- The `S_SE_BIT` is no longer set
- None of the `COT` bits are set

► **Status Code 6 - HARDWARE_ERROR**

This error occurs under the following circumstances:

- The variable is not signed in and cannot be signed in.
- The variable has the **INVALID** bit
- The value cannot be written or the command cannot be sent.

► **Status Code 10 - AUTOMATION_INHIBIT**

The `Operate` command has been sent by the command processing with an invalid status.
Invalid statuses are:

- `S_PN_BIT` (negative confirmation) received
- The `S_SE_BIT` is no longer set
- None of the `COT` bits are set

► **Status Code 12 - OUT_OF_RANGE**

The control code contained in the `Request` is invalid.

7.4.1 LOG - command routing

LOG entry	Level	Description
processing command %1	MSG	Start of processing a command. <ul style="list-style-type: none"> ▶ %1 Command: Select, Cancel Select or Operate.
command %1 terminates with %2	MSG	The processing of the command has been completed. <ul style="list-style-type: none"> ▶ %1 Command: Select or Operate ▶ %2 DNP3 status code
command CANCEL SELECT finished	MSG	The processing of the Cancel Select command is complete.
command timeout - command failed	ERROR	The timeout status bit S_LAUFZEIT was received when waiting for the command confirmation.
invalid - command failed	ERROR	The I-Bit was received when waiting for the command confirmation.
negative confirmation - command failed (%1)	ERROR	The PN-Bit negative confirmation was received when waiting for the command confirmation. <ul style="list-style-type: none"> ▶ %1: Status value, coded in hexadecimal.
no more COT status bits - command failed	ERROR	A status without COT or PN Bit(s) was received when waiting for the command confirmation.
%1 positive (COT_actcon) - command successful	MSG	A positive command confirmation with the code COT_actcon was received. <ul style="list-style-type: none"> ▶ %1 Command: Select or Operate
execution termination positive (COT_actterm) - command succeeds	MSG	A positive command confirmation (COT_actterm) was received.
timeout while waiting for confirmation	ERROR	Waiting for the command confirmation was canceled with a Timeout. No known cancel condition was received during the fixed, defined waiting time of 2 minutes.
timeout while waiting for status change after command launch	ERROR	Waiting for the first status changes after sending the command was canceled with a TIMEOUT. No known cancel condition was received during the fixed, defined waiting time of 2 minutes.
Called SetValueWithStatusEx(%1, %2, %3, ...) returned:	DEBUG	Shows the call to send a command. The following information is logged:

%4		<ul style="list-style-type: none"> ▶ 1 Value (0 or 1) ▶ 2 Lowest-value DWORD of the status ▶ 3 Highest-value DWORD of the status (contains COT and SE) ▶ 4 true (execution OK) or false (execution error)
status request: %1	DEBUG	Shows changes for %1 when the status information is accessed.
status request: %1	DEEPDEBUG	Shows all access to the status information.
converted control code %d to set value %d - result: %u	DEBUG	<p>The command control from Placeholder 1 has been converted to the Boolean value in Placeholder 2.</p> <p>Note: Placeholder 3 is 0 if the conversion was valid, otherwise it shows the status code 12.</p>

7.5 Device Profile

The template for the Device Profile is installed together with the DNP3 Process Gateway by the setup.

You can find the file `DNP3_ProcessGateway.xml` in the following folder:

`%ProgramData%\COPA-DATA\zenon[Version]\CommunicationProfiles\Dnp3\ProcessGateway\`

7.6 Configuration file: specific entries for Access DNP3

The configuration file must be in the system folder. This INI file is called `zenProcGateway.INI` and is located in the following folder: `C:\ProgramData\COPA-DATA\System.`

[DNP3]

Inserimento	Descrizione
SERIAL=	comunicazione seriale (1) o comunicazione via TCP/IP (0)
COMPORT=	interfaccia seriale (COM1 = 0, COM2 = 1,...)
BAUD=	Baud rate dell'interfaccia seriale.
BYTESIZE=	Quantità dei bit di dato dell'interfaccia seriale.
PARITY=	Impostazioni di parità dell'interfaccia seriale (0=nessuna,1=dispari,2=pari)
STOPBITS=	Numero dei bit di stop dell'interfaccia seriale (0=1, 1=1.5, 2=2)
LINKADDRLOC=	Indirizzo di collegamento per la sessione locale.
LINKADDRREM=	Indirizzo di collegamento per la sessione remota.
SELECTTIMEOUT=	Timeout in ms per Select before Operate. Se non si riceve un comando <code>OPERATE</code> per la variabile corrispondente prima che scada questo timeout, viene interrotta automaticamente l'elaborazione della variabile stessa con un comando <code>CANCEL</code> . Default: 50000 ms
PORT=	Porta per la comunicazione via TCP/IP Default: 20000
TIME_USE.UTC=	Formato del time stamp: <ul style="list-style-type: none"> ▶ 0= Ora locale ▶ 1 = UTC Default: 0

Obj1BinInput=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: packet format 2: with flags</p> <p>Default: 1: packet format</p>
Obj2BinInputEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: without time 2: with absolute time 3: with relative time</p> <p>Default: 3: with relative time</p>
Obj10BinOutput=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: packet format 2: with flags</p> <p>Default: 1: with flags</p>
Obj11BinOutputEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: status without time 2: status with time</p> <p>Default: 1: status without time</p>
Obj20Counter=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit without flag 6: 16 bit without flag</p> <p>Default: 5: 32 bit without flag</p>
Obj22CounterEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit flag and time 6: 16 bit flag and time</p> <p>Default: 1: 32 bit with flag</p>
Obj30AnalogInp=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 3: 32 bit without flag 4: 16 bit without flag 5: single precision, floating-point with flag 6: double precision, floating-point with flag</p> <p>Default: 6: double precision, floating-point with flag</p>
Obj32AnalogInpEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit without time 2: 16 bit without time</p>

	3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time 7: single precision, floating-point with time 8: double precision, floating-point with time Default: 6: double precision, floating-point without time
Obj40AnalogOutStatus=	Menù a tendina con le Variations supportate per il gruppo oggetti. 1: 32 bit with flag 2: 16 bit with flag 3: single precision, floating-point with flags 4: double precision, floating-point with flags Default: 2: 16 bit with flag
Obj41AnalogOutput=	Menù a tendina con le Variations supportate per il gruppo oggetti. 1: 32 bit without time 2: 16 bit without time 3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time 7: single precision, floating-point with time 8: double precision, floating-point with time Default: 2: 16 bit without time
UNSOLICITED_RESPONSES_ENABLED=	Attiva o disattiva Unsolicited Responses: ▶ 0 = non attiva ▶ 1 = attiva Default: non attiva (0)
UNSOLICITED_RESPONSES_CONFIRMATION_TIMEOUT=	Tempo in secondi per la comunicazione con il Master. Dopo lo scadere di questo intervallo di tempo, viene inizializzato il conteggio di un timeout. Intervallo di input: da 1 a 60 s Default: 5 s
UNSOLICITED_RESPONSES_RETRY_COUNTER=	Numero di tentativi di stabilire la comunicazione con il Master. Intervallo di input: 0 - 65535 (0 = numero infinito di tentativi). Default: 3
UNSOLICITED_RESPONSES_MAXIMUM_EVENTS_CLASSES_1=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response .

	Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES_MAXIMUM_EVENTS_CLASSES_2=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response . Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES_MAXIMUM_EVENTS_CLASSES_3=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response . Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES_MAXIMUM_DELAY_CLASSES_1=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5
UNSOLICITED_RESPONSES_MAXIMUM_DELAY_CLASSES_2=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5
UNSOLICITED_RESPONSES_MAXIMUM_DELAY_CLASSES_3=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5

[VARIABLES]

Inserimento	Descrizione
COUNT	Numero delle variabili da esportare
EVENT_%d	Gestione degli eventi: Gestione degli eventi per ogni variabile. Appartiene sempre a una variabile: p.es. EVENT_0 appartiene a NAME_0 Valori: ► DEFAULT

	<p>La gestione degli eventi avviene come nel gruppo oggetti.</p> <ul style="list-style-type: none"> ▶ MOST_RECENT Mantiene solamente l'ultimo cambio di un evento di modifica binario. ▶ SOE Crea una serie di eventi. <p>Default: Default</p>
NAME_n	Nome della variabile con il numero n ($0 \leq n < \text{COUNT}$)
OBJECT_n	Tipo oggetto DNP3 della variabile con il numero n ($0 \leq n < \text{COUNT}$)
POINT_n	Numero del dato DNP3 della variabile con il numero n ($0 \leq n < \text{COUNT}$)
ROUTING_n	<p>Command Routing per variabili di tipo Binary Output con il numero n ($0 \leq n < \text{COUNT}$)</p> <ul style="list-style-type: none"> ▶ 1: Command Routing per variabile è attivato. ▶ 0: Command Routing per variabile è disattivato.

▶

7.7 LATCH_ON and LATCH_OFF

Command Control Code from the PLC is written to USINT variables as an 8-bit value via Process Gateway. The following applies for transfer to zenon variables:

Destination variable of the command	Result
BOOL:	Set value LATCH_ON : 1 Set value LATCH_OFF : 0
USINT:	Set value corresponds to control code.
all other variables:	Command failed.

Only **direct control** is supported. **Select**, **SBO** and **Operate** are not supported.

Master, control mode direct	Process Gateway	Value zenon USINT
LATCH_ON	Binary Output Statuses	3
LATCH_OFF	Binary Output Statuses	4
Pulse On	Binary Output Statuses	1
Pulse Off	Binary Output Statuses	2
Trip	Binary Output Statuses	129
Close	Binary Output Statuses	65

For zenon binary output statuses `BOOL`, only **LATCH_ON/LATCH_OFF** is supported.

7.8 INI file

[DNP3]

Inserimento	Descrizione
SERIAL=	comunicazione seriale (1) o comunicazione via TCP/IP (0)
COMPORT=	interfaccia seriale (COM1 = 0, COM2 = 1,...)
BAUD=	Baud rate dell'interfaccia seriale.
BYTESIZE=	Quantità dei bit di dato dell'interfaccia seriale.
PARITY=	Impostazioni di parità dell'interfaccia seriale (0=nessuna,1=dispari,2=pari)
STOPBITS=	Numero dei bit di stop dell'interfaccia seriale (0=1, 1=1.5, 2=2)
LINKADDRLOC=	Indirizzo di collegamento per la sessione locale.
LINKADDRREM=	Indirizzo di collegamento per la sessione remota.
SELECTTIMEOUT=	Timeout in ms per Select before Operate. Se non si riceve un comando <code>OPERATE</code> per la variabile corrispondente prima che scada questo timeout, viene interrotta automaticamente l'elaborazione della variabile stessa con un comando <code>CANCEL</code> .

	Default: 50000 ms
PORT=	Porta per la comunicazione via TCP/IP Default: 20000
TIME_USE_UTC=	Formato del time stamp: <ul style="list-style-type: none">▶ 0= Ora locale▶ 1 = UTC Default: 0

Obj1BinInput=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: packet format 2: with flags</p> <p>Default: 1: packet format</p>
Obj2BinInputEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: without time 2: with absolute time 3: with relative time</p> <p>Default: 3: with relative time</p>
Obj10BinOutput=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: packet format 2: with flags</p> <p>Default: 1: with flags</p>
Obj11BinOutputEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: status without time 2: status with time</p> <p>Default: 1: status without time</p>
Obj20Counter=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit without flag 6: 16 bit without flag</p> <p>Default: 5: 32 bit without flag</p>
Obj22CounterEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 5: 32 bit flag and time 6: 16 bit flag and time</p> <p>Default: 1: 32 bit with flag</p>
Obj30AnalogInp=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit with flag 2: 16 bit with flag 3: 32 bit without flag 4: 16 bit without flag 5: single precision, floating-point with flag 6: double precision, floating-point with flag</p> <p>Default: 6: double precision, floating-point with flag</p>
Obj32AnalogInpEvent=	<p>Menù a tendina con le Variations supportate per il gruppo oggetti.</p> <p>1: 32 bit without time 2: 16 bit without time</p>

	3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time 7: single precision, floating-point with time 8: double precision, floating-point with time Default: 6: double precision, floating-point without time
Obj40AnalogOutStatus=	Menù a tendina con le Variations supportate per il gruppo oggetti. 1: 32 bit with flag 2: 16 bit with flag 3: single precision, floating-point with flags 4: double precision, floating-point with flags Default: 2: 16 bit with flag
Obj41AnalogOutput=	Menù a tendina con le Variations supportate per il gruppo oggetti. 1: 32 bit without time 2: 16 bit without time 3: 32 bit with time 4: 16 bit with time 5: single precision, floating-point without time 6: double precision, floating-point without time 7: single precision, floating-point with time 8: double precision, floating-point with time Default: 2: 16 bit without time
UNSOLICITED_RESPONSES_ENABLED=	Attiva o disattiva Unsolicited Responses: ▶ 0 = non attiva ▶ 1 = attiva Default: non attiva (0)
UNSOLICITED_RESPONSES_CONFIRMATION_TIMEOUT=	Tempo in secondi per la comunicazione con il Master. Dopo lo scadere di questo intervallo di tempo, viene inizializzato il conteggio di un timeout. Intervallo di input: da 1 a 60 s Default: 5 s
UNSOLICITED_RESPONSES_RETRY_COUNTER=	Numero di tentativi di stabilire la comunicazione con il Master. Intervallo di input: 0 - 65535 (0 = numero infinito di tentativi). Default: 3
UNSOLICITED_RESPONSES_MAXIMUM_EVENTS_CLASSES_1=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response .

	Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES _MAXIMUM_EVENTS_CLASSES_2=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response . Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES _MAXIMUM_EVENTS_CLASSES_3=	Numero massimo di eventi (per classi di eventi) che vengono inseriti nel buffer prima che venga inviato un unsolicited response . Intervallo di input: 0 - 255 Default: 5
UNSOLICITED_RESPONSES _MAXIMUM_DELAY_CLASSES_1=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5
UNSOLICITED_RESPONSES _MAXIMUM_DELAY_CLASSES_2=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5
UNSOLICITED_RESPONSES _MAXIMUM_DELAY_CLASSES_3=	Ritardo massimo per classe di eventi al cui scadere viene scritto un nuovo inserimento dopo la scrittura di una <i>unsolicited response</i> . Intervallo di input: 0 - 65535 secondi (0 = nessun ritardo, cioè al cambio di valore). Default: 5

[VARIABLES]

Inserimento	Descrizione
COUNT	Numero delle variabili da esportare
EVENT_%d	Gestione degli eventi: Gestione degli eventi per ogni variabile. Appartiene sempre a una variabile: p.es. EVENT_0 appartiene a NAME_0 Valori: ► DEFAULT

	<p>La gestione degli eventi avviene come nel gruppo oggetti.</p> <ul style="list-style-type: none"> ▶ MOST_RECENT Mantiene solamente l'ultimo cambio di un evento di modifica binario. ▶ SOE Crea una serie di eventi. <p>Default: Default</p>
NAME_n	Nome della variabile con il numero n ($0 \leq n < \text{COUNT}$)
OBJECT_n	Tipo oggetto DNP3 della variabile con il numero n ($0 \leq n < \text{COUNT}$)
POINT_n	Numero del dato DNP3 della variabile con il numero n ($0 \leq n < \text{COUNT}$)
ROUTING_n	<p>Command Routing per variabili di tipo Binary Output con il numero n ($0 \leq n < \text{COUNT}$)</p> <ul style="list-style-type: none"> ▶ 1: Command Routing per variabile è attivato. ▶ 0: Command Routing per variabile è disattivato.

8. ICCP-TASE.2

The **IEC 60870-6 TASE.2 ICCP** protocol can be used with the **AccessICCP.dll** module via the **zenon Process Gateway**. ICCP-TASE.2 supports Conformance Blocks 1 and 2 as client and server. **Process Gateway** acts like a server by default when communication is established.

Communication in the ICCP protocol is spontaneous. An ICCP server reports the value changes to its communication partner, the remote client. However, an ICCP server cannot actively read the value changes from the remote client. In order to guarantee two-way exchange of data, both communication partners should have a client and a server.

POSSIBLE SYSTEM CONFIGURATIONS

▶ Server only

Communication with several remote ICCP communication partners possible.
This is the case if the **Available from ICCP** variable list is empty.

Note: **Client Variables** tab in the configuration dialog of the Process Gateway.

▶ Server and passive client

The client will not initialize the communication with the remote ICCP server itself. Communication with several remote ICCP communication partners is possible. This is the case if the **Initialise communication** property is not active.

Note: **General** tab in the configuration dialog of the **Process Gateway**.

► Server and active client


The client can initialize communication with remote ICCP servers itself.

A communication is only possible with a remote ICCP communication partner.

ESTABLISHING COMMUNICATION

After the initialization of the communication with the zenon ICCP server or initialization by its own client, the verification of the **bilateral table ID** is carried out. If the verification was successful, the zenon ICCP client registers the variables to be communicated on the remote server as a DataSet and activates spontaneous communication of the DSTransferSet (`MMS.InformationReport`).

Note: The ICCP client also communicates with the server if, in the configuration of the **Client variables** (A pagina: 71) tab, no variables are contained in the **Available from ICCP** list. In this case, the client only checks the bilateral table.



ICCP DATA EXCHANGE

► ICCP Server


- The ICCP server sends value changes of variables to `DSTransferSets` (`MMS.InformationReport`) spontaneously. If the values of variables in zenon Runtime change, a `DSTransferSet` is sent to the remote client.
- The ICCP server can also receive write requests from the remote client (`MMS.write request`). These are transferred to zenon Runtime and Runtime forwards this request to the corresponding zenon driver. If the writing is confirmed by the PLC, the zenon variable changes its value.

► ICCP Client

- In the event that a variable in zenon Runtime sends the ICCP client a corresponding write request (`MMS.write request`) to the remote server.
- If a `DSTransferSet (MMS.InformationReport)` is received by the ICCP client (from the remote server) the received values are sent to zenon Runtime. Runtime forwards these requests to the zenon driver. If the writing is confirmed by the PLC, the zenon variables do not change their value.

8.1 Module configuration

Configuration is carried out using three tabs. It can be confirmed and closed by clicking on OK if all three tabs have been configured.



Settings

General | Server Variables | Client Variables

Connection

Bilateral table ID
zenon_to_ControlCenter

Local domain name
zenonSubstation

Remote domain name
ControlCenter

Connection Status

Server State variable
zenPG_ICCP_Server_ConnectionState

Client State variable
zenPG_ICCP_Client_ConnectionState

Client

☐ Initialise communication

IP Address/Hostname
Port
102

☒ Check presence of remote items

Set result in status bit: M2

Variable for result names
zenPG_ICCP_missing_items_on_remote_server

OK Cancel Help


Parameter	Description
General (A pagina: 61)	General settings.
Server variables (A pagina: 67)	Configuration of the server variables. Selection of the variables that the ICCP server provides.
Client variables (A pagina: 71)	Configuration of the client variables. Selection of the variables that are received by the ICCP client.

CHIUDERE LA FINESTRA DI DIALOGO.

Opzione	Descrizione
OK	Applica le impostazioni e chiude la finestra di dialogo.
Annulla	Annulla tutte le modifiche e chiude la finestra di dialogo.
Guida	Apre la guida online.

8.1.1 General

Configuration of the connection settings.



CONNECTION

The `Connection` settings are any desired strings that are coordinated on all devices in the system.

The unique bilateral table ID must be the same on all devices that communicate with the **ICCP Process Gateway**. It is queried when a connection is established by both communication partners. The connection is disconnected if they do not correspond.

The domain names provide the references used at MMS protocol level to ICCP data points. It must be set as the same mirror image for the communication partners.

These comparison rules are prescribed by the ICCP standard.

Parameter	Description
Bilateral Table ID	<p>The bilateral table identification is synced when the communication partner establishes a connection. Access to the data is only permitted for authorized remote clients.</p> <p>Note: The ID must be configured as exactly the same on both sides of the communication.</p> <p>Note: Missing or incorrect entries are visualized as an error message in the dialog.</p>
Local Domain Name	<p>Name of the local ICCP-domain that is used for all server variables.</p> <p>Note: the name must be set as mirrored on the communication partners (= the same as on the remote client).</p> <p>Note: Missing or incorrect entries are visualized as an error message in the dialog.</p>
Remote Domain Name	<p>Name of the remote ICCP-domain that is used for all client variables.</p> <p>Note: the name must be set as mirrored on the communication partners (= the same as on the remote server).</p> <p>Note: Missing or incorrect entries are visualized as an error message in the dialog.</p>
Error message	Display of missing configuration data.

CONNECTION STATUS

Connection status variables allow the display of the current connection status of **Process Gateway** to the remote ICCP communication partner in Runtime. The zenon variable names are given in the **Process Gateway**. The variables should be a numeric data type; recommendation: Internal variables.

You can find detailed information on this in the Status variables (A pagina: 74) chapter.

Parameter	Description
Server state variable	<p>Input field for the entry of a variable name for the display of the current connection status of the server.</p> <p>If this field is empty, no status information can be displayed in zenon.</p> <p>Default: <code>empty</code></p>
Client state variable	<p>Input field for the entry of a variable name for the display of the current connection status of the client.</p> <p>If this field is empty, no status information can be displayed in zenon.</p> <p>Default: <code>empty</code></p>

CLIENT

Parameter	Description
Initialise communication	<p>Checkbox for the activation of the automatic establishment of a connection to the remote ICCP server when the Process Gateway is started.</p> <ul style="list-style-type: none"> ▶ active: When Process Gateways is started, the client automatically attempts to establish a connection to the configured remote ICCP server. If the connection attempt is unsuccessful, another attempt to establish a connection is made after 20 seconds. During this waiting time, a connection attempt can be accepted from a remote ICCP communication partner if this corresponds to the configured IP address or host name. ▶ inactive: No automatic attempt to establish a connection to the ICCP server when the Process Gateway is started. <p>Default: <code>Inactive</code></p> <p>If this option is activated, the following limitation applies:</p> <ul style="list-style-type: none"> ▶ The connection is only possible with a remote ICCP communication partner. ▶ Connection attempts from remote clients with an unknown address are not accepted.
IP Address/Hostname	<p>Input field for IP address or host name for the automatic connection to the remote ICCP server.</p>

	<p>Note: Only active if Initialise communication is inactive.</p> <p>Note: Missing or incorrect entries are visualized as an error message in the dialog.</p>
Port	<p>Input field for port number that is used for communication to the remote ICCP server.</p> <p>Default: 102</p> <p>Note: Only active if Initialise communication is inactive.</p> <p>Note: Missing or incorrect entries are visualized as an error message in the dialog.</p>

Check presence of remote items	<p>Checkbox for the activation of the checking of the variable names of the current client connection to the variable name of the remote ICCP server.</p> <ul style="list-style-type: none"> ▶ active: Activates the checking and allows the configuration of the Set result in status bit and Variable for result names properties. For the connection, the client on the remote server creates a DataSet that only contains existing variables. ▶ inactive: It is assumed that the configured ICCP variables are available on the remote server. If one or more configured ICCP variables are not on the remote server, no successful connection to the remote server can be established. <p>Default: <i>Inactive</i></p>
Set result in status bit	<p>Status bit for zenon variables of the client that are not on the remote ICCP server. Selection of the corresponding user status bit from drop-down list:</p> <ul style="list-style-type: none"> ▶ None No user status bit is set for the variable if the variable is not present on the remote server. ICCP variables that are not present can be evaluated with Variable for result names. ▶ M1 bis M8 The configured status bit is set for the variable if the variable is not present on the remote server. <p>Default: <i>None</i></p> <p>This user status bit is set for configured zenon variables if they are not found during checking on the remote server.</p> <p>Note: Only active if Check presence of remote Items is inactive.</p> <p>You can find further information on status processing in the Status processing manual in the User status chapter.</p>
Variable for result names	<p>Input field to configure a variable name for the display of the names of the missing ICCP variables. In the variable, variable names that are not present on the remote server are visualized.</p> <p>Is this field is empty, the evaluation is carried out with the configured user status bit.</p> <p>Default: <i>empty</i></p> <p>Note: Only active if Check presence of remote Items is</p>


	<p>inactive.</p> <p>You can find further information on the display of variables that do not exist in the Show variables that are not present in Runtime (A pagina: 77) chapter.</p>
--	--

CLOSE DIALOG

Parameter	Description
OK	Accepts the settings of all tabs, saves the configuration in the zenProcGateway.ini file, starts the ICCP server and waits for incoming connections.
Cancel	Annulla tutte le modifiche in tutte le schede e chiude la finestra di dialogo.
Help	Apri la guida online.

ERROR MESSAGES - EXAMPLE

Error messages are displayed in red font:




The screenshot shows the 'Settings' dialog box with the 'General' tab selected. The 'Connection' section contains fields for 'Bilateral table ID', 'Local domain name', and 'Remote domain name'. The 'Connection Status' section contains fields for 'Server State variable' and 'Client State variable'. The 'Client' section contains checkboxes for 'Initialise communication' and 'Check presence of remote items', a 'Set result in status bit' dropdown menu, and a 'Variable for result names' field. At the bottom, there are 'OK', 'Cancel', and 'Help' buttons. Two error messages are displayed in red font at the bottom left of the dialog:

- Failed to start ICCP server.
- No bilateral table ID specified

8.1.2 Server variables

Selection and configuration of the variables that the zenon Process Gateway provides as an ICCP server. The value changes of the variables are sent to the remote ICCP client spontaneously.



Parameter	Description
SCADA variables	<p>List of all numeric variables available in the zenon project. The list can be sorted and filtered.</p> <p>The list shows:</p> <ul style="list-style-type: none"> ▶ Name: Name in zenon ▶ Type: Data type of the zenon variable
Arrow keys	<p>Selected variables are exchanged between the two lists by means of the arrow key.</p> <ul style="list-style-type: none"> ▶ Key >>: Copies all variables from zenon to ICCP. ▶ Key <<: Removes all variables from the ICCP list. ▶ Key >: Copies selected variables from zenon to ICCP ▶ Key <: Removes selected variables from the ICCP list. <p>Variables can also be added to the list for zenon by double clicking on the variable for the ICCP list.</p>
Available for ICCP	<p>Variables from the list are provided by the server for the remote ICCP client.</p> <p>The list shows:</p> <ul style="list-style-type: none"> ▶ SCADA Variable: Name in zenon ▶ ICCP Name: Name in the ICCP protocol ▶ Type: ICCP Type <p>ICCP name and type can be changed using the settings ICCP name, Data type and Extended type options.</p>
ICCP Name	<p>Name of the ICCP data point selected from the top list.</p> <p>Change to the ICCP Name by entering the new name. Empty if no entry is selected in the Available for ICCP list.</p> <p>Note: The ICCP name can usually be named as desired in accordance with the standard. However, it must be ensured that both communication partners use the same name.</p>
Data type	<p>ICCP data type of the variable selected from the top list.</p> <p>Change of the data type by clicking on the options field:</p>

	<ul style="list-style-type: none"> ▶ State ▶ Real ▶ Discrete <p>Standard display of zenon variables on ICCP:</p> <ul style="list-style-type: none"> ▶ BOOL on State ▶ REAL on Real ▶ INTEGER on Discrete <p>Depending on the variables provided by zenon, data types can also be unavailable (grayed out).</p>
Extended type	<p>ICCP suffix of the variable selected from the top list.</p> <p>Change to the Extended type by clicking on the option field:</p> <ul style="list-style-type: none"> ▶ None: No ICCP suffix (only value of the variable) ▶ Quality flags: Quality ▶ Timestamp: Quality + time stamp ▶ Extended: Quality + time stamp + change counter ▶ Timestamp Extended: Quality + extended timestamp <p>Depending on the variables provided by zenon, data types can also be unavailable (grayed out).</p>

**Attenzione**


Data type and **Extended type** must be correctly assigned for both communication partners. Incorrect amendments lead to the received data sets not being interpreted 100% correctly. All other information in the data set is lost!

CLOSE DIALOG

Parameter	Description
OK	Accepts the settings of all tabs, saves the configuration in the zenProcGateway.ini file, starts the ICCP server and waits for incoming connections.
Cancel	Annulla tutte le modifiche in tutte le schede e chiude la finestra di dialogo.
Help	Apre la guida online.

8.1.3 Client variables

Selection and configuration of the variables that the zenon Process Gateway uses as an ICCP client. The client transmits the value changes that it receives from the remote ICCP server to the zenon variables.



Parameter	Description
SCADA variables	<p>List of all numeric variables available in the zenon project. The list can be sorted and filtered.</p> <p>The list shows:</p> <ul style="list-style-type: none"> ▶ Name: Name in zenon ▶ Type: Data type of the zenon variable
Arrow keys	<p>Selected variables are exchanged between the two lists by means of the arrow key.</p> <ul style="list-style-type: none"> ▶ Key >>: Copies all variables from zenon to ICCP. ▶ Key <<: Removes all variables from the ICCP list. ▶ Key >: Copies selected variables from zenon to ICCP ▶ Key <: Removes selected variables from the ICCP list. <p>Variables can also be added to the list for zenon by double clicking on the variable for the ICCP list.</p>
Available from ICCP	<p>Variables from the list are expected from the remote ICCP server.</p> <p>The list shows:</p> <ul style="list-style-type: none"> ▶ SCADA Variable: Name in zenon ▶ ICCP Name: Name in the ICCP protocol ▶ Type: ICCP Type <p>The ICCP name and type can be modified using the ICCP Name, Data type and Extended type settings.</p>
ICCP Name	<p>Name of the ICCP data point selected from the top list.</p> <p>Change to the ICCP Name by entering the new name. Empty if no entry is selected in the Available for ICCP list.</p> <p>Note: The ICCP name can usually be named as desired in accordance with the standard. However, it must be ensured that both communication partners use the same name.</p>
Data type	<p>ICCP data type of the variable selected from the top list.</p> <p>Change of the data type by clicking on the options field:</p> <ul style="list-style-type: none"> ▶ State

	<ul style="list-style-type: none"> ▶ Real ▶ Discrete <p>Standard display of zenon variables on ICCP:</p> <ul style="list-style-type: none"> ▶ BOOL on State ▶ REAL on Real ▶ INTEGER on Discrete <p>Depending on the variables provided by zenon, data types can also be unavailable (grayed out).</p>
Extended type	<p>ICCP suffix of the variable selected from the top list.</p> <p>Change to the Extended type by clicking on the option field:</p> <ul style="list-style-type: none"> ▶ None: No ICCP suffix (only value of the variable) ▶ Quality flags: Quality ▶ Timestamp: Quality + time stamp ▶ Extended: Quality + time stamp + change counter ▶ Timestamp Extended: Quality + extended timestamp <p>Depending on the variables provided by zenon, data types can also be unavailable (grayed out).</p>



Attenzione

Data type and **Extended type** must be correctly assigned for both communication partners. Incorrect amendments lead to the received data sets not being interpreted 100% correctly. All other information in the data set is lost!

CLOSE DIALOG

Parameter	Description
OK	Accepts the settings of all tabs, saves the configuration in the zenProcGateway.ini file, starts the ICCP server and waits for incoming connections.
Cancel	Annulla tutte le modifiche in tutte le schede e chiude la finestra di dialogo.
Help	Apre la guida online.

8.2 Status variables of the connection

Status variables of communication are used for the display of the connection status between the Process Gateway and the remote ICCP communication partner. A separate variable each is configured for the ICCP server and ICCP client. The Process Gateway only communicates this status to zenon Runtime. There is no communication of values of these variables to remote ICCP communication partners.

ENGINEERING

To show the connection status in Runtime, carry out the following project configuration steps:

1. In your zenon Editor, create two numeric variables.
It is recommended that these are configured for the internal driver.
 - The variable cannot be a STRING variable.
2. Configuration in the Process Gateway:
 - Status variable for server connection:
Enter the name of the variable in the **Server state variable** input field in the **General** tab in the Process Gateway module configuration.
 - Status variable for client connection:
Enter the name of the variable in the **Client state variable** input field in the **General** tab in the Process Gateway module configuration.

ASSIGNED STATES

The connection status variables have the following values:

Parameter	Description
0 IDLE	<ul style="list-style-type: none"> ▶ Communication inactive: Directly after the start of Process Gateway or reloading the zenon project. ▶ Connection disconnected again: Once Process Gateway has been closed or after the settings in Process Gateway have been edited, and before the establishing of a new connection.
1 CONNECTING	<p>Communication via TCP/IP and MMS is being established.</p> <p>This status is shown if an incoming CR (<code>Connection Request</code>) has been received or a CR (<code>Connection Request</code>) has been sent successfully. This depends on which page has established the TCP/IP connection. This status is the same for server and client.</p>
2 CONNECTED	<p>ICCP communication has been established successfully.</p> <p>This status is set to a logical connection if a dataset (<code>DSTransferSet</code>) has been agreed for the transfer of data and the first <code>MMS.write request</code> (logical server connection) or the first <code>MMS.write response</code> (logical client connection) has been received.</p> <p>If the ICCP client does not request any data from the remote server, the status of the logical connection remains <code>CONNECTED</code>.</p> <p>Note: The client does not request any data if:</p> <ul style="list-style-type: none"> ▶ The list of variables is empty Available from ICCP. ▶ None of the variables from the Available from ICCP list are available and the Check presence of remote items check has been activated.
3 ERROR	<p>This status is shown if the TCP/IP connection as been interrupted. This status is the same for both logical connections.</p>

8.3 Show non-present variables in Runtime

With the help of this project configuration, you can evaluate in zenon Runtime which of the variables configured on the ICCP client are not present on the remote server.

This evaluation can be carried out with two project configurations:

1. Display of the missing variable names in an additional string variable.
2. Display of a user status bit when there are variables that do not exist.

REQUIREMENT

- The checking of the variable names of the current client connection must be activated: Checkbox **Check presence of remote items** in the **General** tab in the Process Gateway module configuration.

DISPLAY OF THE MISSING VARIABLES IN A STRING VARIABLE

To display the missing variables in Runtime in one variable:

1. In the zenon Editor, create a STRING variable.
It is recommended that these are configured for the internal driver.
2. Configuration in Process Gateway:
Enter the name of the variable in the input field **Variable for result names** in the **General** tab in the Process Gateway module configuration.



Info

The value of the variable in Runtime contains the name of the non-present variables, separated by a comma (;).

DISPLAY OF A USER STATUS BIT WHEN THERE ARE VARIABLES THAT DO NOT EXIST.

To mark the zenon variables in Runtime with a user status bit if they are not present on a remote ICCP server:

- Select the desired user status bit from the drop-down list of the **Set result in status bit** property in the **General** tab in the Process Gateway module configuration.

Note: This user status bit can be evaluated in <CD_RUNTIME> with a **reaction matrix** or a **combined element**.

8.4 Configuration file: INI entries for ICCP-Tase.2

The configuration file `zenProcGateway.ini` contains this entries for ICCP-Tase.2.

[ICCP]

Inserimento	Descrizione
SERVER_PORT=	<p>Numero della porta IP del server; la porta consente la connessione di client remoti</p> <p>La porta viene aperta al momento dello start e rimane aperta.</p> <p>Default: 102</p> <p>Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il ICCP-TASE.2 Process Gateway.</p>
MAX_CONNECTIONS=	<p>Numero massimo di connessioni di client ICCP remoti con il server. Viene ignorato se è stato configurato CLIENT_AUTO_CONNECT=1.</p> <p>Default: 0 (= illimitato)</p> <p>Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il ICCP-TASE.2 Process Gateway.</p>
MAJOR_VERSION_NUMBER=	<p>Numero di versione principale del protocollo ICCP, per es.: 1996, 2000.</p> <p>Default: 2000</p> <p>Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il ICCP-TASE.2 Process Gateway.</p>
MINOR_VERSION_NUMBER=	<p>Numero di sotto-versione del protocollo ICCP.</p> <p>Default: 8</p> <p>Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il ICCP-TASE.2 Process Gateway.</p>
BILATERAL_TABLE_ID=	<p>Identificazione tabella bilaterale. Viene analizzata e confrontata quando viene stabilita una connessione fra tutti i partner coinvolti nella comunicazione ICCP.</p> <p>Nota: l'identificazione bilaterale univoca della tabella deve essere la stessa su tutti i dispositivi che comunicano con ICCP-TASE.2 Process Gateway.</p>
LOCAL_DOMAIN_NAME=	<p>Nome di dominio ICCP locale; impostazione per il server; deve essere impostata in modo speculare rispetto al partner della comunicazione.</p>
REMOTE_DOMAIN_NAME=	<p>Nome di dominio ICCP remoto; impostazione per il client; deve essere impostata in modo speculare rispetto al partner della comunicazione.</p>
CLIENT_AUTO_CONNECT=	<p>Configurazione che stabilisce se il client inizializza automaticamente una connessione con il server ICCP al momento dell'avvio del Process Gateway.</p> <p>0: non inizializzare - solo attendere.</p>

	1: inizializzare.
CLIENT_IP_NAME=	Indirizzo IP o nome host del server remoto se questo client deve inizializzare la comunicazione.
CLIENT_PORT=	Numero di porta del server remoto se questo client deve inizializzare la comunicazione.
CHECK_SERVER_Variables=	Verifica se tutte le variabili configurate sono disponibili sul server remoto. 0: nessuna verifica dei nomi variabile configurati. 1: verifica dei nomi variabile configurati.
CHECK_SERVER_VARIABLES_MARKER_BIT=	Bit di stato per variabili client non esistenti sul server (con verifica attiva delle variabili configurate'). 0: nessun bit di stato per variabili client mancanti. Da 1 a 8: bit di stato utente da M1 a M8.
SERVER_STATE_VARIABLE=	Nome della variabile per la visualizzazione dello stato della connessione fra server ICCP e client remoto.
CLIENT_STATE_VARIABLE=	Nome della variabile per la visualizzazione dello stato della connessione fra client ICCP e server remoto.
NOT_AVAILABLE_SERVER_VARIABLES_VARIABLE=	Nome della variabile per la visualizzazione dei nomi variabili (nel Runtime di zenon) che non sono disponibili sul server remoto per la corrente connessione client.
CALLING_OSI_SESSION_SELECTOR= CALLING_OSI_PRESENTATION_SELECTOR= CALLING_OSI_AE_QUALIFIER= CALLING_OSI_AP_TITLE= CALLED_OSI_SESSION_SELECTOR= CALLED_OSI_PRESENTATION_SELECTOR= CALLED_OSI_AE_QUALIFIER= CALLED_OSI_AP_TITLE=	Parametri di comunicazione OSI Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il ICCP-TASE.2 Process Gateway.

[VARIABLES]

Gruppo dei riferimenti configurati fra variabili di zenon e variabili ICCP. È elencato quanto segue:

- ▶ Parametri di ogni variabile ICCP
- ▶ Numero delle variabili.
- ▶ Nomi delle variabili.

Inserimento	Descrizione
PARAM_0=	<p>Parametri per nome ICCP.</p> <p>La numerazione inizia da 0. Il contatore viene incrementato di 1 ad ogni nuovo parametro. Questo identificatore corrisponde a quello del nome variabile.</p> <p>PARAM_0 corrisponde a NAME_0.</p> <p>Esempio: PARAM_0=1, 0, 0, ICCP_Name</p>
COUNT=	Numero dei riferimenti configurati
NAME_0=	<p>Nome delle variabili di zenon.</p> <p>La numerazione inizia da 0. Il contatore viene incrementato di 1 ad ogni nuovo parametro. Questo identificatore corrisponde a quello del parametro.</p> <p>PARAM_0 corrisponde a NAME_0.</p> <p>Esempio: NAME_0=MyName</p>

8.5 LOG entries

GENERAL

Parameter	Level	Note
Failed to get %s application object.	ERROR	Start zenon Runtime before you start Process Gateway.
Failed to start ICCP server.	ERROR	<p>Correct the settings of Process Gateway.</p> <p>When starting several Process Gateways, configure a different IP port for each one.</p>
<ul style="list-style-type: none"> ▶ Failed to interpret report for data set %s.%s. Bad message structure. ▶ Failed to interpret 	ERROR	Match the ICCP 'data type' and 'extended type' between Process Gateway and remote ICCP communication partner.

report for %s. Bad message structure. ▶ Failed to interpret write request for %s.%s. Bad message structure. ▶ Failed to interpret received data for %s.		
Failed to write '%s', error code: %u.	ERROR	The remote ICCP server responds to the write request in the negative, with MMS error code %u. Correct the settings on the remote server and/or move the variable from the client configuration to the server variables in Process Gateway.

AUTOMATIC ESTABLISHMENT OF A CONNECTION

Parameter	Level	Description
Could not resolve host name %s. Errorcode: %d	ERROR	The pre-set host name or the IP address could not be resolved. ▶ %1 Host name or IP address of the set counterparty. ▶ %2 Windows socket error code
Autoconnection is not possible because no hostname (or IP address) is defined	ERROR	The pre-set host name or the IP address are resolved to the address 0.0.0.0 and are thus invalid.
Maximum number of %1 connections reached. Declining new connection from %2.	MSG	Rejection of an incoming connection that has already achieved the maximum number of possible connections: ▶ %1 Maximum number of connections could be established. ▶ %2 IPv4 address of the counterparty.
Cannot verify selected host name %1. Declining new connection from %2.	MSG	The configured host name cannot be resolved to the IP address. ▶ %1 Configured host name ▶ %2 IPv4 address of the counterparty.

Only connection from %1 allowed. Declining new connection from %2.	MSG	<p>An incoming connection is rejected because the source address does not correspond to the IP address of the configured host for automatic establishment of a connection.</p> <ul style="list-style-type: none"> ▶ %1 configured IP address of the set host. ▶ %2 IPv4 address of the counterparty.
Only one active connection allowed. Declining new connection from %2.	MSG	<p>An incoming connection is rejected because a connection has been established automatically.</p> <ul style="list-style-type: none"> ▶ %2 IPv4 address of the counterparty.
Creating a socket connection to the ICCP server %s [%2:%3].	DEBUG	<p>A TCP socket connection to the configured counterparty is established.</p> <ul style="list-style-type: none"> ▶ %1 Host name or IP address of the set counterparty. ▶ %2 IPv4 address of the counterparty. ▶ %3 Port number of the counterparty.
Could not create the socket connection to the ICCP server %1. Errorcode: %2.	DEBUG	<p>A TCP socket connection to the set counterparty could not be established within the socket timeout.</p> <ul style="list-style-type: none"> ▶ %1 Host name or IP address of the set counterparty. ▶ %2 Windows socket error code.

STATUS VARIABLES OF THE CONNECTION

Parameter	Level	Description
Server state variable with name '%s' does not exist or has an invalid type.	ERROR	<p>The configured status variable to display the status of the server connection does not exist in the project or has an invalid data type (required data type: numeric).</p> <ul style="list-style-type: none"> ▶ %s Configured name of the status variable.
Client state variable with name '%s' does not exist or has an invalid type.	ERROR	<p>The configured status variable to display the status of the client connection does not exist in the project or has an invalid data type (required data type: numeric).</p> <ul style="list-style-type: none"> ▶ %s Configured name of the status variable.

set server state: %1 (%2)	MSG	<p>New status of a pre-existing server connection.</p> <ul style="list-style-type: none"> ▶ %1 Numeric value of the current status of the server connection ▶ %2 Current status of the server connection as a text (IDLE, CONNECTING, CONNECTED, ERROR)
set client state: %1 (%2)	MSG	<p>New status of a pre-existing client connection.</p> <ul style="list-style-type: none"> ▶ %1 Numeric value of the current status of the client connection ▶ %2 Current status of the client connection as a text (IDLE, CONNECTING, CONNECTED, ERROR)

DISPLAY OF VARIABLES NOT PRESENT

Parameter	Level	Description
Unavailable server items variable with name '%1' does not exist or has an invalid type.	ERROR	<p>The configured status variable to display the name of the variable that does not exist does not exist in the project or has an invalid data type (required data type: STRING).</p> <ul style="list-style-type: none"> ▶ %1 Configured name of the status variable.
Error configured client variable '%1' is not available on the remote device.	ERROR	<p>A variable configured in Process Gateway for the client is not available on the remote ICCP server.</p> <ul style="list-style-type: none"> ▶ %1 ICCP name of the variable that is not present on the remote server

8.6 Interoperability

Process Gateway for ICCP-TASE.2 based on the **IEC 60870-6 TASE.2 ICCP** protocol.

ICCP-TASE.2 supports Conformance Blocks 1 and 2 as client and server. **Process Gateway** acts like a server by default when communication is established.

Supported protocol version: 2000.8 and 1996.8

9. IEC870 Slave

LANGUAGE

The IEC870SI Process Gateway and its dialogs for configuration are only available in English.

STRUCTURE

You can configure several virtual controllers (**devices**) in the IEC870 slave gateway. According to the used protocol, they are associated directly to a Master (870-104) or polled by a Master (870-101). The **devices** can contain several sectors. These sectors contain IOs (information objects) representing the actual variables. IOs refer to a variable of the process control system.

IDENTIFICATION AND ADDRESSING

- ▶ 870-101: The PLC is identified by the link address of the Slave.
- ▶ 870-104: The PLC is identified by the IP address of the Master.
- ▶ Sector: Addressed by COA.
- ▶ IO: Addressed by type identification and IOA.

In the following chapters, you will read how to configure the IEC870SI Gateway, how communication takes place and you will read about compatibility issues.



Info

*For variables that are configured in the IEC870SI Process Gateway as command variables, each command is logged as **Send value** via the COM interface in the CEL if the **Impostazione valori tramite VBA** property is active (**Registrazione nella CEL** group).*

9.1 Module configuration

You have many settings options available in the IEC870 slave process gateway. All lists in the configuration dialogs can be sorted. To change the sorting sequence, simply click on the column title.

870-101 PROTOCOL VS 104 PROTOCOL

The gateway supports both protocol IEC60870-5-101 (abbreviated to: 870-101, serial communication) as well as IEC60870-5-104 (abbreviated to: 870-104, TCP/IP communication). The settings for protocols -101 and -104 differ.

In the **main window**, you can choose the protocol you want to use and define general settings:

- ▶ (Protocol) 870-101 (A pagina: 90)
Unlocks the settings for protocol 101 and locks other, irrelevant input fields.
- ▶ (Protocol) 870-104
Unlocks the settings for protocol 104 and locks other, irrelevant input fields.

DEVICES SECTION

Devices (connections) are created and deleted in the **Devices** section of the main window. A **device** defines how the Process Gateway, as an IEC870 slave, should work for a certain 870 master. These **devices** are configured in the tabs. Several devices (connections) can be set up - for several masters.

The following tabs are available in the process gateway:

- ▶ **Device** (A pagina: 92) - general settings and master IP address (-104) or link address of the slave (-101).
- ▶ **Sector** (A pagina: 96) - settings valid for a Common Address of ASDU (COA). A device should contain at least one sector; and one sector should contain at least one Information Object (IO):
 - **Information Objects** - the list of the Information Object Address (IOA), their Type Identifications (TID) and the assignment to zenon variables.
- ▶ Sequence of Events (SOE (A pagina: 133))
- ▶ **104 settings** (A pagina: 113)



Info

Only the general properties are documented in this section. You can find the protocol-dependent configurations in the section for the respective protocol (101) or in the description of the respective device settings (101 and 104).

Settings

Settings

Configuration file
IEC870SLAVE.XML Import... Export...

☐ 870-104 ☒ 870-101

Port Link Address Size COM Port Baud Rate
2404 1 COM 1 9600

☐ Deactivate standard DPI/DCS mapping and use internal mapping (not recommended).

Devices

Device	Name
--------	------

Add Delete

Device **Sector** **SOE** **104 settings**

Common Settings

Name
Test_1

Short Pulse Long Pulse Max. user data
1000 ms 2000 ms 253 ☒ Commands active

File Transfer Directory File Transfer in Control Direction Directory

870-101 specific

COA Size COT Size IOA Size Link Address Master Polling Timeout
2 2 3 1 0 s

870-104 specific


IP-Address
0 . 0 . 0 . 1

OK Cancel Help

Parameter	Description
Settings	
Configuration file	<p>Name of the configuration file. This is where all active settings are stored and also loaded from. The name you enter must be a valid file name. Otherwise, no data can be stored. In this case, you will get an error message.</p> <p>Only enter the file name without path. You do not have to add the file extension XML, as it will be added automatically during saving. The current INI directory will be used as path.</p> <p>The file name will automatically be entered in the INI file of the process gateway as configuration.</p> <p>You can find the INI file in the system folder of the process control system. It is called '<SCADA>ProcGateway.ini' - <SCADA> is the placeholder for the name of the process control system.</p>
Import...	<p>Loads configuration data from an XML configuration file. The current settings are replaced by the ones stored in the file. The current setting for the 'configuration file' remains the same.</p>
Export...	<p>Stores the current settings in a file.</p> <p>Attention: Device that still have the default ID '????' (defined during creation) will not be exported. To export them, you must first configure the device in the configuration window "Device" (A pagina: 92).</p>
870-104	<p>Activates protocol 104 (data layer via TCP), unlocks all input fields for 104 and locks settings only relevant to 101.</p>
Port	<p>Slave TCP/IP port; the port to which the masters connect.</p> <p>Default: 2404</p> <p>Note: Inactive if 870-101 is selected as a protocol.</p> <p>It is possible to have several instances of the Process Gateway running at the same time. That is why you can change this port:</p> <p>Allowed port numbers: 1200 to 65535</p>
870-101	<p>Activates protocol 101 (serial data layer), unlocks all input fields for 101 and locks settings only relevant for 104.</p>
Deactivate standard DPI/DCS mapping and use internal mapping (not recommended).	<p>Deactivates the standard communication via DPI/DCS and uses internal mapping in communication.</p> <p>Default: Inactive</p> <p>Inactive: The transfer (between the Process Gateway and an 870 master) in accordance with the protocol. It is also guaranteed that the values of the zenon variables assigned to the DPI/DPC are suitable for command processing and ALC:</p> <ul style="list-style-type: none"> ▶ zenon value 0 = DPI/DCS value 1 (= OFF) ▶ zenon value 1 = DPI/DCS value 2 (= ON) ▶ zenon value 2 = DPI value 0

	<p>► zenon value 3 = DPI value 3</p> <p>Note: It is not recommend to activate the setting.</p>
Devices	List of configured devices.
Add	Adds a new device with standard settings. By default, it gets the invalid ID '????' and invalid IP/link addresses. Before you can use or export the device, you must configure it.
Delete	Deletes the selected device. This button is not active if no device has been selected.
Device	Tab for the configuration of the devices (A pagina: 92)
Sector	Tab for the configuration of the sectors (A pagina: 96)
SOE	Tab for the configuration of the sequence of events (A pagina: 133)
104 settings	Tab for 870-104 protocol-specific configuration not the timeout. Note: Not active if 870-101 is selected as a protocol.
OK	Accepts all changed settings. They will immediately be stored in the current configuration file (as defined in the Configuration file). Attention: By clicking on 'OK', all existing connections to 870 masters are closed and communication is restarted. There may be communication errors during that.
Cancel	Discards all changed settings. Nothing is saved, the pre-existing communication is not interrupted.
Help	Apri la guida online.

9.1.1 Communication settings for 870-101



Settings

Settings

Configuration file
IEC870SLAVE.XML Import... Export...

☐ 870-104 ☒ 870-101

Port: 2404 Link Address Size: 1 COM Port: COM 1 Baud Rate: 9600

☐ Deactivate standard DPI/DCS mapping and use internal mapping (not recommended).

Devices

Device	Name

Add Delete

Device Sector SOE 104 settings

Common Settings

Name: Test_1

Short Pulse: 1000 ms Long Pulse: 2000 ms Max. user data: 253 ☒ Commands active

File Transfer Directory: File Transfer in Control Direction Directory:

870-101 specific

COA Size: 2 COT Size: 2 IOA Size: 3 Link Address: 1 Master Polling Timeout: 0 s

870-104 specific

IP-Address: 0 . 0 . 0 . 1

OK Cancel Help



Info

Only the general properties of the 870-101 protocol are documented in this section. You can find further information in the general description of the respective device settings.

Parameter	Description
Settings	
870-104	activates protocol 104, unlocks all input fields for 104 and locks settings for 101.
870-101	activates protocol 101, unlocks all input fields for 101 and locks settings for 104.
Link Address Size	<p>Size, in bytes, of the slave's link address. Default: 1</p> <p>Note: Applicable to all connections to masters. Inactive if 870-104 is selected as a protocol.</p>
COM Port	<p>Serial interface of the computer with zenon Runtime. Default: COM 1</p> <p>Note: Applicable to all connections to masters. Inactive if 870-104 is selected as a protocol.</p>
Baud Rate	<p>Data transfer rate. Default: 9600</p> <p>Note: Applicable to all connections to masters. Inactive if 870-104 is selected as a protocol.</p>

9.1.2 Devices


Parameter	Description
Device	ID of the device: IP address of the master (104) or link address of the slave (101). Default: ? ? ? ? (Not defined) Attention: Before you can use or export the device, you must configure it.
Name	Name of the device/connection - desired text for easier identification.
Add	Adds a new device with standard settings. By default, it gets the invalid ID " ? ? ? ? " and invalid IP/link addresses. Attention: Before you can use or export the device, you must configure it.
Delete	Deletes the selected device. This button is not active if no device has been selected.

Devices are created or deleted on the left-hand side of the dialog.

Clicking on the **Add** button adds a device, which is configured in the Device, Sector, SOE and 104settings tabs. Several devices can be created. A simple click on the respective device in the list opens the attendant configuration.

Device

In the part of the main window called '**Device**' you can define the settings of the device. Certain areas are grayed out depending on the protocol selected. A precise definition of which input fields are available for which protocol is in the list below.



Device | Sector | SOE | 104 settings

Common Settings

Name

Short Pulse: 1000 ms Long Pulse: 2000 ms Max. user data: 253 ☒ Commands active

File Transfer Directory: File Transfer in Control Direction Directory:

870-101 specific

COA Size: 1 COT Size: 1 IOA Size: 2 Link Address: -1 Master Polling Timeout: 0 s

870-104 specific

IP-Address: 255 . 255 . 255 . 255

Parameter	Protocol	Description
Common Settings		
Name	101 104	Name of the device for easy identification
File transfer directory	101 104	Defines the directory for transfer of files and directories. Note: The files are sent to the master.
File Transfer in Control Direction Directory	101 104	Defines the directory in which the files for transfer of files and directories are stored. Note: These files are received by the master. All files with the NOF 255 (the temporary NOF for reverse file transfer) are ignored for the directory query.
Short pulse	101 104	Defines the size of the pulse for the Qualifier of Command (A pagina: 131) with the value 'short pulse duration' (QOC = 1) in milliseconds. Valid values: 0 bis 4294967295 Default: 1000 ms
Long pulse	101 104	Defines the size of the pulse for the Qualifier of Command (A pagina: 131) with the value 'long pulse duration' (QOC = 2) in milliseconds. Valid values: 0 to 4294967295. Default: 2000 ms
Max APDU size	104	Maximum length of APDU data as defined in the standard 870-5-104. Valid values: between 25 and 253. Default: 253
Max. user data	101	Maximum length of User Data as defined in TF1.2 870-5-2 3.2. Valid values: between (19 + LAF size + COA size + COT size + IOA size) and (255). Default: 253
Commands active	101 104	This option allows commands from the master to be prevented on a lasting basis. If the setting is deactivated, the commands are not accepted and error entries are made in the log. Note: The commands can be dynamically activated or deactivated using a variable in zenon (T00, IOA 2) (A pagina: 125).

		Default: active
--	--	-----------------


870-101 SPECIFIC

870-101 specific		
COA size	101	<p>Defines the length of the COA (Common Object Address/Common Address of ASDU).</p> <p>Selection of address size from drop-down list:</p> <ul style="list-style-type: none"> ▶ 1 octet ▶ 2 octets ▶ Note: If the 60870-5-104 (TCP/IP) connection type is selected for link layer, the value 2 octets is expected in accordance with the standard. Only change the default value for a connection with a non-compliant PLC. <p>Default: 2</p>
COT size	101	<p>Defines the length of the COT (cause of transmission).</p> <p>Selection of address size from drop-down list. Valid:</p> <ul style="list-style-type: none"> ▶ 1 octet ▶ 2 octets ▶ Note: If the 60870-5-104 (TCP/IP) connection type is selected for link layer, the value 2 octets is expected in accordance with the standard. Only change the default value for a connection with a non-compliant PLC. <p>Default: 2</p>
IOA size	101	<p>Defines the length of the IOA (Information Object Address).</p> <p>Selection of address size from drop-down list. Valid:</p> <ul style="list-style-type: none"> ▶ 1 octet ▶ 2 octets ▶ 3 octets ▶ Note: If the 60870-5-104 (TCP/IP) connection type is selected for link layer, the value 3 octets is expected in accordance with the standard. Only change the default value for a connection with a non-compliant PLC. <p>Default: 3</p>

Link address	101	<p>Link address Via the link address contained in the TF 1.2 frame, the master specifies the device that the command is intended for. With link addresses, a Master can communicate with multiple devices. The allowed range of the address depends on the Link Address Size setting in the main settings.</p> <p>Link address size = 1 allows a range of 0 to 254 Link address size = 2 allows a range of 0 to 65534</p> <p>Default: -1 (invalid)</p> <p>Note: The current value is lost if the protocol is changed.</p>
Master polling timeout	101	<p>Shows the time in seconds in which the master must execute a query to the slave.</p> <p>If there is no query within this time, the connection is ended.</p> <p>Default: 0</p> <p>Note: 0 deactivates the monitoring.</p>
870-104 specific		
IP-Adress	104	<p>IP address of the Master. This allows to identify the device that the Master communicates with. All IP addresses except 255.255.255.255 are allowed.</p> <p>Note: The current value is lost if the protocol is changed.</p>

Sector

The **Sector** tab lists all sectors defined in the device. If you select a sector, its **Information Objects** (A pagina: 100) (IOs) will be displayed.



Parameter	Description
Sectors	
New	Activates the dialog for creating a new sector (A pagina: 97). You close this subsequent dialog and create a new sector by clicking on OK .
Edit	Activates the dialog for editing the selected sector. You can also launch the editor by double-clicking on the sector in the list. This button is inactive if no sector was selected.
Delete	Deletes the selected sector. This button is inactive if no sector was selected.
Information Objects	
New	Activates the dialog for creating new IOs (A pagina: 100). This subsequent dialog is closed and a new IO is created by clicking on 'OK'. This button is inactive if no sector was selected.
Edit	Activates the dialog for editing the selected IO. You can also launch the editor by double-clicking on the IO in the list. This button is inactive if no IO was selected.
Delete	Deletes the selected information object. This button is inactive if no IO was selected.

Sector Settings

Sector settings

Sector Settings

Name COA

Time for Background Scan Time for Periodic Transfer

min s

☐ Select routing

Select Timeout:

s

Transmission of Integrated Totals

☒ With general interrogation

☐ Mode A: Local freeze with spontaneous transmission

☐ Mode B: Local freeze with counter interrogation

☐ Mode C: Freeze and transmit by counter interrogation commands

☐ Mode D: Freeze by counter interrogation command, frozen values spontaneous

OK Cancel Help

Parameter	Description
Name	Any name. For easy identification of a sector.
COA	The COMMON ADDRESS OF ASDUs (IEC 60870-5-101 7.2.4) by which the sector is addressed. This number must be unique for each device (1..254).
Time for Background scan [min]	The "Background scan" cycle in accordance with the requirements of the IEC 60870-5-101 standard, chapter 7.4.13 "Background scan". The values are sent with COT = 2. The time is shown in minutes. Values are transferred cyclically in the time grid set up for all IOs with the "Background Scan" option activated. Values are only transferred cyclically if no spontaneous value is transferred within the time set. If the value is "0", cyclical transfer of values is deactivated for this sector. Default: 0
Time for periodic transfer [s]	Support of cyclical data transfer corresponding to the norm (IEC 60870-5-5 6.3). The values are sent with COT = 1. The time is configured in seconds. Values are transferred cyclically for all IOs with the "Periodic data transfer" option activated. IOs are transferred cyclically and not spontaneously. If the value is "0", cyclical transfer of values is deactivated for this sector. Default: 0
Select routing	If active, a prior select is necessary for an Execute when the command is executed. The switching commands from the master are forwarded using the command processing - via the <code>auto/remote</code> actions - to the respective Energy driver in zenon Runtime.
SBE Timeout [s]	Timeout in seconds within which the select process must be completed and an Execute is triggered. If there is no confirmation of the select from zenon Runtime or the select has been confirmed but the master does not send an execute - the Process Gateway cancels the process. Note: Inactive if select routing is not active. Default: 30 s Input range: 1 bis 65535
Transmission of integrated totals	Selection of the transfer mode (see IEC 60870-5-101 7.4.8) for the integrated totals - the IOs of type ID: <ul style="list-style-type: none"> ▶ 15 (M_IT_NA_1) ▶ 16 (M_IT_TA_1)

	<p>► 37 (M_IT_TB_1)</p> <p>No reset is supported. An FRZ with a reset triggers a warning in the LOG.</p> <p>For modes A to D, IOs are requested immediately after connecting to the master of zenon. Value changes to integrated totals IOs are administered in their own buffer. This can buffer the larger value of (ITs IO number) * 4, or 2048 value changes.</p>
With general interrogation	Integrated Totals are also transferred during a general interrogation (C_IC_NA_1).
Mode A: Local freeze with spontaneous transmission	Integrated totals are transferred when a value is changed.
Mode B: Local freeze with counter interrogation	Integrated totals are only transferred with a counter interrogation command (C_CI_NA_1). To do this, a maximum of five seconds is waited after the interrogation is activated until all ITs have been supplied with values. ITs without a value are transferred with an <i>invalid</i> qualifier. The value changes are buffered until the interrogation is completed (freeze active). All ITs thus transfer the value of the point in time, when the last IT was supplied with a value.
Mode C: freeze and transmit by counter interrogation Transmission of integrated totals commands	As with mode B.
Mode D: freeze by counter interrogation command, frozen values spontaneous	Transfer as with mode C, mode A is activated after conclusion of the interrogation.
OK	By pressing the button OK , you can check whether the COA is available in the device. If it is already in use you will receive an error message. If it is available, the setting is accepted and the dialog is closed.
Cancel	Discards all entries and closes the dialog.
Help	Apri la guida online.

Information Objects

Information object settings

Settings

Information Object
1

Type Identification
<0> Internal status

SCADA Variable
...

Data Transfer
☒ Spontaneous
☐ Background Scan
☐ Periodic Data Transfer
☐ Off
☐ Spontaneous, buffered when master is offline

Sequence of Events
☒ Inactive
☐ All Events
☐ Raising Edge
☐ Falling Edge
☐ Raising & Falling Edge

☐ File Trigger

Hysteresis
Negative
0

Positive
0

OK Cancel Help

SETTINGS

Parameter	Description
Information Object	<p>Defines the address (IOA) under which the IO is addressed (IEC 60870-5-101 7.2.5). In combination with the type ID (Type identifications), it must be unique for each sector.</p> <p>Default: 1</p>
Type identification	<p>Drop-down list with the supported Type identifications (IEC 60870-5-101 7.2.1).</p> <p>Default: <0> Internal status</p> <p>This setting is also called type ID.</p> <p>It also determines the variables of the process control system that can be associated to the IO based on their data type.</p> <p>Note: You can also find more detailed information on type ID in the chapters Assignment of data types (A pagina: 106) and Interoperability (A pagina: 145).</p>
SCADA variable	<p>Defines the variable from the process control system associated with the IO. Syntax: <Project name>#<variable name> define the project connection. If there is no project reference for a variable, it is assumed that this variable is present in the start project.</p> <p>While entering, the system checks if the specified variable exists in the according project and if it has a data type compatible with the type identification.</p> <p>The Button '...' opens the dialog for variable selection.</p> <p>Read more about this in the section 'Variable selection (A pagina: 105)'. (Scada stands for the name of the process control system.)</p>
Data Transfer	<p>Determines the type of data transfer for IOs</p> <p>Default: Spontaneous</p>
Spontaneous	IO data transfer is spontaneous.
Background Scan	<p>IOs are transferred as a background scan in accordance with the IEC 60870 norm. A data point that does not receive a new spontaneous value within the set background scan time is automatically sent by the gateway after the time has expired. Values are only transferred if no spontaneous value has yet been transferred within the time set.</p> <p>The setting is inactive if the background scan is locked in the sector (Time=0) or if the type ID used is not suitable for a background scan in accordance with the protocol. Permitted type IDs:</p> <ul style="list-style-type: none"> ▶ M_SP_NA_1 and M_SP_TA_1, M_SP_TB_1 - for T01, ▶ M_DP_NA_1 and M_DP_TA_1, M_DP_TB_1 - for T03, ▶ M_ST_NA_1 and M_ST_TA_1, M_ST_TB_1 - for T05, ▶ M_BO_NA_1 and M_BO_TA_1, M_BO_TB_1 - for T07,

- ▶ M_ME_NA_1 and M_ME_TA_1, M_ME_TD_1 - for T09,
- ▶ M_ME_NB_1 and M_ME_TB_1, M_ME_TE_1 - for T11,
- ▶ M_ME_NC_1 and M_ME_TC_1, M_ME_TF_1 - for T13

Note: The type IDs with time stamp (for example M_ME_TA_1) is mapped to the corresponding TID without time stamp (for example M_ME_NA_1) in the process of sending the background scan.

The setting is not available for any other type ID.

Periodic Data Transfer	<p>Periodic data transfer in accordance with IEC 60870-5-5-6.3 norm.</p> <p>IOs are transferred cyclically and not spontaneously.</p> <p>The setting is inactive if periodic data transfer is locked for the sector (Time=0) or if the type ID used does not support periodic data transfer.</p> <p>Only the type ID=9, 11 and 13 support a periodic transfer - M_ME_NA_1, M_ME_NB_1, M_ME_NC_1 - "measured values" without time stamp.</p> <p>The setting is not available for any other type ID.</p>
Off	<p>Changes in value are not transferred. No value is sent for the IO during a general interrogation (GI).</p>
Spontaneous, buffered when master is offline	<p>When a connection fails, the data is buffered until the master connects again. All buffered data is sent with the status COT_spont (3). The last buffered value is sent with the status COT_inrogen (20) again.</p> <p>Buffering can be activated for the type IDs <30..37>:</p> <p>M_SP_TB_1, M_DP_TB_1, M_ST_TB_1, M_BO_TB_1, M_ME_TD_1, M_ME_TE_1, M_ME_TF_1 und M_IT_TB_1</p> <p>Note: Only type IDs that have a time stamp with a date are permitted as Events ("time tag CP56Time2a").</p> <p>The setting is not available for any other type ID.</p>
Sequences of events	<p>These settings define the IO-specific behavior for SOE. The SOE transfer (see IEC norm 60870-5-101 7.4.11.3.1) can also be activated for the type IDs <30..37>:</p> <p>M_SP_TB_1, M_DP_TB_1, M_ST_TB_1, M_BO_TB_1, M_ME_TD_1, M_ME_TE_1, M_ME_TF_1 und M_IT_TB_1</p> <p>Note: Only type IDs that have a time stamp with a date are permitted as Events ("time tag CP56Time2a").</p> <p>Default: Inactive</p>
Inactive	<p>Data point is not used for SOE description.</p> <p>Is automatically used for all type IDs that do not support SOE.</p>
All events	<p>Each value or status change triggers a write in the open file.</p> <p>The setting is blocked if the type ID if not planned for the SOE function.</p>
Raising Edge	<p>If the value changes from 0 to <> 0, then it triggers the write mode in the open file.</p> <p>The setting is blocked if the type ID if not planned for the SOE function.</p>
Falling Edge	<p>If the value changes from <> 0 to 0, then it triggers the write mode in the open file.</p> <p>The setting is blocked if the type ID if not planned for the SOE function.</p>
Raising + Falling Edge	<p>A change of value from 0 to <> 0 or from <> 0 to 0 triggers a write in the open file.</p> <p>The setting is blocked if the type ID if not planned for the SOE function.</p>

File trigger	<p>If a value is to be written due to the settings previously described, a new file is created and opened for the activated file, provided this has not yet been opened. The trigger event itself is also written to the SOE file.</p> <p>The setting is blocked if the type ID is not planned for the SOE function.</p> <p>Default: <i>Inactive</i></p>
Hysteresis	<p>Value changes that are within the hysteresis are ignored - not transferred to the master.</p> <p>Hysteresis is applicable for the permitted TID ("measured values") and only if these have been configured for spontaneous data transfer.</p> <p>A transfer is therefore triggered:</p> <ul style="list-style-type: none"> ▶ If Type Identification allows hysteresis. The Type Identifications <9> to <14> and <34> to <36> are permitted. ▶ If Data Transfer = <i>spontaneous</i> ▶ With a value change that acts \geq the hysteresis (according to the direction). <p>And notwithstanding the hysteresis:</p> <ul style="list-style-type: none"> ▶ Change of the quality (status bits of the variable) always triggers the transfer; ▶ The response to a GI (C_IC_NA_1) and a read (C_RD_NA_1) command is always the current value.
Negative	<p>Negative hysteresis, starting from measuring range of the variable.</p> <p>Default: 0</p> <p>Note: not active if type identification is not <9> to <14> or <34> to <36>. This field is also inactive if the value Data Transfer is not <i>spontaneous</i>.</p> <p>Erroneous and meaningless entries (such as text input or incorrect hysteresis values) are ignored and must be corrected by the engineer of the project.</p>
Positive	<p>Positive hysteresis, starting from measuring range of the variable.</p> <p>Default: 0</p> <p>Note: not active if type identification is not <9> to <14> or <34> to <36>. This field is also inactive if the value Data Transfer is not <i>spontaneous</i>.</p> <p>Erroneous and meaningless entries (such as text input or incorrect hysteresis values) are ignored and must be corrected by the engineer of the project.</p>
OK	<p>Your settings are verified after pressing the button "OK". If they are valid, they are accepted and the dialog is closed.</p>

Cancel	Discards all entries and closes the dialog.
Help	Apri la guida online.




Info

The communication for *Spontaneous data transfer*, *Background Scan* and *Periodic Data Transfer* starts once the first general request has been received (*C_IC_NA_1*). For background scan and periodic data transfer, the start of the transfer cycle is calculated per IO from the time of the answer to the general query.

Data point selection

This dialog lists all available projects and their variables.



Parameter	Description
Projekte	An asterisk (*) marks the default project.

Variablen	The list of variables is filtered. You only see the variables that can be used with the 'type identification' selected for the IO. Selecting a project updates the list of variables.
OK	<p>Assumes the selected variable. Alternatively, the variable can be assumed by double clicking. When loading, the currently configured project and the variable will be selected.</p> <p>The same variable can be used several times: for several IOs in the same sector or other sectors, for the same device or another one.</p> <p>If the dialog remains open and there is a reload in the Runtime, all lists will be emptied and refilled after the reload is finished.</p>
Cancel	Discards all entries and closes the dialog.
Help	Apri la guida online.

Mapping of the data types

The zenon data types are compared to the IEC60870 data types in the following table.

Process Gateway		zenon	
IEC 60870-5-101 ASDU	Type identification	Data type	Comment
M_SP_NA_1	1	BOOL	
M_SP_TA_1	2	BOOL	
M_SP_TB_1	30	BOOL	
M_DP_NA_1	3	USINT	
M_DP_TA_1	4	USINT	
M_DP_TB_1	31	USINT	
M_ST_NA_1	5	USINT	Corresponds to whole VTI (IEC60870-5-101 7.2.6.5). Bit 8 is the Transient bit.
M_ST_TA_1	6	USINT	Corresponds to whole VTI (IEC60870-5-101 7.2.6.5). Bit 8 is the Transient bit.
M_ST_TB_1	32	USINT	Corresponds to whole VTI (IEC60870-5-101 7.2.6.5). Bit 8 is the Transient bit.
M_BO_NA_1	7	UDINT	
M_BO_TA_1	8	UDINT	
M_BO_TB_1	33	UDINT	
M_ME_NA_1	9	REAL	If, in zenon, values of the variables in the norm range for 'normalized values' $<-1 \dots 1-2^{-15}>$ are gone below or exceeded, the value of the IO is amended in ASDU and the OV quality bit is set.
M_ME_TA_1	10	REAL	If, in zenon, values of the variables in the norm range for 'normalized values' $<-1 \dots 1-2^{-15}>$ are gone below or exceeded, the value of the IO is amended in ASDU and the OV quality bit is set.
M_ME_TD_1	34	REAL	If, in zenon, values of the variables in the norm range for 'normalized values' $<-1 \dots 1-2^{-15}>$ are gone below or exceeded, the value of the IO is amended in ASDU and the OV quality bit is set.
M_ME_NB_1	11	INT	


M_ME_TB_1	12	INT	
M_ME_TE_1	35	INT	
M_ME_NC_1	13	REAL	
M_ME_TC_1	14	REAL	
M_ME_TF_1	36	REAL	
M_IT_NA_1	15	DINT	
M_IT_TA_1	16	DINT	
M_IT_TB_1	37	DINT	
M_EI_NA_1	70	USINT	A value change from 126 to 127 causes End of initialization to be sent to the master
C_SC_NA_1 (A pagina: 131)	45	BOOL	
C_SC_TA_1	58	BOOL	mirrors the command direction during execution

C_DC_NA_1	46	USINT	mirrors the command direction during execution
C_DC_TA_1	59	USINT	mirrors the command direction during execution
C_RC_NA_1	47	USINT	mirrors the command direction during execution
C_RC_TA_1	60	USINT	mirrors the command direction during execution
C_SE_NA_1	48	REAL	mirrors the command direction during execution
C_SE_TA_1	61	REAL	mirrors the command direction during execution
C_SE_NB_1	49	INT	mirrors the command direction during execution
C_SE_TB_1	62	INT	mirrors the command direction during execution
C_SE_NC_1	50	REAL	mirrors the command direction during execution
C_SE_TC_1	63	REAL	mirrors the command direction during execution
C_BO_NA_1	51	UDINT	mirrors the command direction during execution

C_BO_TA_1	64	UDINT	mirrors the command direction during execution
C_IC_NA_1	100	-	Is executed automatically and the execution is not reflected in zenon
C_CI_NA_1	101	-	Is executed automatically and the execution is not reflected in zenon
C_RD_NA_1	102	-	Is executed automatically and the execution is not reflected in zenon
C_CS_NA_1	103	BOOL	The enable variable of the time synchronization
C_TS_NA_1	104	-	Is executed automatically and the execution is not reflected in zenon
C_TS_TA_1	107	-	Is executed automatically and the execution is not reflected in zenon
C_RP_NA_1	105	USINT	QRP during execution
F_DR_TA_1	126	USINT	For spontaneous directory transfer

Sector

XML FIELDS



CNT_MODE	0
ToSbe	45000
SBE	1

(This taq has no subtaqs.)

Parameter	Description
Version	The CNT_MODE field is expected from version 3 onwards.
CNT_MODE	Configured mode of integrated totals IOs.
Sector	<p>The new items ToSBe and ob SBE are added for the sector:</p> <ul style="list-style-type: none"> ▶ ToSBe: Timeout [ms] for Select before execute: 1000 - 65535000 ▶ SBE: 0 => not required 1 => necessary for execute

CONFIGURED MODE

Parameter	Description
0	With general interrogation. (Default)
1	Mode A
2	Mode B
3	Mode C
4	Mode D

ERROR CODES

Code	Description
13	Advise for integrated totals fail.
14	Queue overrun. Integrated totals values lost.
16	Advise failed for command variable
17	<p>List of value changes for command variables with SBE too long. Value change has been lost.</p> <p>2048 value changes are buffered as a minimum, or four times the number of active Select Before Execute (SBE) - depending on which value is greater.</p>
572	Counter interrogation. Unsupported QCC.
573	Counter interrogation. Unexpected IOA.
574	Counter interrogation. Unsupported COT.
575	Buffer for integrated totals interrogation data too small.

WARNINGS

Code	Description
1011	QCC FRZ is only partly supported.
1012	Counter interrogation already active.
1014	Activation confirmation already confirmed.

ERROR MESSAGE

Message	Description
Unsupported qualifier of counter interrogation. <command>	Unknown QCC. RQT is only supported with 5.
Counter interrogation processed without reset. < command>	Warning. Reset is not supported.
Can't advise IT data point. Device:(<device>)<device> Sector:(<COA>)<Sektortname> adv:0x<Advise-ID>	Data points for integrated totals could not be requested.
IT Values lost, queue full! Device:(<device>)<device> Sector:(<COA>)<Sektortname> <Wertänderung>	The buffer for the value changes of IT IOs is full. The value change is lost.

104 settings

In the **104 settings** tab, you set the timeout times and the number of APDUs . The settings should be the same for slave and master. If a master overwrites a timeout or the number of frames to be confirmed, the slave closes the connection.

Device
Sector
SOE
104 settings

Timeouts

T0: Timeout for connection establishment

T1: Timeout for send or test APDUs

T2: Timeout for ack. in case of no data msg.

T3: Timeout for sending test frames

Hint: Set timeout to 0 to disable it

APDUs

k: Maximum difference receive sequence no. to send state variable

w: Latest acknowledge after receiving w I-Format APDUs

Reset to defaults

Note: The input fields of this tab are only available if 870-104 has been selected as a protocol.

Parameter	Description
Timeouts	Timeout settings of the connection
T0: time-out of connection establishment	Timeout for establishing connection. Value range 0 - 4294967295 Default: 30000 There should also be at least one u-frame from the master in that time.
T1: Time-out send or test APDUs	Timeout for frame confirmation by the master. Value range: 0 - 4294967295 Default: 15000
T2: Time-out for ack. in case of no data msg	Timeout, within which the master should confirm if no data is exchanged. Value range: 0 - 4294967295 Default: 10000
T3: Time-out for sending test frames	Time after which a U-frame is sent to the master if no data is to be transferred. Value range: 0 - 4294967295 Default: 20000
APDUs	<i>Settings for the ISO 7816 standard: Application Protocol Data Unit (APDU).</i>
k: Maximum difference receive sequence nr to send state	Number of maximum I-frames not yet confirmed by the master. Value range: 0 - 4294967295 Default: 12
w: Latest acknowledge after receiving w I-Format APDUs	Number of I-frames received after a confirmation is sent. Value range: 0 - 4294967295. Default: 8



Info

The **Reset to default** button resets all input to the values prescribed by the standard.

9.1.3 Mapping of double point values

Double Point Value Mapping Is a standard function of the zenon Energy driver. It only influences zenon Runtime and has no effect on the driver communication with a device. Configuration is carried out in the driver settings in the **Basic Settings** tab.

Note: It is recommended that you leave the **Deactivate standard double point value mapping** option in the driver configuration as the default, inactive.

The driver uses Double Point Value Mapping to convert values so that they are displayed in a user-friendly manner. However this only applies to the HMI.

The driver always communicates with one device with values for Double Points with 2-bit information. This corresponds to the definitions of the energy standard. That means:

Parameter	Double Point	Value	Meaning
Intermediate	00b	0	Switches are neither open nor closed, for example the End-Position has not yet been reached
Off	01b	1	Switch open
On	10b	2	Close switch/switch closed
Fault	11b	3	Error

Double Points are coded with 2-bits in the energy sector for historical reasons: The transmission of a telegram to a serial connection (RS232) with a series of values that only contain 0 was not safeguarded against transmission errors. In order to increase the certainty, it was decided in the first standards that the value for **OFF** is not to be sent as 0 but as 01b, which corresponds to decimal 1. These Double Point Values also precisely reflect the type of how two sensors record the physical position of a switch.

However, the values sent this way may be confusing for people:

- ▶ OFF = 1
- ▶ ON = 2

Humans are used to all other devices and systems:

- ▶ OFF = 0
- ▶ ON = 1

At the same time, Single Point Values are also defined with **OFF = 0** in the same standard.

The user must always be aware of the technical level on which they are acting and receiving or sending information. In stressful situations, this can very easily lead to serious mistakes. For example, if **ON** is sent instead of **OFF**.

In order to avoid this dangerous error, the zenon Energy driver offers its own Double Point Value Mapping.

MAPPING VOR HMI

With the Double Point Value Mapping, all Double Points in zenon have the following values:

- ▶ Intermediate = 2
- ▶ Off = 0
- ▶ On = 1
- ▶ Fault = 3



Info

This function can be deactivated in the driver settings. However some features such as Command Processing or ALC can no longer be used then.

Recommendation: Do not use numerical elements and numerical values to display OFF/ON or OPEN/CLOSE. Use combined elements with graphic symbols or text elements instead.

DPI MAPPING IN IEC61850 CLIENT DRIVER

In accordance with the IEC61850-7-3 standard, in Common Data Classes, Double Point Status (DPS) and Controllable Double Point (DPC), the `stVal` attribute has the data type `CODED_ENUM` with the value range: intermediate-state (00) | off (01) | on (10) | bad-state (11). The driver therefore waits until a Double Point attribute of the data type `CODED_ENUM` is mapped to the communication protocol as an MMS of the `bit_string` data type. The `stVal` data attribute can thus have the following values: 0x00, 0x40, 0x80 and 0xC0. This basic data type is permitted in the SCL language with the name `Dbpos` (IEC61850-6). In zenon, this corresponds to a variable with data type UDINT (default) or STRING (if changed manually) - see assignment of datatypes.

In the driver configuration, the **Deactivate standard double point value mapping** option should remain inactive by default in order to use the modules from the zenon Energy Edition, for example the functions of **Command Processing** and **ALC**.

With the default settings, the driver assigns values of the `stVal` data attributes of DPS and DPC in accordance with the following table:

Position value in the end device	zenon Dbpos value - STRING	zenon Dbpos value - UDINT unmapped	zenon Wert - value mapped
Intermediate (00b)	'00'	0	2
Off (01b)	'01'	64 (0x40)	0
On (10b)	'10'	128 (0x80)	1
Fault (11b)	'11'	192 (0xC0)	3

The driver only converts values for variables with the names `*/stVal` and numerical data type that corresponds to `bType 'Dbpos'` in the SCL language (IEC61850-6). This means that the values of the `*/stVal` variable with a data type set to STRING manually are excluded from mapping.

This means in Runtime (for example):

Position of the switch	UDINT mapped	UDINT unmapped	STRING
off	0	64	'01'
on	1	128	'10'

9.1.4 XML-File

The configuration of the IEC870SI is stored in an XML file. You can import and export different configurations with the buttons **'Export'** and **'Import'** in the main window.

The active configuration is stored in the INI file, for example:

[IEC 870]

SETTINGS=IEC870SLAVE.XML

You can choose any name. The path is the same as in the INI file.

STRUCTURE OF THE XML FILE

The names of most fields intuitively indicate their meaning. The settings correspond to those that are permitted in the dialog.

The values and structure of the XML file are verified when the file is read. Erroneous entries trigger an error message that is also logged.



Attenzione


XML entries are case sensitive. Pay attention to use correct upper and lower cases.

Name	Property
process_gateway_IEC870Slave	The root node must have this name. Otherwise, the reading process will stop with an error.
VERSION	Contains the current version of attributes and nodes.
Device_x	Nodes for the device configuration. X is replaced by a consecutive number, starting with 1. This way of naming nodes is not obligatory. A device is created for every node.
LinkAdr	In protocol 101, the <code>link address</code> is set here. It must be unique for all devices. For protocol 104, this entry has no meaning.
IpAdr	In protocol 104, the IP address of the Master is entered here. It must be unique for all devices. For protocol 101, this entry has no meaning.
Sector_x	Number of nodes per configured sector. X is replaced by the COA. This way of naming nodes is not obligatory. A sector is created for every node.
IO_x	Number of nodes per information object. X is replaced by a consecutive number, starting with 1. This way of naming nodes is not obligatory. An IO is created for every node.
ScadaVar	When the document is loaded, the existence of the specified variable in the project is verified. Variables without project reference are looked for in the default project. [ScadaProjectName#]ScadaVariableName. (Scada stands for the name of the process control system.)
TypeId	Type identification When the document is loaded, the system will check if the type ID with the specified variable data type is possible.
COA	Common object address Must be unique for every device per sector.
IOA	Information object address In combination with the type ID, it must be unique per sector.
Is101active	With the value '1', the protocol 101 is activated, otherwise 104 will be active.
BSTime	Time for background scan Unit of measurement: ms. 0 deactivates the background scan. Default: 0
CYTime	time for cyclical data transfer Unit of measurement: ms.


	<p>0 deactivates the cyclical transfer.</p> <p>Default: 0</p> <p>Available in version 2 and above</p>
KindOfTransfer	<p>States the type of data transfer.</p> <p>0 Spontaneous. Is also the default value.</p> <p>1 backscan</p> <p>2 Cyclic</p> <p>3 off</p> <p>4 Spontaneous transfer with buffering</p> <p>Default: 0</p> <p>Available in version 3 and above</p>
DeActDPIStd	DPI /DCS compliant (IEC60870 compliant) data transfer or internal control system format
Version	6: describes an XML file with the following fields for SOE support
EnableSOE	<p>0 = inactive</p> <p>1 = SOE active</p>
MaxBufferedFilesSOE	Maximum number of buffered SOE files.
AutodeleteFilesSOE	<p>0 = no Autodelete</p> <p>1 = Autodelete if maximum file number reached</p>
MaxEventsPerFileSOE	Maximum number of ASDU per file
PostTrgToSOE	Post trigger timeout in [ms]
FileToSOE	File timeout in [ms]
Information Object Einstellung für die SOE Unterstützung	Additional settings that must be made at the Information Object for SOE support.
Version	4: describes an XML file with the following fields for SOE support
KindOfTransfer	<p>Defines when an update triggers a transfer.</p> <p>0 Spontaneous</p> <p>1 Background scan</p> <p>2 periodic</p> <p>3 no transfer</p>
TrgSOE	<p>0 = inactive</p> <p>1 = IO acts as trigger</p>
EvDetectionSOE	Determines when a change to an IO value or status can trigger a write in the SOE file.

	0 SOE active 1 Saves all changes. 2 Raising edges 3 Falling edges 4 Raising and falling edges
HysteresisNegative	Value of the negative hysteresis. Note: from zenon 7.11, the entry must exist for each IO.
HysteresisPositive	Value of the positive hysteresis. Note: from zenon 7.11, the entry must exist for each IO.

Example configuration for protocol 101:



Example configuration for protocol 104:



9.2 Communication

This chapter explains details on communication in the **Process Gateway**:

- ▶ Start (A pagina: 122)
- ▶ General query (A pagina: 122)
- ▶ Reset (A pagina: 123)
- ▶ Value changes (A pagina: 124)
- ▶ Priority (A pagina: 125)
- ▶ Read (A pagina: 138)
- ▶ Process Initialized (A pagina: 124)
- ▶ File transfer (A pagina: 131)
 - Storage and naming of files for transfer (A pagina: 131)
 - Spontaneous directory transfer (A pagina: 132)
- ▶ Sequence of Events (SOE) (A pagina: 133)
 - Warnings (A pagina: 135)

- Error message (A pagina: 136)
- ▶ Time synchronization (A pagina: 128)
- ▶ DPI / DCS mapping
- ▶ Select Before Operate (A pagina: 130)
- ▶ Qualifier of command (A pagina: 131)
- ▶ Invalid Bit Handling (A pagina: 129)
- ▶ Normalized Values
- ▶ Monitoring command (A pagina: 130)
- ▶ Internal type T00 (A pagina: 125)
- ▶ Pulse generation
- ▶ Reload project (A pagina: 125)
- ▶ Broadcasts (A pagina: 128)
- ▶ Realtime invalid - Statusbit T_INVALID
- ▶ Test commands (A pagina: 139)

9.2.1 Start

When the process gateway is started, it loads the configured driver.

The driver then attempts to read its active configuration from the file entered in the INI file. If this is not possible, an error message is displayed and the configuration dialog is opened.

If the dialog is not left with OK, the application closes.



Attenzione

If the application is launched as invisible, there will be no configuration dialog. The Process Gateway will automatically quit if its configuration is invalid or missing.

9.2.2 General query

The general query (GI) triggers an establishment of the connection to zenon Runtime in the IEC870 slave. The receipt of the `GI - C_IC_NA_1` - from a master is a requirement for spontaneous communication, Background scan or Periodic data transfer. This connection is built up in sectors (COA).

If the connection cannot be established in Runtime, there is a negative confirmation of the general query ($COT_{actcon} + PN$). The query that is already active for the sector is ended and a warning is logged.

A GI for a sector that does not exist in the slave (unknown COA) is confirmed in the negative ($COT=46 + PN$) and the connection to the master is disconnected. This is an indicator for a configuration error in the system.

For general queries, the slave supports the global address $COA=0xFF(FF)$. You can find detailed information on this in the Broadcast (A pagina: 128) chapter. A master can thus query several sectors with just one GI. This is an alternative envisaged by the standard, which the master can use. Otherwise a master must query the sectors consecutively (one after the other).

If the master sends a further GI whilst the current one has not yet been concluded, the ongoing GI is canceled and the new one is started. Overlapping GIs are logged as a warning. This is an indication of non-standard-compliant behavior with a master.

Value changes for IOs whose value has already been reported to the master as part of the current GI are buffered as long as the GI - due to other IOs is still running in the same sector (COA). If the buffer is overfilled, the current connection is disconnected. You can find further information on this in the Transfer of the value changes (A pagina: 124) chapter.

During a project reload (A pagina: 125), it is not possible to connect to the Runtime. The general request will fail in this case.



Attention

In accordance with the IEC60870 standard, a master must start communication with a general query. For this reason, the slave closes the connection if the master has not sent a GI in the envisaged time ($T0$).

The GI and buffers of the value changes are independent for different **Devices** (for different masters). A master can deactivate the ongoing general query by ASDU<100> with $COT_{deact}(8)$.

9.2.3 End of connection and resets

The reset in the slave is triggered if a master connects:

- ▶ 870-101: All commands will be rejected until the function code for reset (0) has been received. The code causes a reset in the link layer and the application layer.
- ▶ 870-104: As a result of the connection being disconnected, a master can detect the interruption immediately and starts the initialization process again.

ENDING COMMUNICATION

In general, communication is ended if:

- ▶ The Process Gateway application is ended
- ▶ Changes to the configuration of the slave are activated
- ▶ Runtime reloads
- ▶ the master has established the connection but no general query was sent
- ▶ The list of the value changes that have not been sent for the sector has overflowed
- ▶ A non-supported command has been received (command is answered in the negative and the connection is ended for security reasons).
- ▶ A command with a non-supported address is received (command is answered in the negative and the connection is ended for security reasons).

'Reset process command' - T105 - request

The slave can inform zenon Runtime of the receipt of a `C_RP_NA_1` command. To do this:

- ▶ create an IO of type `T105` with IOA 0.

If a master sends the command `C_RP_NA_1`, the value of the variable is first set to 0 and then to the value of `QRP`.

The slave confirms receipt of the command to the master and changes the value of the corresponding `T105` variable for Runtime but otherwise the command has no effect in the slave. The optional sending of the 'End of initialization' (`T70`) is not executed automatically.

'End of Initialization' - T70 - send

From the process control system, it is possible to instigate an `ASDU<70> - M_EI_NA_1` ('End of initialization') being sent to the master. To do this:

- ▶ create an IO of type `T70` with IOA 0.

The transfer is triggered if the current value of the variable is 126 and this is amended to 127. As COI (Cause of initialization), 2 (remote reset) is used.

9.2.4 Transfer of the value changes

The IEC870 slave receives, from zenon Runtime, all value changes of the requested variables. Because, as a result of this, the list of process information that has not yet been transferred to the master can become very large, the list of outstanding value changes is limited.

Limit: at least 2048 values or 4 x number of IOs per sector.

If a master receives the values more slowly than they are generated in the process control system, the list can exceed this maximum. The slave can then no longer buffer the value changes that have not yet been transferred. The slave therefore terminates the connection to the master. The master is thus requested to obtain the next connection with a general query, so that it gets current, only recent variable values.



Attention

The Master must be able to recognize a communication interrupt, so he can react with a new general request. This is why no process commands will be executed until the Master has caused a reset.

Every time there is a chance of data loss (value changes were lost), a reset will be triggered.

9.2.5 Reload

If one of the projects is reloaded in the zenon Runtime, the connection to all projects using the IOs in the sector will be closed. The device (`Device`) with the according sector (`COA`) must be reset. That means: The connection to the master is closed.

While the reload is active, you cannot establish a connection to the Runtime. This means that general requests are also not possible.

9.2.6 Data priorities

The driver supports class 1 and class 2 files.

Spontaneous communication, **background scan** and **periodic data transfer** belong to class 1.

The whole file transfer is treated as class 2. This makes sure that value changes will be transferred to the Master even during a file transfer.

9.2.7 Internal type T00 (status variable)

The internal type `T00` is used for communication between the Slave and the process control system.

For the status variables, each numeric zenon variable can be assigned, for example internal drivers.

IOA 1

The variable provides the status information as to whether there is already a connection to the master. Create an IO of type `T00` with `IOA 1`. If a connection is established, the value will change from 0 to 1.

IOA 2

A decision as to whether commands are carried out in control direction can be made for each sector by means of a zenon variable for each sector. For rejected commands, a master receives `COT_actcon (7) + PN` as confirmation. Rejected commands create a warning in the log.

The zenon variable must be of `UINT` or `DWORD` type and is assigned with `T00` at `IOA`. If the value of the variable is = 1, the commands are approved. The variable must not have the status **INVALID**. The commands are always approved if no IO is configured.

This setting can be set globally using the **Commands active** (A pagina: 92) property.

The enhanced meaning of the `IOA 2` variable:

Value	Description
0	Commands are rejected; sets PN bit
1	Commands are approved
2	Silent mode: accept without execution or error message
3....	Reserved for future versions



Info

Attendant warning message:

Commands for sector deactivated, execution prohibited. <Command text>

Warning: 1009 command in control direction was received, but rejected due to a missing enable.

IOA 3

Status variable is set to 1 if the number of SOE files in the transfer directory exceeds the maximum number of buffered files.

IOA 4

Variable provides status information on the current or most recently processed SOE file:

- 0 - initialization. As long as no SOE file was written.
- 1 - SOE file is opened
- 2 - file was closed
- 3 - too many SOE files in the directory
- 4 - error when writing the SOE file
- 5 - errors when creating the SOE file

IOA 5

Variable provides status information by means of file transfer in `Monitoring Direction` ("Standard Direction" - from the master to the slave).

- 0 - no transfer active
- 1 - section is selected
- 2 - section is requested
- 3 - waiting on section confirmation
- 4 - waiting on confirmation of file transfer
- 255 - error when transferring

IOA 6

Variable provides the number of SOE files present in the transfer directory.

IOA 7

Variable provides status information by means of file transfer in `Control Direction` ("Reverse Direction" - from the slave to the master).

The information is integrated in a `DWORD` as follows: [IOA of the transferred files] * 256 + [status information].

Possible status information:

- 1 = transfer is ongoing

2 - Transfer is ongoing - the transfer that had not been completed beforehand is terminated by the transfer that has currently been started.

Status 3 is also written for the transfer that has been terminated. However because the new status is immediately written afterwards, it cannot be guaranteed in the case of zenon that this is visible in Runtime.

3 - Transfer was terminated due to an error.

4 - File transfer was completed and file is available.

9.2.8 Time synchronization

In order for time synchronization to be carried out - on receipt of `C_CS_NA_1`, there must be, at any desired `Device/Sektor` a type `T103` IO connected to a process variable. The first IO that uses type `T103` is used as an enable.

This variable must have a value of $\neq 0$ and must not have any of the following status bits set:

- ▶ INVALID (Bit 18)
- ▶ OFF (Bit 20)
- ▶ ALT_VAL (Bit 27)
- ▶ BL_870 (Bit 44)

Non execution of the command due to a missing enable (value 0 or status) does not lead to the connection being terminated, the command is only confirmed negatively - `COT_actcon + PN`.

If the `Enable` variable has not been configured or the value for this variable is missing, the connection is disconnected if a `C_Cs_NA_1` is received.

The missing configuration of the enable variable or the missing value of the enable variable leads to the connection being lost when the `C_CS_NA_1` command is received.

9.2.9 Broadcasts

Global address `0xFF(FF)` in the `Common Address of ASDU (COA)` is supported for the following `Typ IDs`:

- ▶ `C_IC_NA_1` - General query - `ASDU<100>`
- ▶ `C_CS_NA_1` - Time synchronization - `ASDU<103>`

No additional project configuration steps are necessary for this.



Attenzione

For Data Link Layer, the Broadcast Address 0xFF(FF) - "all outstations" is not supported in 60870-4-101 communication.

The Broadcast Address 0xFF(FF) - "all outstations" - in Data Link Layer in 60870-4-101 communication is not supported.

9.2.10 Mapping of status bits in message direction

The IEC870 slave supports the sending of quality bits for the information objects. The quality bits of the IO are set - in ASDUs in 'monitor direction' - using certain status bits of the linked zenon variable.

The quality bits are assigned to the status bits of the variables as follows:

Status bit in zenon	IEC60870 quality descriptor bits	Notes
INVALID	IV (invalid) NT (not topical)	The slave forwards the <code>INVALID</code> status bit in message direction as two quality bits.
OFF	IV (invalid)	
OV_870	OV (overflow)	OV_870 status bits that already have the variables in zenon are sent to the master. If values for Normalized Values (<code>T09</code>) go below or exceed the norm range $<-1 \dots 1-2^{-15}>$, the OV quality bit is set, even if the variable does not have the status bit in zenon.
BL_870	BL (blocked)	
SB_870	SB (substituted)	
ALT_VAL	SB (substituted)	Up to zenon version 7.10, it is mapped the same as the <code>OFF</code> bit.
NT_870	NT (not topical)	
T_INVALID (time invalid)	Only in "Binary Time 2a" (<code>CP24Time2a</code> / <code>CP56Time2a</code>) BS[24]- IV (invalid)	The slave forwards the <code>T_INVALID</code> status bit in the time stamp of the IOs with "time tag" only.

9.2.11 Commands

A command received - `T45..T64` - is set as the value for the zenon variables. In sectors without `Select routing`, a confirmation, which is always positive, is always sent to the master immediately - `COT_actcon` (7) and `COT_actterm` (10).

In such sectors, a `Select` is also immediately also confirmed automatically - `COT_actcon` + `SE` and the zenon variable change neither the value nor the status bit.

Note: For variables that are configured in the IEC870SI Process Gateway as command variables, if the **Write set value via VBA** property is active (**Logging in** group), each command is logged as a **write set value** via the API interface in the **CEL**.

Select routing

`Select routing` can only be used together with **Command Processing module - auto/remote actions**.

If `Select routing` was configured for the sector being addressed, there is a wait in receipt of a `Select` until, via the command variable of zenon, the status `SE_870` is acknowledged with `COT_actcon` (7) and possibly with `N_CONF` (corresponds to `PN`).

Only once this has happened is a confirmation to the master (for example a Control Center) triggered. All others for this IO are rejected as long as a selection is taking place.

TIMEOUT, CANCEL AND MISSING SELECT

The following rules apply for the different possibilities for responding to a `Select routing` :

- ▶ If `Select routing` is configured on a sector, one `Select Timeout` per IO is started for each `Select`.
- ▶ The slave checks whether the `Timeout` has expired and then sets the variable to `SE`, `COT_actterm` (10) and `PN`.
- ▶ If a `Cancel` - `COT_deact` (8) is received by the master for an ongoing `Select`, confirmation is provided with `COT_deactcon` (9) and the `Select` is deleted.
- ▶ If an `Execute` or `Cancel` is received without a `Select` beforehand, it is responded to with `PN` - negative.

Pulse generation - 'Qualifier of Command'

The IEC870 slave supports pulse generation for commands received. The Qualifier of Command (QoC) is supported for all commands envisaged in the IEC60870 standard (T45, T46, T47 and T58, T59, T60).

For example, an pulse command received - an ASDU of type T45 - with QoC has the following effect on a zenon variable:

- ▶ **QoC 0:** Undefined in accordance with IEC standard. Behaves in slave as in QoC 3 persistent output.
- ▶ **QoC 1:** Short pulse. The zenon variable assumes the value 'ON' and changes, after the time defined in the Process Gateway settings (A pagina: 92) to 'OFF'.
- ▶ **QoC 2:** Long pulse. The zenon variable assumes the value 'ON' and changes, after the time defined in the Process Gateway settings (A pagina: 92) to 'OFF'.
- ▶ **QoC 3:** Persistent output. The zenon variable assumes the value 'ON' (or 'OFF') and retains the value. This must be reset to receive further commands.

As soon as communication is ended, the pulse for all other active pulse variables will be stopped (i.e. an OFF will be written). If a pulse is triggered for a running pulse generation, the active pulse generation will be stopped. The variable contains the value 'OFF'.

Note: For SCS (single command state), the value 'OFF' is always 0, for DCS (double command state) an 'OFF' is 00b at protocol level, then 2 or 0 in zenon, depending on the "DPI/DCS mapping" setting.

Note: In sectors with `Select routing`, pulse generation cannot be carried out because 'OFF' after `Select` is in conflict with `Execute`.

9.2.12 File transfer

The following applies for file transfer:

- ▶ The values 1-4 are supported in the AFQ UI4
- ▶ The values 0-6 are supported in the SCQ UI4;
0 and 1 are both 'select file'

If a new transfer is started while another one is still active, the currently active transfer will be interrupted and the new one will be started.

Storage and naming

Use the following scheme for storage and naming:

<Configured folder>\<COA>\<IOA>.<NOF>

Only 1 = 'Name of file' is supported as NOF (transparent file).
The maximum size of files for transfer is 16.711.680 Bytes.

EXAMPLE

Folder in the module configuration (A pagina: 92): C:\TEMP\IEC870

File 1100.1: for IO of sector **COA=151** and **IOA 1100**

Save location: C:\TEMP\IEC870\151\1100.1

Spontaneous directory transfer

Spontaneous transfer of files in the folder for file transfer can be triggered by the process control system. To do this:


- create an IO of type F_DR_NA_1 (T126) with IOA '0'.

Value	Meaning
Change from 1 to 2	Starting transfer
3	Transfer active
4	Transfer finished
5	Transfer failure

Nested activation is prevented.

9.2.13 Sequence of Events (SOE)

SETTINGS IN THE MAIN SOE WINDOW:



Parameter	Description
Use sequences of events	If active, the SOE for the selected device is activated. If inactive, all SOE settings to the IOs are ignored. Default: inactive

FILE SETTINGS PER SECTOR

Parameter	Description
Buffered SOE Files	If the number set for SOE files in the folder is reached for the sector, a spontaneous directory transfer (type ID "F_DT_TA_1") is triggered. If the number of files in the folder is doubled, the oldest file will start to be deleted (ring buffer function). Value range 1 to 1024. Default: 1024
Events per File	Number of value changes that are written in a file before it is closed. Value range: 1 to 4096. Default: 512
Automatically delete SOE file	If active, the reaction is that this is then automatically closed for type ID "F_AF_NA_1" (confirmation for file) for an SOE file.

TIMEOUTS

Parameter	Description
Post trigger timeout	<p>If no ASDU is written to the file within this period of time, this is then closed. The time period starts over with each ASDU written.</p> <p>Value range: 100ms to 120000ms</p> <p>Default: 1000ms</p>
File timeout	<p>Maximum time for which the file remains open (regardless of the number of events).</p> <p>Value range: 100ms to 120000ms</p> <p>Default: 5000ms</p>

FIRST VALUE

The exchange of data for SOE starts immediately once the Gateway has been initialized. The exchange of data for data in monitoring direction only starts when a master has connected and triggered a general interrogation (GI). The first value that is initialized does not trigger an event and is thus also not entered into the file. The same applies if Runtime is ready again to exchange data after reloading.

FILE TRANSFER

As part of the SOE function for transparent (1), event (3) is also supported as NOF.

Files are not transferred automatically if the maximum number of SOE files to be buffered is exceeded.

The IEC 60870 norm describes this with "may be activated". The Gateway does not support any file transfers activated by the Slave in the current version.

DIRECTORY TRANSFER

As part of the SOE function for transparent (1), event (3) is also supported as NOF.

Automatic directory transfer:

In accordance with the IEC 60870 norm, an automatic spontaneous directory transfer is activated for the following reasons with existing SOE files:

- ▶ 24 hours after the last automatic directory transfer.
- ▶ if the master connects
- ▶ if the maximum number of files to be buffered is exceeded

Warnings

Warning message	Meaning
Sequences of events for device <Devicename> sector <Sectorname> are activated but no trigger defined	The device has SOE activated, on the server there is an IO with SOE active but the trigger was not activated for any IO. No file is created without a trigger. At least one IO must have the trigger activated for the sector.
SOE value change without trigger and file is closed. Value lost! Device:(<Device ID>)<Device-Name> Sector:(<COA>)<Sector name> <Value information>	A value change was not written because the SOE file is not open. Code:1010

Error message

Error message	Meaning
Sequence of events active but no directory for the file transfer defined!	SOE files are archived in the file transfer folder. Therefore a folder for file transfer must be present.
SOE values lost, queue full! Device:(<Device ID>)<Device-Name> Sector:(<COA>)<Sector name> <Value information>	for IOs that have a SOE activated, data is exchanged to the stack via a queue. This can assume a value of 2048 or 4 * the number of SOE IO's in sector entries. If this number is exceeded, this error message is created and the value change is lost. Error code: 6
Can't create subdirectory for file transfer. Device:(<Device ID>)<Device name> Sector:(<COA>)<Sector name> system error:<System error code>	The subfolder for the sector is automatically created for SOE in the folder for file transfers. This error shows that this folder could not be created. SOE then indicates that this sector is NOT available. Error code: 10
System error code	Contains the error code returned from the operating system.
Can't advise SOE data point. Device:(<Device ID>)<Device name> Sector:(<COA>)<Sector name> adv:0x<Advise ID>	Data point request for SOE IOs failed. SOE then indicates that this sector is NOT available. Error code: 11
Write asdu to file <Filename> fail! Device:(<Device ID>)<Device name> Sector:(<COA>)<Sector name> <Value> system error: <System error code>	ASDU write to SOE file failed. Error code: 8
Illegal file name <Filename> detected! Device:(<Device ID>)<Device name> Sector:(<COA>)<Sector name>	Filenames for the file transfer have a defined format <IOA>.<NOF>. The file does not adhere to this convention. Error code: 12
Auto delete for file failed! System error: <System error code> <File transfer information>	Error code: 9
File transfer information	Contains the information that identifies the file transfer.

LOG entries

The sequence of events writes the following entries to the LOG file

Parameter	Description
deviceIp:	IP address from the device

devicename:	Name of device
COA:	Care of Address -> according to standard
SecName:	Sector description
TypeyId:	Command number
TypeIdAsTxt:	Command as text
IOA:	According to standard
AdviseID:	ID via which value changes are requested and assigned
Value:	Value transferred
TimeStamp:	Time of value change. From the driver or command
QUALDESC:	According to standard
SBEValue:	COT, select and pn mapped to unique enums: 0 : Not select relevant 1 : actcon+pn+select 2 : actcon+select 3 : deactcon+pn+select, 4 : deactcon+select 5 : actterm+pn+select, 6 : actterm+select,
Confirmed:	1 if select already confirmed
COT:	According to standard
CotTxt:	Cot asText
Qualifier:	According to standard and command
Originator:	According to standard
QU:	Qualifier of command QU 7.2.6.26
DCS:	7.2.6.16 Double command (IEV 371-03-03)
ControlCommand:	Depending on control command

EXAMPLE FOR 45:

```
<TypeId> <TypeIdAsTxt> Device:(<deviceip>)<devicename> Sector:(<IOA>)< SecName >
ioa:<IOA> cot:(<COT>)<CotTxt> ori:<Originator> sel:<QOC S/E> qu:<QU> dcs:<DCS>
ValueChange cmd(<TypepeyId>)<<TypeId>> <TypeIdAsTxt> ioa:<IOA> id:<AdviseID> value:<Wert>
time:<TimeStamp> state:< QUALDESC > sir:<SBEValue>
```

LOG entry	Module/Level	Description
SBE IED processing. Device: (<deviceIp>)<device name> Sector: (<COA>)<SecName> <ValueChange> SBE command: advise:<AdviseID> conf:<confirmed> <ControlCommand>	OSI7/Debug	Each value change that is processed for SBE creates this log message
Wrn:1014 SBE activation already confirmed! Device: (<DeviceIp>)<device name> Sector: (<COA>)<SecName> <ValueChange>	OSI7/Warning	Renewed conformation for Select received and ignored
Error:16 Advise for SBE data point fail. SBE command: advise:<AdviseId> conf:<confirmed> <ControlCommand>	Scada/error	Variable could not be requested.
Error:17 SBE value lost, queue full! Device: (<DeviceIp>)<device name> Sector: (<COA>)<SecName> <ValueChange>	Scada/Error	Value change for SBE lost because the source is full.

9.2.14 Read - T102 - request

Maximum 2048 read requests - C_RD_NA_1 - can be active at the same time. Once this limit has been reached, further read requests are rejected.

A read request is executed for each IO with the requested IOA .

Several requests for one IO can be active at the same time.

Read requests will be processed even if the general request is not finished yet.

The response to the read command does not need to be configured and automatically runs in the background.

9.2.15 Test - T104 and T107 - requests

The IEC870 slave responds to the master automatically with the two test commands C_TS_NA_1 (ASDU<104>) and C_TS_TA_1 (ASDU<107>).

This response does not need to be engineered and runs in the background.



Info

You can find further information on command IDs the Interoperability (A pagina: 145) chapter.

9.3 Error analysis

Should there be communication problems, this chapter will assist you in finding out the error.

9.3.1 Analysis tool

Process Gateway behaves like a zenon driver and writes messages to a common log file. To display them correctly and clearly, use the Diagnosis Viewer (main.chm::/12464.htm) program that was also installed with zenon. You can find it under *Start/All programs/zenon/Tools 7.60 -> Diagviewer*. In general, the following applies:

zenon driver log all errors in the LOG files. I file LOG sono file di testo con una struttura speciale: La cartella standard per i file Log è la sottocartella **LOG** della directory **ProgramData**, per es.:

%ProgramData%\COPA-DATA\LOG.

Attention: With the default settings, a driver only logs error information. With the Diagnosis Viewer you can enhance the diagnosis level for most of the drivers to "Debug" and "Deep Debug". With this the driver also logs all other important tasks and events.

Nel Diagnosis Viewer si può anche:

- ▶ Seguire nuovi inserimenti in tempo reale
- ▶ Individualizzare le impostazioni di registrazione
- ▶ Modificare la cartella in cui vengono salvati i file LOG

Note:

1. The Diagnosis Viewer displays all entries in UTC (coordinated world time) and not in local time.

2. The Diagnosis Viewer does not display all columns of a LOG file per default. To display more columns activate property **Add all columns with entry** in the context menu of the column header.
3. If you only use **Error-Logging**, the problem description is in the column **Error text**. For other diagnosis level the description is in the column **General text**.
4. For communication problems many drivers also log error numbers which the PLC assigns to them. They are displayed in **Error text** or **Error code** or **Driver error parameter (1 and 2)**. Hints on the meaning of error codes can be found in the driver documentation and the protocol/PLC description.
5. At the end of your test set back the diagnosis level from **Debug** or **Deep Debug**. At **Debug** and **Deep Debug** there are a great deal of data for logging which are saved to the hard drive and which can influence your system performance. They are still logged even after you close the Diagnosis Viewer.



Attenzione

In Windows CE errors are not logged per default due to performance reasons.

Note: Process Gateway is not available under Windows CE.



Info

You can find further information on the Diagnosis Viewer in the Diagnosis Viewer (main.chm::/12464.htm) chapter.

Logging

The driver supports a comprehensive logging function for:

- ▶ Client name
- ▶ zenProcGateway_IEC870Slave
- ▶ Modules

CLIENT NAME

The way the name of the client is displayed in the Diagnosis Viewer depends on the configuration. That is why the name changes if you change the TCP port, the COM port or the protocol. In this case, the logging settings may also change.

If the Process Gateway is started several times with the same settings, the same client name will be used. The error messages of the different instances can be distinguished by the process ID.



Esempio

zenProcGateway_IEC870Slave

- ▶ 104 protocol with standard port 2404
- ▶ 101 if COM1 selected.
- ▶ If the configuration has not been loaded yet, error messages during startup will always be visible under this client.

zenProcGateway_IEC870Slave:COM4

- ▶ 101 with COM4.
The name contains the used COM port.

zenProcGateway_IEC870Slave:Port:12345

- ▶ 104 with port 12345.
The name contains the port for the Master connection.

MODULES

Error messages are shown for all modules:

- ▶ IEC870 Slave
- ▶ OSI2
- ▶ OSI7
- ▶ SCADA Runtime (ScadaRT)

IEC870 SLAVE

Concerns the connection to the Process Gateway and its configuration.

Information about:

- ▶ Errors during engineering

OSI2

Concerns the protocol level. This where framing with its according functions is implemented.

Information about:

- ▶ Received data as byte dump
- ▶ Sent data as byte dump
- ▶ Function codes for 101

- ▶ Errors on this level, e.g. in the framing
- ▶ APCI for 104 (870-5-104 5)

Levels

- ▶ Msg: Frame interpreting
- ▶ Debug:
Received and sent data
Frame analysis.
New Master connection.
- ▶ Deep Debug: Every request about existence of characters. Produces a large number of logging entries!

OS17

Concerns the application layer.

This is where commands are interpreted and executed.

Information about:

- ▶ Logging 'process and system information'
- ▶ Errors in the ASDUs

Levels:

- ▶ Warning: Recursive interrogation
- ▶ Msg: Process information, System information
- ▶ Debug: Confirmed I-frames
- ▶ Deep Debug: Interrogation runs. Produces a large number of logging entries!

SCADA RUNTIME (SCADART)

Messages for connection to the Runtime:

Information about:

- ▶ advised and unadvised variables
- ▶ updated variables
- ▶ Deactivating the project

Levels

- ▶ Debug:
changed values
project inactive

9.3.2 Error codes

The following error codes can be displayed in the Diagnosis Viewer:

Error code	Meaning
570	Value change for unknown cyclical IO
571	Transfer buffer too small to transfer a cyclical IO

ERROR MESSAGES FOR FILE TRANSFER IN REVERSE DIRECTION

Error number	Error level	Description
20	Error message	Creation of the temporary file for the file transfer in reverse direction was unsuccessful.
1017	Warning	File transfer in reverse direction is already active, the ongoing one will be ended and a new one started.
21	Error message	Segment data write error occurred
22	Error message	Length of the data exceeds the expected file length
23	Error message	Checksum of the transferred segments incorrect for the sector.
24	Error message	Checksum for file incorrect.
25	Error message	Segment data transferred for sector exceeds the data length defined at the start
26	Error message	Sector data transfer is reported as finished but the amount of segment data transferred does not correspond to that stated at the start.
27	Error message	File data is reported as completed but the given file length does not correspond.
581	Error message	Unexpected IOA with SG
582	Error message	Unexpected NOF with SG
583	Error message	Unexpected NOS with SG
584	Error message	Unexpected NOS with LS
585	Error message	Unexpected NOS with LS
586	Error message	Unexpected NOS with LS
587	Error message	FR with non-supported NOF. We only support 1 == transparent

9.3.3 Check list

- ▶ Is the COM port in use by another application or are the settings incorrect?
- ▶ Is the device (PLC) that you are trying to communicate with connected to the power supply?

- ▶ Is the cable between PLC and PC/IPC connected correctly?
- ▶ Have you analyzed the error file (which errors did occur)?
- ▶ For additional error analyses, please send a project backup and the LOG file of the DiagViewer to the support team responsible for you.

9.4 Interoperability

This companion standard presents sets of parameters and alternatives from which subsets must be selected to implement particular telecontrol systems. Certain parameter values, such as the choice of 'structured' or 'unstructured' fields of the information object address of ASDUs represent mutually exclusive alternatives. This means that only one value of the defined parameters is admitted per system. Other parameters, such as the listed set of different process information in command and in monitor direction allow the specification of the complete set or subsets, as appropriate for given applications. This clause summarizes the parameters of the previous clauses to facilitate a suitable selection for a specific application. If a system is composed of equipment stemming from different manufacturers, it is necessary that all partners agree on the selected parameters.

The interoperability list is defined as in IEC 60870-5-101 and extended with parameters used in this standard. The text descriptions of parameters which are not applicable to this companion standard are strike-through (corresponding check box is marked black).

NOTE In addition, the full specification of a system may require individual selection of certain parameters for certain parts of the system, such as the individual selection of scaling factors for individually addressable measured values.

The selected parameters should be marked in the white boxes as follows:

- [] Function or ASDU is not used
- [X] Function or ASDU is used as standardized (default)
- [R] Function or ASDU is used in reverse mode
- [B] Function or ASDU is used in standard and reverse mode

The possible selection (blank, X, R, or B) is specified for each specific clause or parameter.

A black check box indicates that the option cannot be selected in this companion standard.

1. SYSTEM OR DEVICE

(system-specific parameter, indicate definition of a system or a device by marking one of the following with 'X')

- [] System definition
- [] Controlling station definition (Master)
- [X] Controlled station definition (Slave)

2. NETWORK CONFIGURATION: 101 ONLY

(network-specific parameter, all configurations that are used are to be marked 'x')

[x] Point-to-point	[x] Multipoint
[x] Multiple point to point	[] Multipoint-star

3. PHYSICAL LAYER: 101 ONLY

(network-specific parameter, all interfaces and data rates that are used are to be marked 'x')

TRANSMISSION SPEED (CONTROL DIRECTION)

Unbalanced interchange Circuit V.24/V.28 Standard	Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200 bit/s	Balanced interchange Circuit X.24/X.27
[] 100 bit/s	[x] 2400 bit/s	[] 2400 bit/s
[] 200 bit/s	[x] 4800 bit/s	[] 4800 bit/s
[x] 300 bit/s	[x] 9600 bit/s	[] 9600 bit/s
[x] 600 bit/s	[x] 19200 bit/s	[] 19200 bit/s
[x] 1200 bit/s	[x] 38400 bit/s	[] 38400 bit/s
	[x] 56000 bit/s	[] 56000 bit/s
	[x] 57600 bit/s	[] 64000 bit/s
	[x] 115200 bit/s	
	[x] 128000 bit/s	
	[x] 256000 bit/s	

TRANSMISSION SPEED (MONITOR DIRECTION)

Unbalanced interchange Circuit V.24/V.28 Standard	Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200 bit/s	Balanced interchange Circuit X.24/X.27
[] 100 bit/s	[x] 2400 bit/s	[] 2400 bit/s
[] 200 bit/s	[x] 4800 bit/s	[] 4800 bit/s
[x] 300 bit/s	[x] 9600 bit/s	[] 9600 bit/s
[x] 600 bit/s	[x] 19200 bit/s	[] 19200 bit/s
[x] 1200 bit/s	[x] 38400 bit/s	[] 38400 bit/s
	[x] 56000 bit/s	[] 56000 bit/s

	[X] 57600 bit/s	[] 64000 bit/s
	[X] 115200 bit/s	
	[X] 128000 bit/s	
	[X] 256000 bit/s	

4. LINK LAYER: 101 ONLY

(network-specific parameter, all options that are used are to be marked ' X '. Specify the maximum frame length. If a non-standard assignment of class 2 messages is implemented for unbalanced transmission, indicate the Type ID and COT of all messages assigned to class 2.)

Frame format FT 1.2, single character 1 and the fixed time out interval are used exclusively in this companion standard.

Link transmission	Frame length [octets]	Address field of the link
[] Balanced transmission	[255] Maximum length L (both directions)*	[] not present (balanced transmission only)
[X] Unbalanced transmission		[X] One octet
		[X] Two octets
		[X] Structured
		[X] Unstructured

*may be reduced by the system

Link Address 0xFF(FF) - broadcast to all outstations - is not supported.

The structure of Link Address is not interpreted.

When using an unbalanced link layer, the following ASDU types are returned in class 2 messages (low priority) with the indicated causes of transmission:

[] The standard assignment of ASDUs to class 2 messages is used as follows:

Type identification	Cause of transmission
9, 11, 13, 21	<1>

[X] A special assignment of ASDUs to class 2 messages is used as follows:

Type identification	Cause of transmission
120 - 126	All (as specified in the standard)

Note: (In response to a class 2 poll, a controlled station may respond with class 1 data when there is no class 2 data available).

5. APPLICATION LAYER

TRANSMISSION MODE FOR APPLICATION DATA

Mode 1 (Least significant octet first), as defined in 4.10 of IEC 60870-5-4, is used exclusively in this companion standard.

COMMON ADDRESS OF ASDU

(system-specific parameter, all configurations that are used are to be marked 'x')

ASDU address	
101 only	[x] Two octets
[x] One octet	

The ASDU address 0xFF(FF) - global address - is supported only for C_IC_NA_1 and C_CS_NA_1

INFORMATION OBJECT ADDRESS

(system-specific parameter, all configurations that are used are to be marked 'x')

Object address	
101 only	[x] Structured
[x] One octet	
101 only	[x] Unstructured
[x] Two octets	
[x] Three octets	

CAUSE OF TRANSMISSION

(system-specific parameter, all configurations that are used are to be marked 'x')

Cause of transmission	
101 only	[x] Two octets (with originator address)
[x] One octet	Originator address is set to zero if not used.

LENGTH OF APDU: 104 ONLY

(system-specific parameter, specify the maximum length of the APDU per system)

The maximum length of APDU for both directions is 253. The maximum length may be reduced by the system.

[253] Maximum length of APDU per system

SELECTION OF STANDARD ASDUS**PROCESS INFORMATION IN MONITOR DIRECTION**

(station-specific parameter, mark each Type ID 'X' if it is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

Mark	Parameter	Type
[B]	<1>: = Single-point information	M_SP_NA_1
[B]	<2>: = Single-point information with time TAG	M_SP_TA_1
[B]	<3>: = Double-point information	M_DP_NA_1
[B]	<4>: = Double-point information with time TAG	M_DP_TA_1
[B]	<5>: = Step position information	M_ST_NA_1
[B]	<6>: = Step position information with time TAG	M_ST_TA_1
[B]	<7>: = Bitstring of 32 bit	M_BO_NA_1
[B]	<8>: = Bitstring of 32 bit with time TAG	M_BO_TA_1
[B]	<9>: = Measured value, normalized value	M_ME_NA_1
[B]	<10>: = Measured value, normalized value with time TAG	M_ME_TA_1
[B]	<11>: = Measured value, scaled value	M_ME_NB_1
[B]	<12>: = Measured value, scaled value with time TAG	M_ME_TB_1
[B]	<13>: = Measured value, short floating point value	M_ME_NC_1
[B]	<14>: = Measured value, short floating point value with time TAG	M_ME_TC_1
[B]	<15>: = Integrated totals	M_IT_NA_1
[B]	<16>: = Integrated totals with time TAG	M_IT_TA_1
[]	<17>: = Event of protection equipment with time TAG	M_EP_TA_1
[]	<18>: = Packed start events of protection equipment with time TAG	M_EP_TB_1
[]	<19>: = Packed output circuit information of protection equipment with time TAG	M_EP_TC_1
[]	<20>: = Packed single-point information with status change detection	M_SP_NA_1
[]	<21>: = Measured value, normalized value without quality descriptor	M_ME_ND_1
[B]	<30>: = Single-point information with time TAG CP56Time2a	M_SP_TB_1
[B]	<31>: = Double-point information with time TAG CP56Time2a	M_DP_TB_1
[B]	<32>: = Step position information with time TAG CP56Time2a	M_ST_TB_1
[B]	<33>: = Bitstring of 32 bit with time TAG CP56Time2a	M_BO_TB_1
[B]	<34>: = Measured value, normalized value with time TAG CP56Time2a	M_ME_TD_1
[B]	<35>: = Measured value, scaled value with time TAG CP56Time2a	M_ME_TE_1
[B]	<36>: = Measured value, short floating point value with time TAG CP56Time2a	M_ME_TF_1
[B]	<37>: = Integrated totals with time TAG CP56Time2a	M_IT_TB_1
[]	<38>: = Event of protection equipment with time TAG CP56Time2a	M_EP_TD_1
[]	<39>: = Packed start events of protection equipment with time TAG CP56Time2a	M_EP_TE_1

[]	<40>:= Packed output circuit information of protection equipment with time TAG CP56Time2a	M_EP_TF_1
--------	---	-----------

Either the ASDUs of the set <2>, <4>, <6>, <8>, <10>, <12>, <14>, <16>, <17>, <18>, <19> or of the set <30> – <40> are used.

PROCESS INFORMATION IN CONTROL DIRECTION

(station-specific parameter, mark each Type ID ' X ' if it is only used in the standard direction, ' R ' if only used in the reverse direction, and ' B ' if used in both directions).

Mark	Parameter	Type
[X]	<45>:= Single command	C_SC_NA_1
[X]	<46>:= Double command	C_DC_NA_1
[X]	<47>:= Regulating step command	C_RC_NA_1
[X]	<48>:= Set point command, normalized value	C_SE_NA_1
[X]	<49>:= Set point command, scaled value	C_SE_NB_1
[X]	<50>:= Set point command, short floating point value	C_SE_NC_1
[X]	<51>:= Bitstring of 32 bit	C_BO_NA_1
[X]	<58>:= Single command with time TAG CP56Time2a	C_SC_TA_1
[X]	<59>:= Double command with time TAG CP56Time2a	C_DC_TA_1
[X]	<60>:= Regulating step command with time TAG CP56Time2a	C_RC_TA_1
[X]	<61>:= Set point command, normalized value with time TAG CP56Time2a	C_SE_TA_1
[X]	<62>:= Set point command, scaled value with time TAG CP56Time2a	C_SE_TB_1
[X]	<63>:= Set point command, short floating point value with time TAG CP56Time2a	C_SE_TC_1
[X]	<64>:= Bitstring of 32 bit with time TAG CP56Time2a	C_BO_TA_1

Either the ASDUs of the set <45> – <51> or of the set <58> – <64> are used.

SYSTEM INFORMATION IN MONITOR DIRECTION

(station-specific parameter, mark ' X ' if used)

Mark	Parameter	Type
[X]	<70> := End of initialization	M_EI_NA_1

SYSTEM INFORMATION IN CONTROL DIRECTION

(station-specific parameter, mark each Type ID ' X ' if it is only used in the standard direction, ' R ' if only used in the reverse direction, and ' B ' if used in both directions).

Mark	Parameter	Type
[X]	<100>:= Interrogation command*	C_IC_NA_1
[X]	<101>:= Counter interrogation command	C_CI_NA_1
[X]	<102>:= Read command	C_RD_NA_1
[X]	<103>:= Clock synchronization command (option see 7.6)*	C_CS_NA_1
[X]	<104>:= Test command	C_TS_NA_1
[X]	<105>:= Reset process command	C_RP_NA_1
[]	<106>:= Delay acquisition command	C_CD_NA_1
[X]	<107>:= Test command with time TAG CP56Time2a	C_TS_TA_1

*also with global address - with Common Address of ASDU = 0xFF(FF)

PARAMETER IN CONTROL DIRECTION

(station-specific parameter, mark each Type ID ' X ' if it is only used in the standard direction, ' R ' if only used in the reverse direction, and ' B ' if used in both directions).

Mark	Parameter	Type
[]	<110>:= Parameter of measured value, normalized value	P_ME_NA_1
[]	<111>:= Parameter of measured value, scaled value	P_ME_NB_1
[]	<112>:= Parameter of measured value, short floating point value	P_ME_NC_1
[]	<113>:= Parameter activation	P_AC_NA_1

FILE TRANSFER

(station-specific parameter, mark each Type ID ' X ' if it is only used in the standard direction, ' R ' if only used in the reverse direction, and ' B ' if used in both directions).

Mark	Parameter	Type
[B]	<120>: = File ready	F_FR_NA_1
[B]	<121>: = Section ready	F_SR_NA_1
[B]	<122>: = Call directory, select file, call file, call section	F_SC_NA_1
[B]	<123>: = Last section, last segment	F_LS_NA_1
[B]	<124>: = Ack file, ack section	F_AF_NA_1
[B]	<125>: = Segment	F_SG_NA_1
[X]	<126>: = Directory {blank or X, only available in monitor (standard) direction}	F_DR_TA_1

TYPE IDENTIFIER AND CAUSE OF TRANSMISSION ASSIGNMENTS

(station-specific parameters)

Shaded boxes: option not required.

Blank: functions or ASDU not used.

Mark Type Identification/Cause of transmission combinations:

'X' if only used in the standard direction;

'R' if only used in the reverse direction;

'B' if used in both directions.

154

Type identification		Cause of transmission																			
		1	2	3	4	5	6	7	8	9	10	11	12	13	20 to 36	37 to 41	44	45	46	47	
<38>	M_EP_TD_1																				
<39>	M_EP_TE_1																				
<40>	M_EP_TF_1																				
<45>	C_SC_NA_1						X	X	X²	X²	X								X	X	
<46>	C_DC_NA_1						X	X	X²	X²	X								X	X	
<47>	C_RC_NA_1						X	X	X²	X²	X								X	X	
<48>	C_SE_NA_1						X	X	X²	X²	X								X	X	
<49>	C_SE_NB_1						X	X	X²	X²	X								X	X	
<50>	C_SE_NC_1						X	X	X²	X²	X								X	X	
<51>	C_BO_NA_1						X	X	X²	X²	X								X	X	
<58>	C_SC_TA_1						X	X	X²	X²	X								X	X	
<59>	C_DC_TA_1						X	X	X²	X²	X								X	X	
<60>	C_RC_TA_1						X	X	X²	X²	X								X	X	
<61>	C_SE_TA_1						X	X	X²	X²	X								X	X	
<62>	C_SE_TB_1						X	X	X²	X²	X								X	X	
<63>	C_SE_TC_1						X	X	X²	X²	X								X	X	
<64>	C_BO_TA_1						X	X	X²	X²	X								X	X	
<70>	M_EI_NA_1*				X																
<100>	C_IC_NA_1						X	X	X	X	X								X		
<101>	C_CI_NA_1						X	X			X								X		
<102>	C_RD_NA_1					X												X	X	X	
<103>	C_CS_NA_1						X	X										X	X		
<104>	C_TS_NA_1						X	X													
<105>	C_RP_NA_1						X	X										X	X		
<106>	C_CD_NA_1																				
<107>	C_TS_TA_1						X	X													
<110>	P_ME_NA_1																				
<111>	P_ME_NB_1																				
<112>	P_ME_NC_1																				

Type identification		Cause of transmission																			
		1	2	3	4	5	6	7	8	9	10	11	12	13	20 to 36	37 to 41	44	45	46	47	
<113>	P_AC_NA_1																				
<120>	F_FR_NA_1													X					X		
<121>	F_SR_NA_1													X					X		
<122>	F_SC_NA_1					X								X				X	X		
<123>	F_LS_NA_1													X					X		
<124>	F_AF_NA_1													X				X	X		
<125>	F_SG_NA_1													X					X		
<126>	F_DR_TA_1*			X		X															

* Blank or X only

¹ Optional.

² Slave confirms deactivations of write command (TI <45> ... <64>) but by deactivated 'Select routing' the corresponding activation is already transferred to execution; COT_actcon and COT_actterm were already sent.

COT	Cause of Transmission	
<0>	not used	
<1>	periodic, cyclic	per/cyc
<2>	background scan	back
<3>	spontaneous	spont
<4>	initialized	init
<5>	request or requested	req
<6>	activation	act
<7>	activation confirmation	actcon
<8>	deactivation	deact
<9>	deactivation confirmation	deactcon
<10>	activation termination	actterm
<11>	return information caused by a remote command	retrem
<12>	return information caused by a local command	retloc
<13>	file transfer	file
<14...19>	reserved	
<20>	interrogated by station interrogation	inrogen
<21...36>	interrogated by interrogation of the group 1..16	inro1..16
<37>	requested by general counter request	reqcogen
<38...41>	requested by counter interrogation of the group 1 ... 4	reqco1..4
<42, 43>	reserved	
<44>	unknown type identification	
<45>	unknown cause of transmission	
<46>	unknown common address of ASDU	
<47>	unknown information object address	
<48, 63>	for special use (private range)	

6. BASIC APPLICATION FUNCTIONS

STATION INITIALIZATION

(station-specific parameter, mark 'X' if function is used)

[] Remote initialization

CYCLIC DATA TRANSMISSION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

[X] Cyclic data transmission

READ PROCEDURE

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

[X] Read procedure

SPONTANEOUS TRANSMISSION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions)

[B] Spontaneous transmission

DOUBLE TRANSMISSION OF INFORMATION OBJECTS WITH CAUSE OF TRANSMISSION SPONTANEOUS

(station-specific parameter, mark each information type 'X' where both a Type ID without time and corresponding Type ID with time are issued in response to a single spontaneous change of a monitored object)

The following type identifications may be transmitted in succession caused by a single status change of an information object. The particular information object addresses for which double transmission is enabled are defined in a project-specific list.

- [] Single-point information M_SP_NA_1, M_SP_TA_1, M_SP_TB_1 and M_PS_NA_1
- [] Double-point information M_DP_NA_1, M_DP_TA_1 and M_DP_TB_1
- [] Step position information M_ST_NA_1, M_ST_TA_1 and M_ST_TB_1
- [] Bitstring of 32 bit M_BO_NA_1, M_BO_TA_1 and M_BO_TB_1 (if defined for a specific project)
- [] Measured value, normalized value M_ME_NA_1, M_ME_TA_1, M_ME_ND_1 and M_ME_TD_1
- [] Measured value, scaled value M_ME_NB_1, M_ME_TB_1 and M_ME_TE_1
- [] Measured value, short floating point number M_ME_NC_1, M_ME_TC_1 and M_ME_TF_1

STATION INTERROGATION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

--	--	--

[X] global		
[] group 1	[] group 7	[] group 13
[] group 2	[] group 8	[] group 14
[] group 3	[] group 9	[] group 15
[] group 4	[] group 10	[] group 16
[] group 5	[] group 11	Information object addresses assigned to each group must be shown in a separate table.
[] group 6	[] group 12	

CLOCK SYNCHRONIZATION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

[X] Clock synchronization

[] Day of week used

[] RES1, GEN (time tag substituted/ not substituted) used

[B] SU-bit (summertime) used

optional, see 7.6

COMMAND TRANSMISSION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

[X] Direct command transmission

[X] Direct set point command transmission

[X] Select and execute command

[X] Select and execute set point command

[X] C_SE ACTTERM used

[X] No additional definition

[X] Short-pulse duration (duration determined by a system parameter in the outstation)

[X] Long-pulse duration (duration determined by a system parameter in the outstation)

[X] Persistent output

[setting] Supervision of maximum delay in command direction of commands and set point commands

[no limit] Maximum allowable delay of commands and set point commands

TRANSMISSION OF INTEGRATED TOTALS

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- ☒ Mode A: Local freeze with spontaneous transmission
- ☒ Mode B: Local freeze with counter interrogation
- ☒ Mode C: Freeze and transmit by counter-interrogation commands
- ☒ Mode D: Freeze by counter-interrogation command, frozen values reported spontaneously

- ☒ Counter read
- ☒ Counter freeze without reset
- ☐ Counter freeze with reset
- ☐ Counter reset

- ☒ General request counter
- ☐ Request counter group 1
- ☐ Request counter group 2
- ☐ Request counter group 3
- ☐ Request counter group 4

PARAMETER LOADING

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- ☐ Threshold value
- ☐ Smoothing factor
- ☐ Low limit for transmission of measured values
- ☐ High limit for transmission of measured values

PARAMETER ACTIVATION

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- ☐ Act/deact of persistent cyclic or periodic transmission of the addressed object

TEST PROCEDURE

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- ☒ Test procedure

FILE TRANSFER

(station-specific parameter, mark 'X' if function is used).

File transfer in monitor direction

- [X*] Transparent file
- [] Transmission of disturbance data of protection equipment
- [X] Transmission of sequences of events
- [] Transmission of sequences of recorded analogue values

* a data can be transparently transported by the system but not generated or evaluated. Maximum file size is 16711680 bytes.

File transfer in control direction

- [X] Transparent file

BACKGROUND SCAN

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- [X] Background scan

ACQUISITION OF TRANSMISSION DELAY

(station-specific parameter, mark 'X' if function is only used in the standard direction, 'R' if only used in the reverse direction, and 'B' if used in both directions).

- [] Acquisition of transmission delay

DEFINITION OF TIME OUTS: 104 ONLY

Parameter	Default value	Remarks	Selected value
t0	30 s	Time-out of connection establishment	setting
t1	15 s	Time-out of send or test APDUs	setting
t2	10 s	Time-out for acknowledges in case of no data messages; t2 < t1	setting
t3	20 s	Time-out for sending test frames in case of a long idle state; t3 > t1	setting

Recommended range for timeouts t0 - t2 : 1s to 255s, accuracy 1s

Recommended range for timeout t3 : 0s to 48hrs, accuracy 1s

Long timeouts for t3 may be needed in special cases where satellite links or dialup connections are used (e.g. to establish connection and collect values only once per day or week). For dialup connections it may be necessary to give up the connection supervision completely. This is achievable by setting the timeout t3 to zero.

MAXIMUM NUMBER OF OUTSTANDING I FORMAT APDUS K AND LATEST ACKNOWLEDGE APDUS (W): 104 ONLY

Parameter	Default value	Remarks	Selected value
k	12 APDUs	Maximum difference receive sequence number to send state variable	setting
w	8 APDUs	Latest acknowledge after receiving w I format APDUs	setting

Recommended range of values k: 1 to 32767 APDUs, accuracy 1 APDU

Recommended range of values w: 1 to 32767 APDUs, accuracy 1 APDU (Recommendation: w should not exceed two-thirds of k)

PORTNUMBER: 104 ONLY

Parameter	Default value	Remarks
Portnumber	2404	setting

REDUNDANT CONNECTIONS

[] Number N of redundancy group connections used

RFC 2200 SUITE

RFC 2200 is an official Internet Standard which describes the state of standardization of protocols used in the Internet as determined by the Internet Architecture Board (IAB). It offers a broad spectrum of actual standards used in the Internet. The suitable selection of documents from RFC 2200 defined in this standard for given projects has to be chosen by the user of this standard.

- [] Ethernet 802.3
- [] Serial X.21 interface
- [] Other selection from RFC 2200:

List of valid documents from RFC 2200

1.
2.
3.
4.
5.
6.
7. etc.


10. MODBUS Slave

Process Gateway for Modbus Slave supports:

- ▶ Function Code 3:
Read Multiple Registers
- ▶ Function Code 16:
Write Multiple Registers

10.1 Module configuration

Clicking on the Settings button in the start dialog for the Process Gateway opens the dialog for selecting the variables. The variables selected in this way are continuously synchronized in zenon or in the MODBUS system.



The 'Settings' dialog box is divided into two main sections: 'Variables' and 'MODBUS Connection'.

Variables Section:

- Available in Scada:** A list of projects including 'ENERGY' and 'BASISTUTORIAL'.
- Variable:** A list of variables such as 'EMS_Supply area 1_EMS_running', 'EMS_Supply area 1_adjusted_sup...', 'EMS_Supply area 1_current_avera...', 'EMS_Supply area 1_first_switching...', 'EMS_Supply area 1_forecast_aver...', 'EMS_Supply area 1_forecast_error...', 'EMS_Supply area 1_forecast_final...', 'EMS_Supply area 1_gross_actua...', 'EMS_Supply area 1_last_switching...', 'EMS_Supply area 1_net_actual_de...', 'EMS_Supply area 1_planned_switc...', and 'EMS_Supply area 1_prio_primary'.
- Exported into MODBUS:** A table showing the mapping of variables to MODBUS addresses.

Variable	Offset
EMS_Supply area 1_forecast_start_consumption	0
BASISTUTORIAL#Temperaturfühler	1
test	2

MODBUS Connection Section:

- Slave Address:** A text box containing the value '1'.
- Port:** A dropdown menu showing 'COM 1'.
- Stop bits:** A dropdown menu showing '1'.
- Parity:** A dropdown menu showing 'No'.
- Data bits:** A dropdown menu showing '8'.
- Baudrate:** A dropdown menu showing '9600'.
- TCP/IP:** A radio button option, currently unselected.
- Port:** A text box containing the value '502'.
- Timeout:** A text box containing the value '60' followed by a unit 's'.

At the bottom right of the dialog are 'OK' and 'Cancel' buttons.

VARIABLES

Parameter	Description
Variables	Selection of variables that are exported to MODBUS and synchronized with zenon.
Available in Scada	<p>Displays all variables available in zenon</p> <p>With multi-project administration, variables from active projects can be selected.</p> <ul style="list-style-type: none"> ▶ Projects: shows all available projects; the standard project is marker with a * ▶ Variables: offers all variables from the selected project to be transferred
Exported into MODBUS	<p>Lists all variables exported to MODBUS and their offset. List can be sorted by clicking on headings.</p> <ul style="list-style-type: none"> ▶ Variables: List of all SCADA variables that are exported to the MODBUS. Variables that do not come from the standard project receive the project name as a prefix, separated by a # in front of the variable name. ▶ Offset: Offset of the variable (MODBUS holding register offset)
Pfeiltasten	<p>Allocation of the variables to MODBUS:</p> <ul style="list-style-type: none"> ▶ Clicking on the ► button adds variables from the Available in Scada list to the Exported into MODBUS list. A dialog to allocate the address is opened (see Allocation dialog section). ▶ Clicking on the ◀ button removes variables from the Exported into MODBUS list and inserts them back into the Available in Scada list.

MODBUS CONNECTION

MODBUS Connection	MODBUS connection settings.
--------------------------	-----------------------------


Slave Address	Modbus hardware address. Default: 1
Serial	<p>Active: Serial connection is used.</p> <ul style="list-style-type: none"> ▶ Port: Serial interface that is used for access to the MODBUS system. ▶ Stop bits: number of stop bits. Default: 1 ▶ Parity: Parity setting: No (default) Odd Even ▶ Data bit: number of data bits. Default: 8 ▶ Baud rate: baud rate of the serial interface. Default: 9600
TCP/IP	<p>Active: TCP/IP connection is used.</p> <ul style="list-style-type: none"> ▶ Port: Port address for the connection. ▶ Timeout: Waiting period.
OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.

Note:

- ▶ Change of name of project or variables in the Editor:
If a project name or a variable name is changed in the Editor, this change must subsequently be carried out in the configuration file (A pagina: 167), so that the name in the INI file and in the prefix of the **Exported into MODBUS** are amended accordingly.
- ▶ Change to standard project:
If the standard project is changed in multi-project administration, the variables must be amended.
Variables of the standard project must not have a prefix. All other variables need a **Projectname#** prefix.

ALLOCATION DIALOG

If a variable is moved to the `Exported into MODBUS` list via clicking the button ➤, a dialog for the name assignment of the zenon variable to an offset in MODBUS opens:



The dialog box is titled "Address Settings" and has a close button (X) in the top right corner. It contains two input fields: "Name" with the text "EMS_Supply area 1_forecast_average_error_range" and "Offset" with a small numeric input field showing "1" and the text "(MODBUS Holding Register Offset)" to its right. At the bottom are "OK" and "Cancel" buttons.

Parameter	Description
Name	Name of the variable. Note: The name of the variable is grayed out, because it can no longer be changed.
Offset	Offset: MODBUS holding register offset. Offset of the variable in MODBUS Attention: 0 is always entered as the offset by default.
OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.

10.2 Hardware address of the MODBUS system

The MODBUS system of the **Process Gateway** has a MODBUS hardware address that can be defined. This is set in the configuration dialog (A pagina: 164) with the **Slave Address property**. The address 1 is given as standard.

10.3 Configuration file: specific entries for AccessMODBUS

The configuration file `zenProcGateway.ini` contains specific entries for MODBUS. The file must be in the system folder.

[MODBUS]

Inserimento	Descrizione
COMPORT=	Interfaccia seriale (COM1 = 0, COM2 = 1,...). Può essere impostata usando il dialogo di configurazione (A pagina: 164).
BAUD=	Baud rate della porta seriale Può essere impostata usando il dialogo di configurazione (A pagina: 164).
BYTESIZE=	Quantità dei bit di dati dell'interfaccia seriale
PARITY=	Impostazioni di parità dell'interfaccia seriale: 0=No 1=Odd 2=Even Può essere impostata usando il dialogo di configurazione (A pagina: 164).
STOPBITS=	Quantità dei bit di stop dell'interfaccia seriale 0=1 1=1.5 2=2 Può essere impostata usando il dialogo di configurazione (A pagina: 164).
TIMEOUT=	Intervallo di timeout in millisecondi per la comunicazione seriale.
HWADDRESS=	Indirizzo hardware del sistema MODBUS. Default: 1 Può essere impostata usando il dialogo di configurazione (A pagina: 164).
REFRESHRATE=	Tempo di update in millisecondi.
SERIELL=	Comunicazione seriale o TCP/IP: 1 = seriale 0 = TCP/IP Può essere impostata usando il dialogo di configurazione (A pagina: 164).
PORT=	Porta TCP/IP
TCPTIMEOUT=	Intervallo di timeout TCP/IP in secondi.

[MODBUS VARIABLES]

Variabili che devono essere sostituite in AccessMODBUS.

Nota: a partire da zenon 7.11, questo inserimento sostituisce quello originario **[VARIABLES]**. Questo impedisce che per le variabili del progetto standard venga eseguita una sostituzione inutile tramite l'opzione **Logic per connessione SCADA**.

Inserimento	Descrizione
COUNT	Numero delle variabili da esportare
OFFSET_n	Indirizzo Modbus assegnato al numero corrispondente (n). La numerazione inizia da 0.
NAME_n	<p>Nome della variabile assegnata al numero corrispondente (n). La numerazione inizia da 0.</p> <p>Esempi:</p> <ul style="list-style-type: none"> ▶ OFFSET_0=0 NAME_0=EMS_Supply area 1_forecast_final_consumption Variabile dal progetto di partenza. ▶ OFFSET_1=2 NAME_1=BASISTUTORIAL#Temperaturfühler Variabile dal progetto "BASISTUTORIAL"

▶

11. MS Azure

La **AccessAzure.dll** scrive valori di variabili del Runtime in una coda del bus di servizio di MS Azure (**Queue**) oppure in un **Event Hub**. I dati della coda (**Queue**) possono essere poi acquisiti da MS Azure tramite il driver **AzureDrv** e integrati in processi di zenon. I dati di un Hub di eventi (**Event Hub**) servono per applicazioni di terzi e non possono più essere letti da zenon.

Il Process Gateway stabilisce ciclicamente una connessione con MS Azure e scrive messaggi nella coda (Queue) del bus di servizio, oppure nel Hub di eventi (Event Hub).

Per leggere i valori dalla Servicebus Queue, il driver **AzureDrv** instaura una connessione con la coda (Queue) del bus di servizio con il nome configurato e acquisisce tutti i messaggi in essa contenuti. Questi messaggi vengono decompressi ed i valori online in essi contenuti vengono assegnati alle variabili. La chiave utilizzata è il **Indirizzo simbolico**.

Tutti i messaggi già presenti nella coda quando il primo tentativo di connessione viene portato a termine con successo, vengono caricati e ignorati. Vengono visualizzati sempre solo i valori attuali.

Questo significa: ogni istanza driver su ogni computer ha la propria **Queue** come canale di entrata.
Esempio: in MS Azure, la Queue del bus di servizio per il computer **MYSERVER1** e per il prefisso configurato **onlinedata** si chiamerà: **onlinedata_myserver1**.

Sono supportati valori numerici (**DOUBLE**) e alfanumerici (**STRING**) . Il time-stamp e i bit di stato di sistema vengono trasferiti alla variabile di destinazione.

You can also find general information on **MS Azure** in the MS Azure manual.

11.1 Module configuration

Configuration dialog for MS Azure connection via Process Gateway.

VARIABLES

In the **Variables** group, you configure the variables whose values are saved by zenon in an MS Azure Service Bus.

Parameter	Description
Available in Scada	Displays all variables available in zenon With multi-project administration, variables from active projects can be selected.
Projects	List of all available projects. The standard project is marked with a *.
Variables	List of all variables of the selected project. List can be sorted; multiple selection is possible. Hint: Double clicking on the variable moves it.
Button >	Selected variables from the list of variables are moved to the Exported into MS Azure list.
Button <	Selected variables are removed from the Exported into MS Azure list.
Exported into MS Azure	List of the variables that are written to the MS Azure Service Bus by the Process Gateway. Naming: <ul style="list-style-type: none"> ▶ Project name ▶ # (as separator) ▶ Variable name. The key for the values in MS Azure is always PROJECTNAME#VARIABLENAME . Hint: Double clicking on the variable moves it.

MS AZURE CONNECTIONS

All target connections in which the current values of the selected variable are to be inserted in MS Azure are to be entered into the **MS Azure Connections** group.

In doing so, the current variable values are added to the connection created in **All** at the same time.

Parameter	Description
List of MS Azure connections	<p>Lists all connections to MS Azure configured. Each connection consists of the connection name (MS Azure Connection) and the Service Bus Queue Namen.</p> <ul style="list-style-type: none"> ► Creation of a new connection with the button New... ► A selected connection can be amended with the Edit... button.
MS Azure Connection	MS Azure Connection address
Service Bus Queue name	Name of the queue in the MS Azure service bus.
New...	Opens dialog to configure the MS Azure connection.
Edit...	Opens existing connections to configure the MS Azure connection.
Delete	Deletes the selected MS Azure connection from the list.

MS AZURE SETTINGS



Parameter	Description
Integrity period	<p>Time interval in which the current values of the selected variables are written as an image to the MS Azure Service Bus queue.</p> <p>If the value of a variable changes during this this interval, the value change is immediately transferred to the MS Azure queue.</p> <p>Default: 5 s</p>
HTTP Proxy Domain	Address of the proxy server in the network.
HTTP Proxy User	Input field of the user name for login on the proxy server.
HTTP Proxy Password	Input field for password for login on the proxy server. Note: Input is shown with dots - even during entry.
Confirm HTTP Proxy Password	Input field for the confirmation of the password for login on the proxy server. Note: Input is shown with dots - even during entry.

NAVIGATION

Parameter	Description
OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.

DIALOG IN THE EVENT OF INCORRECT ENTRIES

Configurations of the proxy server are validated. A corresponding warning dialog is shown in the event of an incorrect configuration.




Attenzione

.NET 4.5 must be installed on the computer in order for the proxy settings to work.

11.1.1 MS Azure Connection Settings

Configuration dialog for the connection to **MS Azure**:



Parameter	Description
MS Azure Connection	<p>MS Azure Connection address</p> <p>Note: You can read and copy this address in the Azure administration portal under Manage Connection Strings of the desired Servicebus Namespace.</p>
Service Bus Queue / Event Hub Name	<p>Name of the MS Azure Service Bus queue or the Event Hub. Selection by means of radio buttons.</p> <p>Note: Only characters that appear in the name of an MS Azure Service Bus Queue or in an Event Hub are permitted. Use simple, short and meaningful names. Avoid special characters, language-specific letters and blank spaces.</p> <p>Service Bus Queue</p> <p>The name of the Service Bus Queue comprises:</p> <ul style="list-style-type: none"> ▶ A freely-configurable prefix ▶ An underscore (_) ▶ The NETBIOS computer name (without domain name suffix) in small lettering <p>If the name does not yet exist in the Namespace a Queue with this name is created. Requirement: The corresponding rights are present.</p> <p>Event Hub</p> <ul style="list-style-type: none"> ▶ Message format: Select in the drop-down list in the Format option. ▶ Event Hub Name: Name of the Event Hubs in the MS Azure Service Bus The Event Hub must already be created with this name in the Namespace.
Queue	<ul style="list-style-type: none"> ▶ Active: The connection is established using the name of the Service Bus Queue.
Event Hub	<ul style="list-style-type: none"> ▶ Active: The connection is established using the name of the Event Hub. Selection of the message format using the Format option.
IoT Hub	<ul style="list-style-type: none"> ▶ Active: Sending of actual values and the receipt of messages via MS Azure. Entry of the device connection string in the MS Azure Connection input field.
Format	<p>Message format for connection via Event Hub. Select from drop-down list:</p> <ul style="list-style-type: none"> ▶ XML ▶ JSON

	► BOND (compact binary)
OK	Applica le impostazioni e chiude la finestra di dialogo.
Cancel	Annulla tutte le modifiche e chiude la finestra di dialogo.



Info

*The Service Bus Queue Name can be freely configured.
This queue is automatically created in MS Azure during the first communication to MS Azure.*

For each computer that calls up data from MS Azure, use the **AzureDrv** driver to create a separate MS Azure Connection.

IOT HUB

Actual values are sent to the **IoT Hub** as a message. Messages received by the **IoT Hub** are decoded and written to the contained value as a set value.

Content of IoT configuration

VarName	string	Variable name
IsString	Bool	Value of actual string.
NumValue	Number	Numeric value
StrValue	String	String value
Time	ISO timestamp	Timestamp
Status	Number	Status

Example for MS Azure connection entry:

```
{ "IsString":true,"NumValue":0,"Status":1078067200,"StrValue":"sunshine","Time":
"2016-12-16T06:45:39.851Z","VarName":"AZURE_TEST#Weather" }
```

11.2 Message formats

SERVICE BUS QUEUE

The messages in the Queue must have a serialized .NET class `OnlineValueMessage`.

FORMAT:

```
public class OnlineValueMessage
{
    public string strVarProject { get; set; }
    public string strVarName { get; set; }
    public long nVarID { get; set; }
    public double fValue { get; set; }
    public string strValue { get; set; }
    public bool bValueIsString { get; set; }
    public long nTime_s { get; set; }
    public short nTime_milli { get; set; }
    public long nStatus { get; set; }
}
```

EVENT HUB

When using the Event Hub as a connection, it is possible to choose between XML, JSON and BOND (compact binary) as a message format. Partition-Key is the zenon variable name.

FORMAT BOND

```
namespace AzureServiceBusShared

struct ArchiveMessage
{
    0: string strArvProject;
    1: string strArvName;
    2: string strVarProject;
    3: string strVarName;
    4: int64 nVarID;
    5: int16 nCalc;
    6: double fValue;
```



```
7: string strValue;
8: bool bValueIsString;
9: int64 nTime_s;
10: int16 nTime_milli;
11: int64 nStatus;
}

struct OnlineValueMessage
{
0: string strVarProject;
1: string strVarName;
2: int64 nVarID;
3: double fValue;
4: string strValue;
5: bool bValueIsString;
6: int64 nTime_s;
7: int16 nTime_milli;
8: int64 nStatus;
}
```

11.3 Error message

Error message in the LOG file:

Error message	Debug Level	Description
Project %s inactive fail!	Error	The project-inactive event could not be processed by the Gateway in the given time.
Project %s active fail!	Error	The project-active event could not be processed by the Gateway in the given time.
Value change queue full: Value change for id:%u of project:%s lost!	Error	The queue for the value changes from Runtime is full. Additional values are discarded. The connection to Azure is probably too slow in order to forward all value changes.
Adding of %d Online Rows failed for '%s' Queue '%s'	Error	The insertion of value changes into the service bus queue was unsuccessful.
Adding of %d Online Rows succeeded for '%s' Queue '%s'	Deep Debug	The insertion of value changes into the service bus queue was successful.
Starting to add Online Rows failed for '%s' Queue '%s'	Error	The establishment of the a connection to the service bus queue was unsuccessful.
Creating Azure Wrapper failed	Error	The ManagedAzureWrapper.dll could not be loaded.

IOT

Parameter	Description	Description
Sending value to '%s' failed	Error	The writing of the set value has failed
IoTHubMessage_GetByteArray() failed	Error	The SDK API call has failed.
Received message from IoT Hub	Deep Debug	Message from IoT hub received.
Exception when deserializing payload: %s	Error	Received message is in the wrong format
IoTHubClient_CreateFromConnectionString() failed	Error	The SDK API call has failed.
IoTHubClient_SetMessageCallback() failed	Error	The SDK API call has failed.
IoTHubMessage_CreateFromByteArray() failed	Error	The SDK API call has failed.
Sent message to IoT Hub	Deep Debug	The message was sent.

11.4 Configuration file: specific entries for MS Azure

The configuration file `zenProcGateway.ini` contains this entries for MS Azure.

[AZURE]

Inserimento	Descrizione
INTEGRITYPERIOD=	Intervallo in secondi del ciclo di scrittura.
PROXY_DOMAIN=	Indirizzo del server proxy.
PROXY_USER=	Nome utente da usare per la registrazione sul server proxy.
PROXY_PWD=	Password da usare per la registrazione sul server proxy. Nota: la password viene visualizzata anche nel file .INI in forma crittografata.

Nota: Una condizione perché le impostazioni proxy funzionino, è che sul computer sia installato .NET 4.5.

[VARIABLES]

Inserimento	Descrizione
Name_n=	<p>Nome della variabile per il Process Gateway. Formato: SOURCEPROJECT#SOURCEVARIABLE..</p> <p>Numerazione (n): n rappresenta il numero progressivo della configurazione di connessione. Questa numerazione inizia da 0.</p> <p>Esempio:</p> <ul style="list-style-type: none"> ► 1 variabile dà come risultato $n = 0$ ► Con 3 variabili si ha, per il terzo inserimento, $n = 2$
Count=	<p>Numero delle variabili.</p> <p>Nota: in questo caso la numerazione inizia da 1. Otto connessioni danno come risultato <code>Count=8</code>.</p>

[CONNECTIONS]

Inserimento	Descrizione
CONN_n=	<p>Nome della connessione MS Azure.</p> <p>Numerazione (n): n rappresenta il numero progressivo della configurazione di connessione. Questa numerazione inizia da 0.</p> <p>Esempio:</p> <ul style="list-style-type: none"> ► 1 connessione dà come risultato $n = 0$ ► Con 3 connessioni si ha, per il terzo inserimento, $n = 2$
QUEUE_n=	<p>Nome della coda MS Azure.</p> <p>Per la numerazione (<u>n</u>) valgono le stesse regole che si applicano a CONN</p>
COUNT=	<p>Numero delle connessioni MS Azure configurate.</p> <p>Nota: in questo caso la numerazione inizia da 1. Due connessioni danno come risultato <code>Count=2</code>.</p>

12. OPC UA Server

The OPC UA Server provides the variables used in the project to all standard-compliant OPC UA Client tools.



Info

The OPC UA server can be used for all zenon versions from 5.50.

The predecessor to the OPC UA servers is the OPC DA server. This is not part of the Process Gateway.

The OPC UA driver and all dialogs are only available in English.

MULTI-PROJECT CAPABILITY

The OPC UA server is multi-project compatible from zenon 7.11 onwards. Variable from the Runtime project and all its subprojects can be selected. In doing so, the object name from the variable name and the project name are combined. Configurations for OPC UA clients that were created before zenon 7.11 are thus not compatible. These must be amended when using zenon 7.11 or higher.

From version 7.60, the `NodeIDs` change if variables are not explicitly defined in the configuration. The data type of the `NodeID` is `string`. The `NodeID` always consists of the project GUID and the variable ID. If variables have been explicitly configured, this change has no effect.



Esempio

`NodeID: "6d5ea886-1b04-4d9c-aa35-2b5664c500cd-38d"`; the following is applicable in the process: `"6d5ea886-1b04-4d9c-aa35-2b5664c500cd"` is the **ID progetto** and `"38d"` corresponds to the variable ID 909.

From version 7.60, the `Namespace Index` is `"2"` by default, instead of `"80"`, for new configurations. The `Namespace Index` can no longer be configured in the user interface. This change has no effect for existing configurations.


The earlier action can be activated again by means of the `"configuration_version=1"` entry in the INI file. This can, for example, make sense for a `Namespace Index` with 80 or for a configurable `Namespace Index`.

12.1 Confronto fra OPC Server e OPC UA Server


L'OPC UA Server ha preso il posto dell'OPC Server. Si raccomanda l'uso dell'OPC UA server per la maggior parte delle applicazioni.

OPC SERVER

- ▶ OPC Task Force dal 1995
- ▶ Interfaccia universale per i sistemi di automazione.
- ▶ Basato sulla tecnologia COM/DCOM di Microsoft.
- ▶ OPC foundation dal 1996
- ▶ Diverse specifiche per differenti applicazioni.



OPC UA SERVER




CONFRONTO FRA OPC SERVER E OPC UA SERVER

Parametro	OPC Server	OPC UA Server
Modello di dati	Limitato	Per tutte le applicazioni
Implementazione	Dipendente dal produttore	Indipendente dal produttore
Interoperabilità	--	X
Configurazione	Complicata	Semplice
Più istanze	--	X
Uso in rete	--	X
Tecnologia di rete	--	OPC UA TCP binary Protocol
Prestazioni	Basse	Alte
Piattaforme	Solo Windows	Indipendente
Fabbisogno di risorse	Alte	Più basso
Service-Oriented Architecture (SOA)	--	X
Protezione	Obsoleta	Al passo con gli standard attuali
Protezione connessione	--	X
Windows CE	--	X

Legenda:

- ▶ **X**: viene supportato
- ▶ --: non è supportata.

12.2 Module configuration




To configure the server and variables for OPC UA:

1. In the **Process Gateway** statistics dialog, click the **Configuration** button.
The dialog for the configuration of the OPC UA module is opened.
2. In the module configuration dialog, you configure:

- Server (A pagina: 184)
Connection parameters to the OPC UA server
- Variables (A pagina: 191)
Variable assignment

12.2.1 Server

You configure connection parameters to an OPC UA server in the **Server** tab.



Settings

Server Variables

Connection

Name: zenon OPC UA Process Gateway Port: 4841

Security

Certificates path: C:\ProgramData\COPA-DATA\System\PKI\CA\ ...

Server certificate path: C:\ProgramData\COPA-DATA\System\PKI\CA\certs\zenopcua.der ...

Server private key path: C:\ProgramData\COPA-DATA\System\PKI\CA\private\zenopcua.pem ...

☐ Accept secure connections only

☒ Trust all client certificates

☐ Use Scada user authentication

Historical data

Archive for historical data: ...

OK Cancel Help

CONNECTION

Communication parameters to the OPC/OPC UA server.

Parameter	Description
Name	Name of the server as it is shown on the client. Default: zenon OPC UA Process Gateway
Port	TCP port via which the client establishes the connection to the OPC UA server. Default: 4841

SECURITY

Settings and assignment of certificates for secure and encrypted communication.

Parameter	Description
Certificates path	<p>Path for the root folder with the certificate files and the respective subfolders.</p> <p>Click on the ... button to open the file selection dialog</p> <p>Default: %ProgramData%\PKI\CA\</p> <p>Note: If this root folder is changed, the paths for Server certificate path and Server private key path must also be amended.</p>
Server certificate path	<p>File with the public key of the server. This public key is used by the client for the encryption of messages.</p> <p>Click on the ... button to open the file selection dialog Files with the following file type are shown for selection:</p> <ul style="list-style-type: none"> ▶ Format: DER ▶ Suffix: .der <p>Default: %ProgramData%\PKI\CA\certs\zenopcua.der</p> <p>Note: This path must be a subfolder of the configured Certificates path. In the event of an error, a warning dialog is visualized and the OK button is grayed out.</p>
Server private key path	<p>File with the private key of the server. This private key is used by the server to decrypt the messages from the client.</p> <p>Click on the ... button to open the file selection dialog Files with the following file type are shown for selection:</p> <ul style="list-style-type: none"> ▶ Format: PEM ▶ No password <p>Default: %ProgramData%\PKI\CA\private\zenopcua.pem</p> <p>Note: This path must be a subfolder of the configured Certificates path. In the event of an error, a warning dialog is visualized and the OK button is grayed out.</p>
Accept secure connections only	<p>Checkbox to be ticked if only one secure connection can be used to establish the connection.</p> <ul style="list-style-type: none"> ▶ Active: Establishment of a connection is only accepted with a secure connection. Securing is carried out each time with a signature or with a signature and encryption. ▶ Inactive: Establishment of a connection is only accepted with a secure

	<p>connection.</p> <p>The following are considered a secure connection:</p> <ul style="list-style-type: none"> ▶ Basic128Rsa15: RSA15 as key wrap algorithm and 128-bit basic as algorithm for the message encryption ▶ Basic256: 256-bit basic as algorithm for message encryption <p>Default: Inactive</p> <p>Note: for connections with a signature, the packages are secured against tampering, but the contents of the package are not encrypted.</p>
Trust all client certificates	<p>Checkbox to select whether all client certificates are accepted for the establishment of a connection or only client certificates known on the server.</p> <ul style="list-style-type: none"> ▶ Active: All client certificates are accepted and the connection is made. ▶ Inactive: All clients that want to connect with the server must send a valid certificate. This certificate is also checked to see if it is in the list of known client certificates Certificate trust list path. <p>Default: active</p> <p>Note: An OPC UA client without a secure connection does not send a certificate. For an OPC UA client with a secure connection, the certificate must always be stored in the Trust List folder.</p>
Use SCADA user authentication	<p>Checkbox to configure the connection. If there is no user administration configured in the zenon project, this checkbox is grayed out.</p> <ul style="list-style-type: none"> ▶ Active: Clients can only log on to the server with a valid user ID and password. Note: To do this, the user administration must be activated and configured in zenon Editor. ▶ Inactive: Anonymous login is possible. <p>Attention: The user name and password are not transferred in encrypted form in the OPC UA telegram. If necessary, use your own users in the project without assigned authorization levels.</p>

HISTORICAL DATA

Archive for historical data	<p>Archive for historical data. Selection of the archive from a drop-down list. Only one individual archive from one of the projects can be selected in Runtime.</p> <p>The archive must have already been configured in the zenon project.</p>
------------------------------------	---

CLOSE DIALOG

OK	<p>Accetta le modifiche in tutte le schede e chiude la finestra di dialogo.</p> <p>Attention: All active connections are ended and the server is restarted with the new settings. Connection errors may occur in the process.</p>
Cancel	<p>Annulla tutte le modifiche in tutte le schede e chiude la finestra di dialogo.</p>
Help	<p>Apre la guida online.</p>

ERROR MESSAGE

Error messages are displayed in red font. In doing so, not all errors are shown together. The first error of the configuration is shown each time. It is therefore possible that a new error message is shown after a correction has been made.

Certificates

*All certificates must correspond to the format **X509**.*

CERTIFICATE STORE

The OPC UA server in the process gateway uses an OpenSSL Directory certificate store.

SERVER CERTIFICATE

The server certificate created on initial startup is a self-signed certificate. The certificate contains a public key. In addition, a suitable private RSA key (1024 bit) is generated.

Although the OPC UA can in principle run with the self-created certificate, it is recommended that a corresponding certificate is created for productive operation. To do this, the self-created certificate can serve as a template for applications that allows creation of the certificates according to user criteria.

Attention: The file name `zenopcua.der` is used by both the OPC UA server as well as the OPCUA32 client driver. If encrypted communication between the OPCUA32 client driver and OPC UA server in the Process Gateway is configured for tests on the same computer, it is best that the certificate for the OPCUA32 client driver is renamed before the certificate is copied to the trust list by the OPCUA server.

*As a URI in the **SubjectAltName** field, the certificate gets the Full Qualified Domainname (FQN) of the computer, the default port number 4841 from the OPC UA server and a DNS entry with the computer name. The URI of the OPCUA servers is compiled dynamically and changes if, for example, the port number is changed. The server certificate is not changed in this case. A client that carries out a strict check of the server certificate can then reject the server certificate. It can also be necessary to create your own certificate where **SubjectAltname** also contains an entry for the IP address in addition to the DNS entry.*

CERTIFICATE TRUST LIST/CERTIFICATE TRUST CHAIN

*All certificates with the suffix **.der** are checked by the OPC UA server and classed as a trustworthy certificate. As an alternative to the self-designated Application Instance **certificate** of an OPC UA clients, the public root certificate of the Certificate Authority that was used to sign an Application Instance **certificate** of an OPC UA client can also be stored. The Application Instance **certificate** of the client does not need to be present on the server in this case.*

CERTIFICATE REVOCATION LIST

If an OPC UA client uses an Application Instance **certificate** that is signed by a Certificate Authority, the Certificate Revocation List is also checked by the server in addition to the certificate. The OPC UA server checks all files with the suffix **.crl** in the **Crl** subfolder.

Attention: The **.crl** file must be stored in PEM format. Only one single **.crl** file can be present per Certificate Authority.

The connection is denied if:

- ▶ The client certificate is included in the **Revocationlist** `BadCertificateRevoked`
- ▶ The CRL is no longer current (`BadCertificateTimeInvalid`)

If, for a certificate that was signed by a Certificate Authority, there is no **Certificate Revocation List** present, it is assumed that there is no such Revocation List. In this case, the certificate is treated as trustworthy.

Generate new certificate

If necessary, new certificates can be generated when the OPC UA server is started.
To do this:

1. Remove the existing certificates.
There are two possibilities for doing so:
 - a) Delete the following folder: %programdata%\COPA-DATA\system\PKI.
In doing so, all trusted certificates and certificate revocation lists are removed.
Or:
 - b) Delete the following files in order to get all other certificates and lists:
zenopcua.der in the folder %programdata%\COPA-DATA\system\PKI\CA\certs
zenopcua.pem in the folder
%programdata%\COPA-DATA\system\PKI\CA\private
zenopcua.crl in the folder %programdata%\COPA-DATA\system\PKI\CA\crl
2. Open the **zenprocgateway.ini** configuration file.
3. Go to the section **[OPCUA]**.
4. Remove the following entries:
 - **CERTIFICATES_PATH=**
 - **SERVER_CERTIFICATE_LOCATION=**
 - **SERVER_PRIVATE_KEY_LOCATION=**
5. Start the OPC UA **Process Gateway**.
6. Confirm the message box by clicking on the **Yes** button to create new certificates.



Attenzione

If server certificates need to be renewed, each OPC UA client that needs a valid server certificate must receive the renewed certificate.

The following situations can make it necessary to create the server certificate from scratch:

- several instances of Process Gateway on the same system with different port numbers
- a change to the port number
- a change to the computer name
- the certificate has expired

12.2.2 Variables

Variables for the **OPC UA Process Gateway** can be selected automatically or individually.

Variables from the current project and its subprojects can be selected. The name on the server consists of the variable names and the project names.



Attenzione


Variables that do not have the **Imposta valore attivo** property activated in the zenon Editor cannot be written by an OPC UA client.

DEFINING VARIABLES

If no variables are defined in the OPC UA server configuration, all variables from the zenon projects are added to the OPC UA Address Space. All variables (including system driver variables) are visible for the clients.

with manual configuration (at least one configured variable), the values defined by the user are used. The **Namespace Index 2** is used by default and a **String Identifier** with the variable names is entered.

You configure the variables that are to be provided as a node in the OPC UA data model in the **Variables** tab.



Parameter	Description
Available in SCADA	<p>List of the configured variables available in the zenon Runtime.</p> <ul style="list-style-type: none"> ▶ Project zenon project name ▶ Name zenon variable name <p>The list can be sorted and filtered.</p> <ul style="list-style-type: none"> ▶ Sort by clicking on the column heading. Another click changes the sorting order. ▶ Filter by entering the filter text in the input field. The characters * or ? are possible as placeholders.
Exported to OPC UA	<p>List of exported variables.</p> <p>The variables can be sorted according to:</p> <ul style="list-style-type: none"> ▶ Identifier ▶ SCADA Project ▶ SCADA name
Node Id	<p>The input field for Node ID is only available if an entry in the Exported to OPC UA list is selected.</p>
Namespace index	<ul style="list-style-type: none"> ▶ Field can only be configured with an old configuration; otherwise not available. For a new configuration, the namespace index is always Default 2.
Identifier	<p>Defines the <code>Node Identifier</code> for the selected OPC UA variable. The node identifier type is automatically defined through the entry:</p> <ul style="list-style-type: none"> ▶ A numerical <code>Identifier</code> is automatically created with numerical input. ▶ If a GUID is entered, a <code>GUID Identifier</code> is created automatically, otherwise the <code>Identifier</code> is treated as a string. GUID form: xxxxxxxx-xxxx-xxxx-xxxx-xxxxxxxxxxxxx) <p>The field must not be empty.</p> <p>The node identifier must be unique in the complete address range.</p>

To export variables to OPC UA:

1. Select the desired variables and aggregation archives in **Available in SCADA** with a mouse click. Multiple selection is possible.

2. Click on the arrow direction **Exported to OPC UA**

To export all variables, click on the double arrow

The zenon variable name is used as **Browsename** and **Displayname**.



Info

For zenon variables with a slash (/) in the names, the / is replaced by a dot (.). The parts of the name separated by a slash are saved in their own subfolders.

Example: The zenon variable "Static/Scalar/Int32" is divided into:

- ▶ An OPC UA variable "Int32"
- ▶ In a folder called "Scalar",
- ▶ which is a subfolder of the "Static" folder

This works with all data types, multi-dimensional arrays, umlauts in names and slashes at the end.

12.3 Start

When starting, **Process Gateway** loads the configured module.

When first starting or if no variables have been explicitly configured, the OPC UA server automatically creates the data model for all projects in Runtime. With many variables, or with many variables configured with alarms, the start can take a corresponding length of time. It is, in principle, to be recommended that only the variables that are actually needed by the OPC UA client are provided through the OPC UA server. Several instances of the OPC UA Process Gateway can also be started, with a different TCP port and a different configuration in terms of variables.

The driver tries to read the active configuration from the given INI file. If the configuration contains error, or an error occurs on starting, the configuration dialog (A pagina: 183) is opened and an error message is shown with an error text. If the configuration is not confirmed with **OK**, the **Process Gateway** is closed.



Attenzione

If the application is started as invisible, there is also no configuration dialog displayed. If the configuration is invalid or not present, the process gateway is automatically closed.

12.4 Connection

The **OPC UA Process Gateway** only supports the **OPC UA TCP binary Protocol** and does not contain a **Discovery Server**. The client must also connect directly to the server. The connection address corresponds to the scheme: **opc.tcp://hostname.of.server:port**

The connection can be secured (A pagina: 195).

12.5 Security

The module uses the security procedures that correspond to OPC UA (signing and encrypting messages) as defined in the standard. Certificates can be checked or all accepted, depending on the setting (A pagina: 183).

SECURE CONNECTIONS

If the **Accept secure connections only** (A pagina: 184) option is activated, the server only accepts connections that use the **Security Mode** `Sign` or `Sign & Encrypt`. In addition, the **Security Policy** used by the client must be `Basic128Rsa15` or `Basic256`. If this option is deactivated, any desired combination of **Security Mode** and **Security Policy** is accepted.

USER ADMINISTRATION

If user administration is activated in the zenon project and at least one user is created, the option **Use SCADA user authentication** (A pagina: 184) is available. If this option is activated only clients that send a valid combination of `user` and `password` have access to the OPC UA server data. There is no check if this option is inactive. In this case, both anonymous connections and also all user/password combinations are accepted.

12.6 Alarms and Conditions

The **OPC UA Process Gateway** also supports OPC UA Alarms and Conditions. When starting, the OPC UA server automatically checks the configured variables for existing limit values or a reaction matrix, with statuses that are defined as an alarm.

An OPC UA client can create a subscription for event notifications and add the server object. The OPC UA client can thus be informed of limit value breaches of a variable with an alarm active. The client is also in a position to confirm the alarm, as in the zenon Runtime.

Attention: The comments for alarms for the OPC UA method call for acknowledgment is no longer submitted to zenon Runtime. If an alarm is configured in zenon with "Comment required", an OPC UA client cannot confirm this alarm with a comment.

Attention: If an alarm is configured so that an alarm cause is required, the alarm cannot be acknowledged on the OPC UA side.

The standard-compliant OPC weighting is shown on the index of the alarm/event classes linked to the limit value. The index of an alarm/event class is automatically incremented by the zenon Editor with each new alarm/event class and can be checked in the properties. Up to 20 classes with the following allocation are supported:


OPC UA range	zenon alarm/event class	OPC weighting
HIGH	20	1000
	19	950
	18	900
	17	850
MEDIUM HIGH	16	800
	15	750
	14	700
	13	650
MEDIUM	12	600
	11	550
	10	500
	9	450

MEDIUM LOW	8	400
	7	350
	6	300
	5	250
LOW	4	200
	3	150
	2	100
	1	50

If a variable with no alarm/event class is linked, the lowest possible classification 1 (LOW) is used.

ILLUSTRATION ZENON ALARM AS OBJECT

zenon variables and related alarms are illustrated in the OPC UA server as objects.



The illustration shows the inclusion of the zenon project (TEST651) and the zenon variables (WIZ_VAR_10, WIZ_VAR_11, WIZ_VAR_12) as objects in the upper area. Below this are the alarms that have been generated when the limit values are reached (Limit 750 reached! etc.).

ALARM CONDITION NOTE IDENTIFIER

The node identifier type of the alarm condition is a string type node ID.

The following structure is used:

<project GUID>-<variable ID hexadecimal>@<variable name>:_<limit value description or "Rema">

About the INI entry: `USE_LIMIT_TEXT_FOR_ALARM_NODES=TRUE` in the OPCUA section in the ini file for the OPC UA process gateway, an alternative structure can be activated where the limit value text is used. This alternative structure is only available for limit values and not for alarms via a reaction matrix. A dynamic limit value text is not supported in doing so. It must be ensured that the same limit value text is not used for several limit value texts for the same variable, because otherwise there is no uniqueness:

`<project GUID>-<variable ID hexadecimal>@<static limit value text>`

LOGGING

The driver supports a comprehensive LOG function. These LOG entries can be evaluated with the Diagnosis Viewer tool.

12.7 Service Sets

Service Set	Is supported
Discovery Service Set	
FindServers	yes
GetEndpoints	yes
RegisterServer	no
SecureChannel Service Set	
OpenSecureChannel	Yes
CloseSecureChannel	Yes
Session Service Set	
CreateSession	yes
ActivateSession	yes
CloseSession	yes
Cancel	yes
NodeManagement Service Set	
AddNodes	no
AddReferences	no
DeleteNodes	no
DeleteReferences	no
View Service Set	
Browse	yes
BrowseNext	yes
TranslateBrowsePathsToNodeIds	yes
RegisterNodes	yes
UnregisterNodes	yes
Query Service Set	
QueryFirst	no
QueryNext	no
Attribute Service Set	
Read	yes

HistoryRead	yes
Write	yes
HistoryUpdate	no
Method Service Set	
Call	yes
MonitoredItem Service Set	
CreateMonitoredItems	yes
ModifyMonitoredItems	yes
SetMonitoringMode	yes
SetTriggering	yes
DeleteMonitoredItems	yes
Subscription Service Set	
CreateSubscription	yes
ModifySubscription	yes
SetPublishingMode	yes
Publish	yes
Republish	yes
TransferSubscriptions	yes
DeleteSubscriptions	yes

12.8 Communication

SUBSCRIPTIONS

The OPC UA server supports communication by means of Subscriptions. Several Subscriptions with different settings can be created per session by a client. The maximum number of Subscriptions per Session is limited to 10 by default. The "MAX_COUNT_OF_SUBSCRIPTIONS_PER_SESSION" ini entry in the "OPCUA" section can be used to configure the maximum number between "1" and "100".

PUBLISHREQUESTS

A maximum of 10 `PublishRequests` for the queue are permitted by the OPC UA server per session. This depends on the number of `Subscriptions`.

- ▶ **Sequence for publish requests (first in, first out):**
When sending, the incoming sequence of the `PublishRequest` is taken into account. If a subscription is executed and a `PublishResponse` must be sent for a `DataChangeNotification` or a `KeepAlive`, the oldest `PublishRequest` from the queue is always taken.
- ▶ **`BadNoSubscription` for all publish requests if the last `Subscription` has been deleted or the session has been closed:**
If the last `Subscription` has been logged off from the server, for `PublishRequests` that are still logged onto the server, `PublishResponse` with the value `OpcUa_BadNoSubscription` is created and sent to the client. The open `PublishResponses` are then deleted on the server.
- ▶ **`timeoutHint` for `PublishRequests`:**
Before the `PublishResponses` for the `Subscriptions` are sent, it is ensured that only valid - i.e. not expired `PublishRequests` are present. The validity is checked using the time stamp of the `PublishRequests` as well as the `timeoutHint` stated in the `Request`. The resulting end time must be less than the current time of the server. If this is not the case, a `Response` with `OpcUa_BadTimeout` is sent back to the client. The `Request` is deleted in this case.
- ▶ **`SubscriptionAcknowledgement` that is included in the `PublishRequest`** processes the OPC UA server if the `PublishRequest` is taken from the queue

REPUBLISHREQUESTS

The OPC UA server also supports the `RepublishRequests` in the event that the TCP connection between OPC UA client and OPC UA server is interrupted.

SYNCHRONOUS TIME

For `PublishRequests`, the OPC UA server takes the "`timeoutHint`" field into account.

If the OPC UA server has to send a `PublishResponse`, all existing `PublishRequests` in the queue (max. 10) are checked. This check validates whether the time stamp is more recent than the current time. If this is the case, the oldest `PublishRequest` from the queue is used.

If the queue contains `PublishRequests` whereby the time stamp in the `PublishRequest` + `timeoutHint` in the `PublishRequest` is the same or older than the current time in the OPC UA server, the `PublishRequests` are removed from the queue and for each `PublishRequest`, a `ServiceFault` with "`Bad_Timeout`" is sent.

It is therefore important that the system time of the OPC UA server and the system time of the OPC UA client is synchronized accordingly. For this time synchronization, it is recommended that, for both the OPC UA server and the OPC UA client, a common synchronization source is used. A common source can, for example, be the same NTP server for server and client. Otherwise it is possible that the OPC UA

server immediately rejects all `PublishRequests` from the OPC UA client and no value changes can be transferred.



Info

THE TIME STAMP NAME CONSISTS OF: PUBLISHREQUEST + TIMEOUTHINT FROM THE PUBLISHREQUEST.

MONITORED ITEMS

The OPC UA server supports the adding, removal and modification of `MonitoredItems`.

If a queue of greater than 1 is requested from a OPC UA client, this request is supported. As a result, several value changes for the same variable are buffered between two publish intervals by the OPC UA server. A `PublishResponse` is used to send the value changes to the OPC UA client.

DATACHANGEFILTER - DEADBAND

The OPC UA server supports the `absolute deadband`.

READ REQUESTS

The OPC UA server also supports, in addition to communication by means of `Subscriptions`, `Read Requests`. In principle, communication by means of `Subscriptions` is preferred to communication by means of read requests. If an OPC UA client does not support subscriptions and sends read requests cyclically in order to get the current value, it is strongly recommended that the client uses the `RegisterNodes` call once for such nodes that are read cyclically.

This allows the OPC UA server to optimize communication with Runtime for cyclical `Read Requests`.

WRITE REQUESTS

The OPC UA server supports write requests. The set value limits of the variable are taken into account.

Attention: If a variable in the Energy Edition is linked to a command group and this variable is written by an OPC UA client, the command interlocking is not taken into account but the command variable is written directly.

12.9 Configuration file: INI entries for OPC UA

The configuration file `zenProcGateway.ini` contains this entries for OPC UA:

[OPCUA]

Inserimento	Descrizione
SERVER_NAME=	Nome del server OPC UA con il quale il Gateway stabilisce una connessione.
SERVER_PORT=	Porta per la comunicazione con il server OPC UA. Default: 4841
CERTIFICATES_PATH=	percorso della cartella radice con i file di certificato e le relative sotto-cartelle. Default: %ProgramData%\PKI\CA\ Nota: L'inserimento deve essere cancellato se si vuole creare un nuovo certificato al momento dello start del Process Gateway.
SERVER_CERTIFICATE_LOCATION=	URI del file con la chiave pubblica del server. Il percorso è sempre indicato come percorso assoluto. Questa chiave pubblica viene usata dal client per crittografare i messaggi. Default: %ProgramData%\PKI\CA\certs\zenopcua.der Nota: L'inserimento deve essere cancellato se si vuole creare un nuovo certificato al momento dello start del Process Gateway.
SERVER_PRIVATE_KEY_LOCATION=	URI del file con la chiave privata del server. Il percorso è sempre indicato come percorso assoluto. Questa chiave privata viene usata dal server per decifrare i messaggi del client. Default: %ProgramData%\PKI\CA\private\zenopcua.pem Nota: L'inserimento deve essere cancellato se si vuole creare un nuovo certificato al momento dello start del Process Gateway.
ARCHIVE_NAME=	nome di un archivio per dati storici configurato in zenon. Solo un archivio di uno dei progetti può essere selezionato a Runtime.
ONLY_SECURE_CONNECTIONS=	Selezione del tipo di connessione (protetta o non protetta) consentito quando si stabilisce una determinata connessione. <ul style="list-style-type: none"> ▶ TRUE Una connessione con il server deve essere sempre protetta. ▶ FALSE

	<p>È possibile anche una connessione non protetta con il server.</p> <p>Default: TRUE</p>
TRUST_ALL_CLIENT_CERTIFICATES=	<p>Selezione del tipo di certificati (certificati client o server) consentito per una determinata connessione.</p> <ul style="list-style-type: none"> ▶ TRUE Tutti i certificati client vengono accettati, la connessione viene stabilita. ▶ FALSE Tutti i client che si vogliono connettere al server devono trasmettere un certificato valido. Il sistema verifica anche se questo certificato si trova nella lista dei certificati digitali conosciuti (Certificate trust list path). <p>Default: TRUE</p>
USE_USER_AUTHENTICATION=	<p>Definizione se, al momento della registrazione sul server, deve essere utilizzata la gestione user del progetto attuale di zenon per l'identificazione.</p> <ul style="list-style-type: none"> ▶ TRUE I client possono registrarsi sul server solo con identificazione utente e password valide. Nota: a questo scopo, deve essere progettata e attivata la Gestione user nell'Editor di zenon. ▶ FALSE È possibile un Login anonimo. <p>Default: FALSE</p>
CONFIGURATION_VERSION=2	<p>Nota relativa al versionamento.</p> <p>Nota: questo inserimento INI non può essere configurato nell'interfaccia grafica utente per il OPC UA Gateway.</p>
MAX_COUNT_OF_SUBSCRIPTIONS_PER_SESSION=	<p>Numero delle <i>Subscriptions</i> pro Session. Si può impostare questo numero che deve essere compreso fra un minimo di 1 e un massimo di 100 <i>Subscriptions</i>.</p> <p>Default: 10</p>

[VARIABLES]

Inserimento	Descrizione
PROJECT_x=	<p>Nome del progetto da cui derivano le variabili. x rappresenta qui la numerazione all'interno di un progetto, a cominciare da 0.</p> <p>Esempio: PROJECT_0=TEST</p>

PARAM_x=	Parametri per il progetto x . La numerazione parte da 0 ed è crescente. Esempio: PARAM_0 =80:INI.Driverforinternalvariables_ModemHwAdrSet
COUNT=	Numero delle variabili configurate.
NAME_x=	nome della variabile. x rappresenta qui il numero del progetto, a cominciare da 0. Esempio: NAME_0 =Driverforinternalvariables_ModemHwAdrSet

2 = costante per Namespace Index

viene predefinito/attribuito in modo fisso dal sistema e non deve essere cambiato.

12.10 Error message

Error messages in the log file:

Error message	Debug Level	Description
Failed to validate client certificate	Error	The client certificate could not be validated. It is either invalid (the date of validity may have been overwritten) or it was not found in the list of known client certificates. Additional information including an error number describes the error in more detail.
Wrong user/password supplied while trying to activate session (User: %s)	Error	User authentication failed. ▶ %s: Name of the user to be authenticated.
Login of user '%s' succeeded.	Deep Debug	User authentication successful. ▶ %s: Name of the user to be authenticated.
Variable '%s' could not be added to OPC UA address space, because node '%s' with the same node identifier already exists	Error	A variable defined by the user could not be created, because another variable with the same Identifier already exists.
Failed to initialize server architecture: An	Error	The file format for one or more of the following files is not present in a valid format:

internal error occurred as a result of a programming or configuration error. (0x80020000)		<ul style="list-style-type: none"> ▶ Certificate ▶ Private Key ▶ Certificate Revocation List
%1 PublishResponse with OpcUa_BadNoSubscriptions sent because no subscriptions are created in session %2	Error	<p>There is no valid Subscription for a publish request or the session was deleted. The OPC UA server sends a messages to the OPC UA client for all active PublishRequests if the last subscription was deleted by the server or the client.</p> <ul style="list-style-type: none"> ▶ %1 Number of PublishResponses that have been sent to a client with the result value OpcUa_BadNoSubscription. ▶ %2 Name of the session from which the PublishResponse has been sent.
%1 PublishResponse with OpcUa_BadTimeout sent in session %2	Error	<p>The time stamp + timeout hint in the PublishRequest that is provided by the client is older than the current time on the OPC UA server. Possible causes: the timeoutHint in the PublishRequest is too short, the OPC UA client provides more PublishRequests than are needed and the PublishRequests expire or the time of the computer with the OPC UA server and the time of the computer with the OPC UA client are not synchronous.</p> <ul style="list-style-type: none"> ▶ %1 Number of the PublishResponses that have been sent to a client with the result value OpcUa_BadTimeout. ▶ %2 Name of the session from which the PublishResponses are sent. <p>Note: The PublishRequest is deleted.</p>

12.11 Status mapping

In certain situations, the OPC UA server communicates a different `StatusCode` for the value (Value Attribute). This concerns each `node` that represents the variable.

The table below lists the zenon status with the corresponding UA status code.

Status of the variable in the Runtime	StatusCode Value Attribute OPC UA Node
INVALID	0x80050000 BadCommunicationError
ALT_VAL	0x40910000 UncertainSubstituteValue
OFF	0x808C0000 BadSensorFailure
OV_870	0x803C0000 BadOutOfRange
N_UPDATE	0x80310000 BadNoCommunication

13. SNMP agent

13.1 SNMP architecture


The Windows SNMP agent supports SNMP version 2 (SNMPv2c). It also supports the SNMP functions (GET, GETNEXT, GETBULK, SET, TRAP).

More details about Microsoft's implementation of the SNMP can be found on the Microsoft TechNet Website: "How SNMP Works"

<http://technet2.microsoft.com/windowsserver/en/library/bf555774-2d63-4e96-b432-c4b7bcac6b531033.mspx>


(<http://technet2.microsoft.com/windowsserver/en/library/bf555774-2d63-4e96-b432-c4b7bcac6b531033.mspx>)

WINDOWS OPERATING SYSTEM COMPONENTS WITH A CONNECTION TO THE PROCESS GATEWAY AND THE RUNTIME:



13.2 Management Information Base (MIB)

The Management Information Base (MIB) is organized in the form of a tree structure, in which the SNMP agent provides the variables = (OID – Object Identifier). See below: the MIB structure, with additional variables provided via the Process Gateway.




13.3 MIB structure

Info block structure is always present				
OID	Description	Data type	Access	Change is sent as Trap
1.3.6.1.4.1.300.1.1.0	copadata.info.statusinfo, Runtime is (Online, Offline)	string	read	yes
1.3.6.1.4.1.300.1.2.0	copadata.info.statusval, Runtime is 1=Online 0=Offline	integer	read	yes
1.3.6.1.4.1.300.1.3.0	copadata.info.watchdog	integer	read	no
1.3.6.1.4.1.300.1.4.0	copadata.info.project, name of project which the Process Gateway reads variables from	string	read	no


Variable structure (table) is dynamically adjusted, according to the configuration of the Process Gateway				
OID	Description	Data type	Access	Change is sent as Trap
1.3.6.1.4.1.300.2.1.0	copadata.variables.ifNumber, number of configured variables=OID	integer	read	yes
1.3.6.1.4.1.300.2.2.1.X	copadata.variables.ifTables.ifIndex, configured OID index from the Process Gateway configuration	integer	read	no
1.3.6.1.4.1.300.2.2.2.X	copadata.variables.ifTables.ifName, variable name	string	read	no
1.3.6.1.4.1.300.2.2.3.X	copadata.variables.ifTables.ifValue, variable value as Integer. All numerical data types are formatted to an SNMP Integer data type. ATTENTION: the decimal places of REAL and DOUBLE are lost.	integer	according to configuration in Process Gateway	no
1.3.6.1.4.1.300.2.2.4.X	copadata.variables.ifTables.ifValueAs String, variable value as String. All numerical data types are formatted to an SNMP String data type.	string	according to configuration in Process Gateway	yes
1.3.6.1.4.1.300.2.2.5.X	copadata.variables.ifTables.ifStatus, variable status value	integer	read	yes
1.3.6.1.4.1.300.2.2.6.X	copadata.variables.ifTables.ifTimestamp, variable time stamp	integer	read	yes

13.4 Module configuration

The following dialog appears after the **Settings** button is clicked:



Here the variables that should be connected can be selected. On the left-hand side all variables which are available in zenon are displayed. You can select them there and move them to the SNMP export list with the button > With the button < they can be removed again. If you move a variable to the export list, a dialog for the name assignment of the zenon variable to an OID address in the SNMP structure appears:



The variables selected in this way are then available on the SNMP server and are continuously synchronized between zenon and the SNMP OID structure. For every OID address you can define whether it can be write-accessed via SNMP SET. The exact structure of every OID address is described in the chapter "MIB structure."

13.5 Configuration file: specific entries for Access SNMP

The configuration file must be in the system folder.

Parameter	Description
[SNMP]	
REFRESHRATE	Update time in milliseconds

Parameter	Description
[VARIABLES]	
COUNT	number of variables to be exported
NAME_n	name of the variable with the number n ($0 \leq n < \text{COUNT}$)
PARAM_n	Parameter SNMP OID table offset and the information R=read only / RW=read and write with the number n ($0 \leq n < \text{COUNT}$)

EXPORT OF VARIABLES

For the successful export the project name in `zenProcgateway.ini` in folder `%CD_SYSTEM%` must be entered correctly. Enter it here:

```
[DEFAULT]
PROJECT=
```

Attention: If the entry is wrong or missing the gateway is closed without any error messages. Thus the variable is not available.

13.6 Configuration of the Windows SNMP agent

To make sure that the Windows SNMP Agent (**SNMP.exe**) provides the zenon MIB partial structure, the Process Gateway file **AccessSNMP.dll** in the registry must be configured accordingly:

1. Installation of the Windows SNMP service via the control panel:
 - Via module: *Programs and functions* - > *Activate or deactivate Windows functions*.

Note: With Windows 8, the computer must be restarted once the SNMP service has been added.

2. Installation of Process Gateway with the file `AccessSNMP.dll` in the folder `%Program Files (x86)%\COPA-DATA\zenon 7.60`

3. Add the following keys and character strings using the registry editor. The paths and content are sometimes different for 32-bit systems and 64-bit systems:

32-Bit:

- **[HKEY_LOCAL_MACHINE\SYSTEM\CurrentControlSet\Services\SNMP\Parameters\ExtensionAgents]**
Name=ProcessGateway
Wert=SOFTWARE\COPA-DATA\SNMP\CurrentVersion
- **[HKEY_LOCAL_MACHINE\SOFTWARE\COPA-DATA\SNMP\CurrentVersion]**
Name=Pathname
Wert=C:\Program Files\COPA-DATA\zenon 7.60 SP0\AccessSNMP.dll

64-Bit:


- **[HKEY_LOCAL_MACHINE\SYSTEM\CurrentControlSet\Services\SNMP\Parameters\ExtensionAgents]**
Name=ProcessGateway
Wert=SOFTWARE\COPA-DATA\SNMP\CurrentVersion
- **[HKEY_LOCAL_MACHINE\SOFTWARE\Wow6432Node\COPA-DATA\SNMP\CurrentVersion]**
Name=Pathname
Wert=C:\Program Files (x86)\COPA-DATA\zenon 7.60 SP0\AccessSNMP.dll

4. Start the SNMP service.

This loads the process gateway file `AccessSNMP.dll` via the registry configuration.


Further configuration settings for the Windows SNMP service: Control panel -> Administration-> Services-> SNMP service-> Properties

- a) **Traps:** tab Defines the IP address in the network to which traps are sent:



- **Communityname:** Must be identical on manager and agent

- **Trap destinations:** Addresses of the destinations as host names, IP addresses or IPX addresses
- a) **Security:** tab Defines the rights with which an SNMP client can access the SNMP agent:



- **Rights:** Must be set to "READ WRITE"
- **Community:** Must be identical on manager and agent

14. SQL

14.1 Module configuration

The configuration of the database connection consists of two parts.

1. OLE-DB connection: This OLE-DB connection can be defined in the configuration dialog using the selection button for the connect string. Then the standard dialog for data connection properties is opened.
2. Additionally the name of the table can be defined, if the standard name ONLINE_VALUES should not be used.

This can be set with the **TABLE** entry in the **[DATABASE]** section of the configuration file (`zenProcGateway.ini`). The settings are taken over by the add-on when starting it.



Attenzione

If table names are defined manually in the configuration file (zenProcGateway.ini), these table names must also be amended or created in the database by hand.


ORACLE DATABASES

Use of the Process Gateway and `AccessSQL.dll` in conjunction with Oracle databases can cause errors: It is possible, with some ODBC drivers, that no online values are written to the database. The advanced ODBC logging then issues the error message "**1843**".

The problem can be solved by changing the ODBC driver. **Example:** ODBC driver 9.02.00.05 for Oracle 9.2.



14.2 Variable selection

In the configuration dialog the zenon variables that should be written to the SQL process image can be defined. In order to do this the variables available in the zenon project - listed in the left part - have to be added to the image - listed in the right part.



14.3 Creating tables

After closing the configuration dialog with **OK**, the table structure of the SQL database is automatically generated. For the case, that it is created by hand:



14.4 Operation in a redundant system

In redundant operation two alternatives are available. In the first variation the SQL database runs locally on both servers and the Process Gateway also runs on both servers. As only online values are handled

no further alignment between the databases is necessary. The big disadvantage of this version is the high network load that is a result from the additional reading of online values on the Standby Server.

In the second version the Process Gateway only runs on the Runtime server and writes data to a local or a remote SQL database. In this alternative no additional network load between the Runtime Server and the Standby Server occurs and in the case of the remote SQL database the Server is not strained by external requests to that database.

14.5 Configuration file: specific entries for AccessSQL

The configuration file must be in the system folder.

Parameter	Description
[DATABASE]	
INITSTRING	OLE-DB connect-string to the SQL database
TABLE_ONL	name of the table that receives the process image
TABLE_VAR	name of the table that receives the variable IDs
REFRESHRATE	maximum refresh rate in milliseconds

Parameter	Description
[VARIABLES]	
COUNT	number of variables to be exported
NAME_n	name of variable number n (0

14.6 Table format

14.6.1 Table for process image

VARIABLE	<code>int[4]</code>	ID of the zenon variable
VALUE	<code>varchar[64]</code>	current value as string
VALUE_NUM	<code>float</code>	current value as float
TIMESTAMP	<code>int[4]</code>	time stamp of the current value (as UNIX time)
TIMESTAMP 2	<code>datetime</code>	time stamp of the current value (as datetime)
STATUS	<code>int[4]</code>	status word of the current value

14.6.2 Table for variable IDs

VARIABLE	<code>int[4]</code>	ID of the zenon variable
NAME	<code>varchar[128]</code>	name of the control system variable