



zenon
by COPA-DATA

zenon manual

Status processing

v.8.20



© 2020 Ing. Punzenberger COPA-DATA GmbH

All rights reserved.

Distribution and/or reproduction of this document or parts thereof in any form are permitted solely with the written permission of the company COPA-DATA. Technical data is only used for product description and are not guaranteed properties in the legal sense. Subject to change, technical or otherwise.

Contents

1	Welcome to COPA-DATA help	5
2	Status processing	5
3	Status bits.....	6
3.1	User status 1 to 8 [M1-M8] and 14 to 16 [M14-M16]	11
3.2	Select in the network [NET_SEL].....	12
3.3	Revision [REVISION].....	12
3.4	In operation [PROGRESS].....	13
3.5	Run time exceeded [TIMEOUT]	14
3.6	Manual value [MAN_VAL].....	14
3.7	General interrogation [GI]	15
3.8	Spontaneous [SPONT]	15
3.9	Invalid [INVALID].....	15
3.10	External standard time [T_STD_E]	16
3.11	Switched off [OFF]	16
3.12	Real time - external time stamp [T_EXTERN].....	17
3.13	Internal time stamp [T_INTERN].....	18
3.14	Not sortable [N_SORTAB].....	19
3.15	Fault message transformer value [FM_TR]	19
3.16	Run message transformer value [RM_TR].....	19
3.17	Info for variable [INFO].....	20
3.18	Alternative value [ALT_VAL]	20
3.19	Not updated in the zenon network [N_UPDATE]	21
3.20	Internal standard time [T_STD]	22
3.21	Cause of Transmission [COTx]	22
3.22	P/N-Bit (N_CONF).....	24
3.23	Test bit [TEST].....	25
3.24	Acknowledge writing [WR-ACK]	25
3.25	Writing successful [WR-SUC].....	25
3.26	Normal status [NORM]	25
3.27	Deviation normal status [N_NORM]	26

3.28 IEC status: Blocked [BL_870]	26
3.29 IEC status: Substituted [SB_870]	26
3.30 IEC status: Not Topical [NT_870]	26
3.31 IEC status: Overflow [OV_870]	27
3.32 Command step: Select [SE_870]	27
3.33 External time stamp invalid [T_INVALID]	28
3.34 Breaker tripping detected [CB_TRIP]	28
3.35 Breaker tripping detection inactive [CB_TR_I]	29
3.36 Value out of the valid range [OR_DRV]	30
3.37 ClockNotSynchronized [T_UNSYNC]	30
3.38 Not recorded in the Process Recorder [PR_NR]	31
3.39 Time deviation [T_DEV]	31
4 Usage	32
4.1 Reaction matrices	32
4.2 Dynamic screen elements	33
4.3 Combined element	33
4.4 Report Generator	34
4.5 Recipegroup Manager	34
4.6 VBA	34
4.7 Process Recorder	34

1 Welcome to COPA-DATA help

ZENON VIDEO TUTORIALS

You can find practical examples for project configuration with zenon in our YouTube channel (https://www.copadata.com/tutorial_menu). The tutorials are grouped according to topics and give an initial insight into working with different zenon modules. All tutorials are available in English.

GENERAL HELP

If you cannot find any information you require in this help chapter or can think of anything that you would like added, please send an email to documentation@copadata.com.

PROJECT SUPPORT

You can receive support for any real project you may have from our customer service team, which you can contact via email at support@copadata.com.

LICENSES AND MODULES

If you find that you need other modules or licenses, our staff will be happy to help you. Email sales@copadata.com.

2 Status processing

With the status administration you get a better overview in the process and in the network. Each variable can have its own statuses. A total of 64 statuses/attributes have been defined.

The most common statuses are:

- ▶ *spontaneous* (on page 15)
(status bit 17 - *SPONT*)
- ▶ Interrupted or invalid (on page 15)
(status bit 18 - *INVALID*)

- ▶ Manual value (on page 14)
(status bit 12 - *MAN_VAL*)
- ▶ Alternate value (on page 20)
(status bit 27 - *ALT_VAL*)

⚠ Attention

The **driver for internal variables** does not support status administration. Use the **driver for simulator variables** instead.

In the Runtime there are several possibilities to evaluate the status of a variable, as for example: the combined element, the reaction matrices (on page 32) and the Report Generator. The status is also accessible in VBA or VSTA as well as in the Recipegroup Manager.

If a variable is saved in zenon, such as in the **Archive**, **CEL**, or **AML**, the entry consists of three pieces of information: value, time stamp and state. This means: Each archived value also contains the correct status.

COMMUNICATION ERROR

Communication errors are also shown in color in the Runtime.

Default color coding of screen items for errors:

- ▶ **Communication failure to PLC:** *red square* (hex value: #FF0000)
- ▶ **Communication failure to server:** *blue square* (hex value: #0000FF)
- ▶ **Unknown value in Process Recorder:** *yellow square* (hex value: #FFC000)

These colors can be adjusted in the project properties in the **Graphical design/Status of variable** node.

3 Status bits

The following status bits are available in zenon:

Bit number	Short term	Long name	zenon Logic identifier
0 (on page 11)	M1	User status 1; for Command Processing: Action type "Block"; Service Tracking of the IEC 850 driver	_VSB_ST_M1
1 (on page 11)	M2	User status 2	_VSB_ST_M2

Bit number	Short term	Long name	zenon Logic identifier
11)			
2 (on page 11)	M3	User status 3	_VSB_ST_M3
3 (on page 11)	M4	User status 4	_VSB_ST_M4
4 (on page 11)	M5	User status 5	_VSB_ST_M5
5 (on page 11)	M6	User status 6	_VSB_ST_M6
6 (on page 11)	M7	User status 7	_VSB_ST_M7
7 (on page 11)	M8	User status 8	_VSB_ST_M8
8 (on page 12)	NET_SEL	Select in the network	_VSB_SELEC
9 (on page 12)	REVISION	Revision	_VSB_REV
10 (on page 13)	PROGRESS	In operation	_VSB_DIREC
11 (on page 14)	TIMEOUT	Command "Timeout exceeded" (command runtime exceeded)	_VSB_RTE
12 (on page 14)	MAN_VAL	Manual value	_VSB_MVALUE
13 (on page 11)	M14	User status 14	_VSB_ST_14
14 (on page 11)	M15	User status 15	_VSB_ST_15
15 (on page 11)	M16	User status 16	_VSB_ST_16
16 (on page 15)	GI	General interrogation	_VSB_GR

Bit number	Short term	Long name	zenon Logic identifier
17 (on page 15)	SPONT	Spontaneous	_VSB_SPONT
18 (on page 15)	INVALID	Invalid	_VSB_I_BIT
19 (on page 16)	T_STD_E	External standard time (standard time) Caution: up to version 7.50, this was the status bit T_CHG_A	_VSB_SUWI
20 (on page 16)	OFF	Switched off	_VSB_N_UPD
21 (on page 17)	T_EXTERN	Real time - external time stamp	_VSB_RT_E
22 (on page 18)	T_INTERN	Internal time stamp	_VSB_RT_I
23 (on page 19)	N_SORTAB	Not sortable	_VSB_NSORT
24 (on page 19)	FM_TR	Error message transformer value	_VSB_DM_TR
25 (on page 19)	RM_TR	Working message transformer value	_VSB_RM_TR
26 (on page 20)	INFO	Information for the variable	_VSB_INFO
27 (on page 20)	ALT_VAL	Alternate value	_VSB_AVALUE
28	RES28	Reserved for internal use (alarm flashing)	_VSB_RES28
29 (on page 21)	N_UPDATE	Not updated (zenon network)	_VSB_ACTUAL
30 (on page 22)	T_STD	Internal standard time	_VSB_WINTER
31	RES31	Reserved for internal use (alarm	_VSB_RES31

Bit number	Short term	Long name	zenon Logic identifier
		flashing)	
32 (on page 22)	COT0	Cause of transmission bit 1	_VSB_TCB0
33 (on page 22)	COT1	Cause of transmission bit 2	_VSB_TCB1
34 (on page 22)	COT2	Cause of transmission bit 3	_VSB_TCB2
35 (on page 22)	COT3	Cause of transmission bit 4	_VSB_TCB3
36 (on page 22)	COT4	Cause of transmission bit 5	_VSB_TCB4
37 (on page 22)	COT5	Cause of transmission bit 6	_VSB_TCB5
38 (on page 24)	N_CONF	Negative confirmation of command by device (IEC 60870 [P/N])	_VSB_PN_BIT
39 (on page 25)	TEST	Test bit (IEC870 [T])	_VSB_T_BIT
40 (on page 25)	WR_ACK	Writing acknowledged	_VSB_WR_ACK
41 (on page 25)	WR_SUC	Writing successful	_VSB_WR_SUC
42 (on page 25)	NORM	Default status	_VSB_NORM
43 (on page 26)	N_NORM	Deviation normal status	_VSB_ABNORM
44 (on page 26)	BL_870	IEC 60870 status: <i>blocked</i>	_VSB_BL_BIT
45 (on page 26)	SB_870	IEC 60870 status: <i>substituted</i>	_VSB_SP_BIT
46 (on page 26)	NT_870	IEC 60870 status: <i>not topical</i>	_VSB_NT_BIT

Bit number	Short term	Long name	zenon Logic identifier
47 (on page 27)	OV_870	IEC 60870 status: <i>overflow</i>	_VSB_OV_BIT
48 (on page 27)	SE_870	IEC 60870 status: <i>select</i>	_VSB_SE_BIT
49 (on page 28)	T_INVALID	External time stamp invalid	not defined
50 (on page 28)	CB_TRIP	Breaker tripping detected	not defined
51 (on page 29)	CB_TR_I	Breaker tripping detection inactive	not defined
52 (on page 30)	OR_DRV	Value out of the valid range (IEC 61850)	not defined
53 (on page 30)	T_UNSYNC	ClockNotSynchronized (IEC 61850)	not defined
54 (on page 31)	PR_NR	Not recorded in the Process Recorder	not defined
55 (on page 31)	T_DEV	Configured time difference between internal and external timestamp reached.	not defined
56	RES56	reserved	not defined
57	RES57	reserved	not defined
58	RES58	reserved	not defined
59	RES59	reserved	not defined
60	RES60	reserved	not defined
61	RES61	reserved	not defined
62	RES62	reserved	not defined
63	RES63	reserved	not defined



Information

In formulas all status bits are available. For other use the availability can be limited.

Note:

- ▶ The single states are not available for all drivers.
- ▶ As the statuses of each variable can also be accessed from VBA/VSTA in form of a 64 bit value, the bit position of each status is also listed in the detailed description below. This information is necessary for the individual evaluation with VBA/VSTA.
- ▶ There are two possibilities for display in Runtime: the short form and the long form. These are separated in the description by a "/".
- ▶ For each user status, its own text can be defined. This text then is displayed in the different modules (editors such as Runtime). In this case, the short text and long text is separated by a semi-colon ";".

To do this, the following entries must be inserted into *project.ini*:

[STATUS]

STATUS0=MS_K;my status 0

STATUS1=ET;custom text

.....

STATUS63=RES;not used

3.1 User status 1 to 8 [M1-M8] and 14 to 16 [M14-M16]

Bit number	Display	Set	Available
0	M1; user state 1	based on user; for Command Processing: Action type "Block"; Service Tracking of the IEC 850 driver	with all drivers Exception: Not available for internal driver
1 bis 7	M2 to M8; user state 8	by the user	with all drivers Exception: Not available for internal driver

Bit number	Display	Set	Available
13 bis 15	M14; user state 14 to M16; user state 16	by the user	with all drivers Exception: Not available for internal driver

The total of 11 user status bits can be used project-specifically. Examof usage for these user status bits are e.g.: special interlockings of Command Processing or flags for own information.



Information

The user status bit M1 is used by the command processing action *Block* to mark the switching point as blocked. The bit is also used in the IEC850 driver when transferring service tracking data to Runtime.

You can find further information in the command processing manual and in the IEC850 driver documentation.

3.2 Select in the network [NET_SEL]

Bit number	Display	Set	Available
8	NET_SEL; selected in zenon network	automatic	with all drivers

The NET_SEL status bit highlights the response variable during command processing in the zenon network. If the NET_SEL bit is set, another command selection - from a further workspace (for example from another client in the network) - cannot be executed on the same response variable.

The NET_SEL status bit is set:

- ▶ If a command processing screen that is linked to the response variable is opened.
- ▶ When executing a command processing action using the context menu or in the Command Sequencer module.
- ▶ When executing an auto/remote command (via VBA, Process Gateway etc.).

3.3 Revision [REVISION]

Bit number	Display	Set	Available
9	REVISION; Revision	by the user	with all drivers

Variables can be set to revision. If this status is active, alarms and setting of command processing are suppressed by the process control system. It is thus possible to simply not show individual equipment parts from alarming and processing.

Note: Only the alarms and command processing are suppressed. All other limit value properties that are linked to this, such as **Limit value color**, **Execute function instantly**, **Invisible**, **Flashing** etc., are not affected by this and are displayed or executed. The current variable values are also shown on the screens as before and also archived.

If linked functions or other properties are suppressed, create a reaction matrix that evaluates the revision status.💡

Information

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to PLC** project property: Enables the color of the display to be amended.

▶

3.4 In operation [PROGRESS]

Bit number	Display	Set	Available
10	PROGRESS; In operation	automatic	only in certain drivers

The status bit **in operation** together with command processing (only SICAM 230 or zenon Energy Edition) is used to show that a switch is in operation, as a result of which the switch will change its position (on/off). The status bit is set and reset when **runtime monitoring** is started, if this has been successfully completed or overwritten (*TIMEOUT* (on page 14)) .

The automatic setting of the bit in Runtime can be activated by activating the **Set status PROGRESS** property.

If the written command already matches the response value, the bit is not set. Only response values *ON* and *OFF* can be monitored.

3.5 Run time exceeded [TIMEOUT]

Bit number	Display	Set	Available
11	TIMEOUT; Runtime exceeded	Automatic; from Runtime monitoring in command processing	only in certain drivers

The **runtime exceeded** status is only set by the **Command Processing** module. The *Command* action type sets the bit if the timeout for the **Watchdog** is exceeded or the command has been ended negatively. This is also applicable if *COT_actterm* is received by the PLC with a **P/N** bit (**COT** value 10 with **N_CONF** - status bits 33, 35 and 38).

The action sets the **TIMEOUT** bit if, during command execution, the expected position of the switching element is not reached. That means: The value of the response variable has a different value to that defined and the Watchdog timer is configured in such a way that it monitors the response variable, possibly also together with the **COT** of the command variable. The next action for this switching element resets the **TIMEOUT** bit.💡 **Information**

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to PLC** project property: Enables the color of the display to be amended.

▶

3.6 Manual value [MAN_VAL]

Bit number	Display	Set	Available
12	MAN_VAL; Manual value	automatic	with all drivers

This status is set, as soon as a value in an archive has been changed by hand. This can be done in the Report Generator or in screen Archive revision.

In addition, the validation of the the **metering point administration** sets this status if a measured value is edited manually.

3.7 General interrogation [GI]

Bit number	Display	Set	Available
16	GI; General interrogation	automatic	with all drivers

After initializing Runtime, the first image that is read is named "general request". That means that the value has not changed since Runtime start.

3.8 Spontaneous [SPONT]

Bit number	Display	Set	Available
17	SPONT; Spontaneous	automatic	with all drivers

Current value is valid. Everything OK.

3.9 Invalid [INVALID]

Bit number	Display	Set	Available
18	INVALID; Invalid	automatic	with all drivers

This bit is set, if there is a problem in the communication with the driver or with a single variable. Most of the zenon drivers however are polling drivers, thus only a general problem in the communication can be indicated (and not a separate one for each variable).

In the event of a fault in the communication, the status bits *INVALID* and *SPONT* exclude each other mutually. However, both bits can be set at the same time for the following exceptions:

- ▶ Protocol-dependent

In some spontaneous protocols, the controllers have the possibility of marking a value as invalid, such as IEC 60870 indicator INV, IEC 61850 Quality. Values marked as such then get the *INVALID* bit, possibly at the same time as with *SPONT*. You can find details in the corresponding driver documentation.

- ▶ Driver monitoring by Runtime

Runtime monitors the availability of the driver by means of a watchdog. This monitoring is not applicable for internal drivers. If a driver is no longer available, the *INVALID* status bit is also set by Runtime. You can find details in the corresponding driver documentation.



Information

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to PLC** project property: Enables the color of the display to be amended.



3.10 External standard time [T_STD_E]

Bit number	Display	Set	Available
19	T_STD_E	automatic	Only in real-time-compatible drivers. Note: You can find out whether the driver is real-time-compatible from the respective driver documentation.

This status indicates whether the time stamp received by the controller is in winter time (bit set) or in summer time (bit not set).

This status can occur together with the status T_EXTERN (on page 17).

Note: Please also note the status T_STD (on page 22) for the internal time stamp.

⚠ Attention

Note: up to version 7.50, this status bit had a different meaning (old identification: T_CHG_A)

3.11 Switched off [OFF]

Bit number	Display	Set	Available
20	OFF; Switched off	by the user	with all drivers

If a variable is not needed online, it can be switched off. So it is no longer read from the hardware and no longer updated.

This state can e.g. be used to exclude not yet active parts of the process from the alarm handling.



Information

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to PLC** project property: Enables the color of the display to be amended.



3.12 Real time - external time stamp [T_EXTERN]

Bit number	Display	Set	Available
21	T_EXTERN	automatic	<p>Only in real-time-compatible drivers.</p> <p>Note: You can find out whether the driver is real-time-compatible from the respective driver documentation.</p>

The time stamp was supplied by an external device. zenon takes this time value as it is. All zenon modules use this time stamp.

⚠Attention

The status of a variable can be either T_EXTERN or T_INTERN .

- ▶ If a value has the status T_EXTERN and no T_INVAL , the value of the the external time stamp is used as a time stamp.
The external time stamp is the time value that the controller has provided together with the value at the driver.
- ▶ If a value has the status T_INTERN or has T_EXTERN and T_INVAL , the value of the internal time stamp is used as a time stamp.
The internal time stamp is the time point at which the driver has received the value from the controller.

Based on this, all zenon modules sort the values.

3.13 Internal time stamp [T_INTERN]

Bit number	Display	Set	Available
22	T_INTERN	automatic	with all drivers

The time stamp is issued by the zenon driver. As soon as the value is read correctly, it is stamped. All modules use this time stamp.

⚠Attention

The status of a variable can be either T_EXTERN or T_INTERN .

- ▶ If a value has the status T_EXTERN and no T_INVAL , the value of the the external time stamp is used as a time stamp.
The external time stamp is the time value that the controller has provided together with the value at the driver.
- ▶ If a value has the status T_INTERN or has T_EXTERN and T_INVAL , the value of the internal time stamp is used as a time stamp.
The internal time stamp is the time point at which the driver has received the value from the controller.

Based on this, all zenon modules sort the values.

Note: The internal time stamp of variable values supports the full resolution of microseconds (μ s).

3.14 Not sortable [N_SORTAB]

Bit number	Display	Set	Available
23	N_SORTAB	automatic	for IEC standards

Only for SICAM 230.

Concerns real-time data flow at the SSI protocol. SSI is used for SK1703 and concerns the AK driver.

State no longer used.

Originally: If a telegram arrived much too late, it receives the status N_SORTAB if it could not be sorted in. As now there is a secondary sorting, the state has no meaning anymore.

3.15 Fault message transformer value [FM_TR]

Bit number	Display	Set	Available
24	FM_TR	automatic	for IEC standards

Only for SICAM 230.

Only for SSI protocol: Implausibel transformer value. IN newer protocols this information is transported via INVALID (on page 15) bit.

SSI is used for SK1703 and concerns the AK driver.



Information

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be activated or deactivated in zenon Editor using the **Representation/Display status of variable** element property.

3.16 Run message transformer value [RM_TR]

Bit number	Display	Set	Available
25	RM_TR	automatic	for IEC standards

Only for SICAM 230.

Concerns SSI protocol and IEC870-101: As long as it is stepped this BIT comes along.

SSI is used for SK1703 and concerns the AK driver.

3.17 Info for variable [INFO]

Bit number	Display	Set	Available
26	INFO	automatic	for IEC standards

Only for SICAM 230.

No longer used.

3.18 Alternative value [ALT_VAL]

Bit number	Display	Set	Available
27	ALT_VAL; alternative value	by the user	with all drivers

To substitute a value, it can be switched to the alternative value. At this the value is completely uncoupled from the process as with Switched off (OFF) (on page 16). Similar to Switch off the last process value is displayed. There is however the possibility to change the alternate value in the Runtime; e.g. via the set value dialog

- ▶ *Modify substitute value:*
Only changes the alternate value
- ▶ *Switch to and modify alternate value:*
Switches to alternate value and changes it to the set value.
- ▶ *Modify spontaneous value:*
A set value is sent to the hardware despite an alternate value. The variable however retains the alternate value.
- ▶ *Switch to spontaneous value:*
Switches off the alternate value.

If no value was transferred, the defined alternate value is used otherwise the last valid value is used.

There are further possibilities to affect the alternate value in **command processing**, via the Recipegroup Manager or the programming interfaces.

If at the time of the switching to the alternate value the state was invalid (INVALID (on page 15)), the state remains. The value has the state *invalid* and *alternate value set*.

The alternate value is not sent to the connected hardware, but stays in the process image on the computer. This value is sent to all modules of zenon and further processed there. So it is for example archived and alarms are created.

Using this state information these values can especially be marked in the report. So on the one hand the changes are traceable, on the other hand the further processing works with correct values.

Example

If an outside temperature sensor is defective, it may send an unrealistic value, e.g. -280°C. Now the user can enter the correct value instead of the defective value by reading the temperature, e.g. 14°C. Now this value is archived, alarmed and logged.

All modules in zenon now use this alternate value.

Information

The status bit is shown in the Runtime with a red square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to PLC** project property: Enables the color of the display to be amended.

▶

3.19 Not updated in the zenon network [N_UPDATE]

Bit number	Display	Set	Available
29	N_UPDATE	automatic	with all drivers

In the zenon network, the status bit is set if the network client loses the connection to the Primary Server or if the variable has the **Only read from Standby Server** property but the Standby Server is not available.



Information

This status bit is shown in the Runtime with a blue square in the top right corner of the screen element.

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variable/Communication failure to server** project property: Enables the color of the display to be amended.

INTEGRATION PROJECT

The integration project is a special case. An integration project can be a standalone project that does however contain network projects.

As a result, the integration project becomes the client for subprojects. In this case, the blue dot indicates that the primary server of the subproject has not yet supplied the data.

ADDITIONAL INFORMATION

The following applies for some drivers: The status *Not updated* (*N_UPDATE*) is set if a value has been requested from the hardware, but no valid value could be read.

3.20 Internal standard time [T_STD]

Bit number	Display	Set	Available
30	T_STD	automatic	with all drivers

This status indicates whether the time stamp is in winter time (bit set) or in summer time (bit not set).

This status accompanies the T_INTERN (on page 18) status.

Note: Please also note the status T_STD_E (on page 16) for the external time stamp.

3.21 Cause of Transmission [COTx]

Bit number	Display	Set	Available
32 - 37	COT0 to COT5	automatic	for energy standards

The Cause of Transmission (COT) in accordance with the IEC60870 protocol.

The value of the Cause of Transmission (see **IEC60870-5-101 7.2.3**) is mapped to status bits 32 - 37. Up to 6 COTx bits can thus be set (x represents bit numbers 0 to 5).

For example: the lowest bit of the COT value is shunted to status bit 32 and named *COT0* in zenon.

The complete COT value can be evaluated in the Runtime via a reaction matrix (multi-numeric or multi-binary). For each COTx bit the value of the cause of transmission is increased as follows:

- ▶ $COT0 = 2^0 = 1$
- ▶ $COT1 = 2^1 = 2$
- ▶ $COT2 = 2^2 = 4$
- ▶ $COT3 = 2^3 = 8$
- ▶ $COT4 = 2^4 = 16$
- ▶ $COT5 = 2^5 = 32$

EXAMPLE

Typical COT values:

Status	Value	Cause of transmission	Short name
COT0	1	<i>periodic, cyclic/poll</i>	COT_per
COT1	2	<i>background scan/integrity</i>	COT_back
COT0, COT1	$1+2 = 3$	<i>spontaneous/reported</i>	COT_spont
COT0, COT1, COT2	$1+2+4 = 7$	<i>activation (command) confirmation</i>	COT_actcon
COT1, COT3	$2+8 = 10$	<i>activation (command) termination</i>	COT_actterm
COT2, COT4	$4+16 = 20$	<i>interrogated by general interrogation</i>	COT_inrogen



Information

The Command Processing module uses the following for watchdog timer of commands:

- ▶ *COTx*
- ▶ *N_CONF*
- ▶ *SE_870* Status

Note:

- ▶ Some Energy drivers support *COTx* status bits, although the protocol itself does not contain COT (e.g. DNP3, IEC850).
- ▶ Some Energy drivers only support an area restricted to the Runtime monitoring in Command Processing.

You can find details in the corresponding driver documentation.

3.22 P/N-Bit (*N_CONF*)

Bit number	Display	Set	Available
38	<i>N_CONF</i>	automatic	for energy standards

Signalizes that the controller has confirmed the command as negative. Corresponds to the P/N bit (*positive/negative response*) in the IEC 60870 protocol. During the command in the IEC 61850 too, the negative confirmations of the Select and Operate command are allocated to the *N_CONF* status bit. Applies together with *COTx*: *COT_actcon(7)*, *COT_actterm(10)*.



Info

The Command Processing module uses the following for watchdog timer of commands:

- ▶ *COTx*
- ▶ *N_CONF*
- ▶ *SE_870* Status

3.23 Test bit [TEST]

Bit number	Display	Set	Available
39	TEST	automatic	IEC870, IEC850

Signalizes the *Test* status in accordance with the IEC 60870 standard or in accordance with IEC 61850: Quality=*Test*. This status bit can be evaluated in the Combined element and in the Interlocking formula. The evaluation of the reaction matrix is available as a multi-binary or multi-numeric reaction matrix.

3.24 Acknowledge writing [WR-ACK]

Bit number	Display	Set	Available
40	WR_ACK	automatic	Driver specific

Is used by the zenon functions **Write set value** or **Write recipe** to request a write confirmation from the driver.

Note: You can find more detailed information in the Variables manual in the **Checking writing of set values** chapter.

3.25 Writing successful [WR-SUC]

Bit number	Display	Set	Available
41	WR_SUC	automatic	Driver specific

If, for a **Set value** or **Execute recipe** action, a writing confirmation should be requested (WR-ACK (on page 25)), this status bit is set accordingly after writing.

Note: You can find more detailed information in the Variables manual in the **Checking writing of set values** chapter.

3.26 Normal status [NORM]

Bit number	Display	Set	Available
42	NORM	automatic	with all drivers

The normal status is defined in the variable properties and evaluated in the status bit NORM.

3.27 Deviation normal status [N_NORM]

Bit number	Display	Set	Available
43	N_NORM	automatic	with all drivers

For bit variables the driver compares the process status with the defined normal status and writes the result to the status bit N_NORM.

3.28 IEC status: Blocked [BL_870]

Bit number	Display	Set	Available
44	BL_870	automatic	IEC870, IEC850

Signalizes *Blocked* status in accordance with the IEC 60870 standard or in accordance with IEC 61850: Quality=*OperatorBlocked*. The controller reports that the value is blocked for transfer and remains in the status it had before it was blocked. This status bit can be selected in Multi reaction matrices, in Combined elements and in the Interlocking formula.

In VBA the top 32 bits can be polled with `StatusExtValue()`. With `SetValueWithStatusEx()` all 64 status bits can be polled.

3.29 IEC status: Substituted [SB_870]

Bit number	Display	Set	Available
45	SB_870	automatic	IEC870, IEC850 Process Gateway IEC870 Slave

Signalizes *Substituted* status in accordance with the IEC 60870 standard or in accordance with IEC 61850: Quality.Source=*Substituted*. The controller reports that the value no longer comes from hardware but was simulated in the controller. This status bit can be selected in Multi reaction matrices, in Combined elements and in the Interlocking formula.

In VBA the top 32 bits can be polled with `StatusExtValue()`. With `SetValueWithStatusEx()` all 64 status bits can be polled.

3.30 IEC status: Not Topical [NT_870]

Bit number	Display	Set	Available
46	NT_870	automatic	IEC870 Process Gateway IEC870 Slave

Signalizes *Not topical* status in accordance with IEC 60870 standard. The controller reports that the value was not updated on the hardware for a certain period of time or is not available. This status bit can be selected in Multi reaction matrices, in Combined elements and in the Interlocking formula.

In VBA the top 32 bits can be polled with `StatusExtValue()`. With `SetValueWithStatusEx()` all 64 status bits can be polled.

3.31 IEC status: Overflow [OV_870]

Bit number	Display	Set	Available
47	OV_870	automatic	IEC870, IEC850 Process Gateway IEC870 Slave

Signalizes *Overflow* status in accordance with the IEC 60870 standard or in accordance with IEC 61850: Quality=*Overflow*. The controller reports that the value is outside the predefined bandwidth or that there is a counter overrun. This status bit can be selected in Multi reaction matrices, in Combined elements and in the Interlocking formula.

3.32 Command step: Select [SE_870]

Bit number	Display	Set	Available
48	SE_870	automatic	for energy standards

The bit is used in energy protocols in conjunction with the **Select before operate** function and serves to make a distinction between the Select- and Execute/Operate-step of a command. Applies together with *COTx*: *COT_act(6)*, *COT_actcon(7)*.

Values:

- ▶ 0 = execute
- ▶ 1 = select

Info

The Command Processing module uses the following for watchdog timer of commands:

- ▶ *COTx*
- ▶ *N_CONF*
- ▶ *SE_870* Status

3.33 External time stamp invalid [T_INVALID]

Bit number	Display	Set	Available
49	T_INVALID	automatic	IEC870, IEC850 Process Gateway IEC870 Slave

The *invalid time* status is set by a driver if the real-time stamp received by the controller is marked as invalid. In this case, the zenon modules use the received value of the variable with the local time stamp of the computer. This status bit can be selected in Multi reaction matrices, in Combined elements and in the Interlocking formula.

⚠Attention

The status of a variable can be either *T_EXTERN* or *T_INTERN*.

- ▶ If a value has the status *T_EXTERN* and no *T_INVALID*, the value of the the external time stamp is used as a time stamp.
The external time stamp is the time value that the controller has provided together with the value at the driver.
- ▶ If a value has the status *T_INTERN* or has *T_EXTERN* and *T_INVALID*, the value of the internal time stamp is used as a time stamp.
The internal time stamp is the time point at which the driver has received the value from the controller.

Based on this, all zenon modules sort the values.

▶

3.34 Breaker tripping detected [CB_TRIP]

Bit number	Display	Set	Available
50	CB_TRIP	Automatic from command processing	with all drivers

The status bit takes the value 1 if breaker tripping detection has been activated in the Command processing module and breaker tripping is detected.

The detection occurs if:

- ▶ the value of the response variable changes from $\neq 0$ to 0 and

- ▶ the status bit *CB_TR_I* (on page 29) (51) is not 1
- ▶ the status bit *PROGRESS* (on page 13) (10) is not 1
- ▶ The value of the response variable is already defined (i.e. it is not the initial value for this variable)

A change to the value of the variable from 0 to $\neq 0$ resets this bit again. This bit is also reset if the *PROGRESS* (on page 13) status bit (10) is active. A change to *CB_TR_I* (on page 29) does not have an influence on a breaker trip that has already been detected.

This status bit can be explicitly modified with the "**Status**", "**Status on**" or "**Status off**" action in the command processing. The status bit contains this status up until the value of the variable switches from $\neq 0$ to 0 or from 0 to $\neq 0$. A requirement for this is that the *CB_TR_I* status bit is 0. This means that breaker tripping detection is not suppressed.

NETWORK

In the network the evaluation is carried out on the server which is responsible for the process. The evaluation is indeed also carried out on the Standby Server but the result is not written to the status bits. The current state of *CB_TR_I* and *CB_TRIP* are synchronized when the Standby Server is started or reconnected. If the response variable is a variable on a local computer, the evaluation is also carried out on the client computer.

3.35 Breaker tripping detection inactive [*CB_TR_I*]

Bit number	Display	Set	Available
51	<i>CB_TR_I</i>	automatic as result of the formula of property Suppress detection in the command processing	with all drivers

Shows that breaker tripping detection is suppressed in command processing for the variable.

The new calculation is triggered in the event of a status change or value change of a variable if this has been defined in the command processing for calculations in formulas. The formula is not evaluated and the result is not written to the status if:

- ▶ one of the variables in the formula does not have a defined value and status yet
or
- ▶ one of the variables is invalid (INVALID).

This status bit can be explicitly modified with the "**Status**", "**Status on**" or "**Status off**" action in the command processing. The status bit will then remain in this state until the result of the formula changes and a different status bit status occurs as a result.

Attention: The detection of a breaker tripping (*CB_TRIP*) and the setting breaker tripping detection inactive at the same time does not work.

Example: The "*RM.Value<1*" will detect breaker tripping (*CB_TRIP* = 1), because *CB_TR_I* is not yet active at the time of the value change.

NETWORK

In the network the evaluation is carried out on the server which is responsible for the process. The evaluation is indeed also carried out on the Standby Server but the result is not written to the status bits. The current state of *CB_TR_I* and *CB_TRIP* are synchronized when the Standby Server is started or reconnected. If the response variable is a variable on a local computer, the evaluation is also carried out on the client computer.

3.36 Value out of the valid range [OR_DRV]

Bit number	Display	Set	Available
52	OR_DRV	automatic	IEC850

Signalizes *Out of Range* in accordance with the IEC 61850 standard, corresponds to *Quality=OutOfRange*. The controller reports that the value is outside of the predefined measurement range. This status bit can be selected in the Combined element and in the Interlocking formula.

3.37 ClockNotSynchronized [T_UNSYNC]

Bit number	Display	Set	Available
55	T_UNSYNC	automatic	IEC850

Signalizes *ClockNotSynchronized* information in *TimeQuality* in accordance with the IEC 61850 standard. The controller informs you that its clock is not synchronized with an external time source.

This status bit can be selected in the combined element.



Information

You can find further information about this in the documentation for the IEC850 driver in the Quality, time stamp and status bits of the variable chapter.

3.38 Not recorded in the Process Recorder [PR_NR]

Bit number	Display	Set	Available
54	PR_NR	automatic	For the Process Recorder in playback mode

This status bit shows in the Runtime that the variable has not been recorded during playback in the **Process Recorder**. No value is therefore known in the playback.



Information

This status bit is shown in the Runtime with a yellow square in the top right corner of the screen element.

The display of this yellow square is treated as a higher priority than the other status displays (red or blue).

The display can be amended individually using the properties in the zenon Editor:

- ▶ **Representation/Display status of variable** element property: Activates or deactivates the display.
- ▶ **Status of variableUnknown value in Process Recorder** project property/: Enables the color of the display to be amended.

WRITE PROTECTION

This bit is only issued by the **Process Recorder**. Because the bit is for the identification of non-recorded variables during playback, the bit must not be set the other way.

This means that the following functionality is not possible:

- ▶ Forwarding of the bits through the zenon allocation.
- ▶ Manual changes through:
 - ▶ Recipegroup Manager
 - ▶ zenon API:

e.g.: Value changes, as configured in the **Non linear value adjustment with macros** property.

3.39 Time deviation [T_DEV]

Bit number	Display	Set	Available
55	T_DEV	automatic	Only in real-time-compatible drivers.

Bit number	Display	Set	Available
			Note: You can find out whether the driver is real-time-compatible from the respective driver documentation.

This bit is only calculated if the external timestamp is also set.

The external and internal timestamps are compared in Runtime. If the deviation is greater than the configured value, the status bit is set. The value is configured in the property **Timestamp Deviation** for the tag or data type in the property group **Value calculation**.

The status bit can then be evaluated in a multi-binary or multi-numeric reaction matrix. In Runtime, the calculated time difference can be displayed in a screen from type **Alarm Message List Filter** or **Chronological Event List Filter** in the *Time difference* column. Note that this column is hidden by default.

4 Usage

4.1 Reaction matrices

The reaction matrices are the most sophisticated way to deal with statuses.

Here single statuses can be evaluated and cause alarms. Basically a status can be treated like a value. As with a value it is also possible with a status to cause certain actions.

As for example:

- ▶ Generate alarm
- ▶ Generate entry in CEL
- ▶ Execute function
- ▶ Flashing
- ▶ Color change
- ▶ Print

Example:


If a value becomes invalid, it gets the state INVALID (on page 15). This happens when the driver loses the connection to the PLC. You can create a reaction matrix, which causes an alarm, as soon as the value becomes invalid (INVALID). There is the possibility to evaluate these alarms afterwards.

4.2 Dynamic screen elements


All dynamic screen elements offer the possibility to display the status of the linked variable. This is done with the property **Display status of variable**.

It is then possible to display the status in the Runtime with the right mouse key.

In the Runtime the status is displayed by clicking the dynamic element with the right mouse key. As long as the mouse button stays pressed down, the variable name and the current status of the variable is displayed.



If the status display is activated, some states are shown in the top right corner of the element by a small colored rectangle, such as red for *INVALID* or *ALT_VAL*:



This indicates, that the value no longer is spontaneous. By clicking the element with the right mouse key it becomes obvious, that somebody changed the status to the alternative value.

4.3 Combined element

The Combined Element offers the possibility to evaluate and graphically display the stati. In contrast to the reaction matrices, the evaluation only has an effect in the screen.

This means:

1	The color changes
2	Another symbol is displayed
3	displaying another text
4	Other bitmaps are shown
5	changing the color of a symbol

4.4 Report Generator

Also the Report Generator offers the possibility to evaluate the stati.

This is done by using the function **variabler** with the status as a parameter.

The syntax is the following:

```
=variabler(Temperature_outside,status)
```

In the Runtime the display can look like below.

Temperature_outside	21°C	ALT_VARIABLE (on page 20)
---------------------	------	---------------------------

4.5 Recipegroup Manager

The Recipegroup Manager offers the possibility to read, display and change all stati, as long as they are not set by the process (driver). To set status bits, go to dialog Editing a recipe and use column Actions.

4.6 VBA

In VBA there are all possibilities to access and change all stati, as long as they are not set by the process (driver).

4.7 Process Recorder